



Environmental
Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

8/2/2010

Certified Mail

Paul Logsdon
Lima Refining Company
1150 South Metcalf Street
Lima, OH 45804

No	TOXIC REVIEW
No	PSD
No	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
No	MACT
No	NSPS
No	NESHAPS
No	NETTING
No	MAJOR NON-ATTAINMENT
No	MODELING SUBMITTED

RE: FINAL AIR POLLUTION PERMIT-TO-INSTALL
Facility ID: 0302020012
Permit Number: P0106611
Permit Type: Administrative Modification
County: Allen

Dear Permit Holder:

Enclosed please find a final Air Pollution Permit-to-Install (PTI) which will allow you to install or modify the described emissions unit(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, we urge you to read it carefully. Please complete a survey at www.epa.ohio.gov/dapc/permitsurvey.aspx and give us feedback on your permitting experience. We value your opinion.

The issuance of this PTI is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Kevin Boyce," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. If you have any questions regarding this permit, please contact the Ohio EPA DAPC, Northwest District Office. This permit can be accessed electronically on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Issued Air Pollution Control Permits" link.

Sincerely,


Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: U.S. EPA
Ohio EPA-NWDO; Indiana



FINAL

Division of Air Pollution Control
Permit-to-Install
for
Lima Refining Company

Facility ID: 0302020012
Permit Number: P0106611
Permit Type: Administrative Modification
Issued: 8/2/2010
Effective: 8/2/2010



Division of Air Pollution Control
Permit-to-Install
for
Lima Refining Company

Table of Contents

Authorization 1
A. Standard Terms and Conditions 3
1. Federally Enforceable Standard Terms and Conditions 4
2. Severability Clause 4
3. General Requirements 4
4. Monitoring and Related Record Keeping and Reporting Requirements 5
5. Scheduled Maintenance/Malfunction Reporting 6
6. Compliance Requirements 6
7. Best Available Technology 7
8. Air Pollution Nuisance 7
9. Reporting Requirements 7
10. Applicability 8
11. Construction of New Sources(s) and Authorization to Install 8
12. Permit-To-Operate Application 9
13. Construction Compliance Certification 9
14. Public Disclosure 10
15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations 10
16. Fees 10
17. Permit Transfers 10
18. Risk Management Plans 10
19. Title IV Provisions 10
B. Facility-Wide Terms and Conditions 11
C. Emissions Unit Terms and Conditions 13
1. P010, Process 14

Authorization

Facility ID: 0302020012

Facility Description: Petroleum Refinery and Storage

Application Number(s): M0000857

Permit Number: P0106611

Permit Description: Administrative modification to PTI #03-17408, to revise the RATA language for the NOx and SO2 CEMS to the frequency defined in the Consent Decree (once every 3 years), and to remove the language for the ESP stack SO2 CEMS.

Permit Type: Administrative Modification

Permit Fee: \$0.00

Issue Date: 8/2/2010

Effective Date: 8/2/2010

This document constitutes issuance to:

Lima Refining Company
1150 South Metcalf Street
Lima, OH 45804

of a Permit-to-Install for the emissions unit(s) identified on the following page.


Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402
(419)352-8461

The above named entity is hereby granted a Permit-to-Install for the emissions unit(s) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Chris Korleski
Director



Authorization (continued)

Permit Number: P0106611
Permit Description: Administrative modification to PTI #03-17408, to revise the RATA language for the NOx and SO2 CEMS to the frequency defined in the Consent Decree (once every 3 years), and to remove the language for the ESP stack SO2 CEMS.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Emissions Unit ID:	P010
Company Equipment ID:	Process
Superseded Permit Number:	03-17408
General Permit Category and Type:	Not Applicable

A. Standard Terms and Conditions



1. Federally Enforceable Standard Terms and Conditions

- a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:
 - (1) Standard Term and Condition A.2.a), Severability Clause
 - (2) Standard Term and Condition A.3.c) through A. 3.e) General Requirements
 - (3) Standard Term and Condition A.6.c) and A. 6.d), Compliance Requirements
 - (4) Standard Term and Condition A.9., Reporting Requirements
 - (5) Standard Term and Condition A.10., Applicability
 - (6) Standard Term and Condition A.11.b) through A.11.e), Construction of New Source(s) and Authorization to Install
 - (7) Standard Term and Condition A.14., Public Disclosure
 - (8) Standard Term and Condition A.15., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations
 - (9) Standard Term and Condition A.16., Fees
 - (10) Standard Term and Condition A.17., Permit Transfers

2. Severability Clause

- a) A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.
- b) All terms and conditions designated in parts B and C of this permit are federally enforceable as a practical matter, if they are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. Terms and conditions in parts B and C of this permit shall not be federally enforceable and shall be enforceable under State law only, only if specifically identified in this permit as such.

3. General Requirements

- a) The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification.

- b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c) This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d) This permit does not convey any property rights of any sort, or any exclusive privilege.
- e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

4. Monitoring and Related Record Keeping and Reporting Requirements

- a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - (1) The date, place (as defined in the permit), and time of sampling or measurements.
 - (2) The date(s) analyses were performed.
 - (3) The company or entity that performed the analyses.
 - (4) The analytical techniques or methods used.
 - (5) The results of such analyses.
 - (6) The operating conditions existing at the time of sampling or measurement.
- b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - (1) Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the Ohio EPA DAPC, Northwest District Office.

- (2) Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the Ohio EPA DAPC, Northwest District Office. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See A.15. below if no deviations occurred during the quarter.
 - (3) Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted (i.e., postmarked) to the Ohio EPA DAPC, Northwest District Office every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - (4) This permit is for an emissions unit located at a Title V facility. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d) The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the Ohio EPA DAPC, Northwest District Office in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

6. Compliance Requirements

- a) The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.
- b) Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- c) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:

- (1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - (3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - (4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- d) The permittee shall submit progress reports to the Ohio EPA DAPC, Northwest District Office concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
- (1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - (2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

7. Best Available Technology

As specified in OAC Rule 3745-31-05, new sources that must employ Best Available Technology (BAT) shall comply with the Applicable Emission Limitations/Control Measures identified as BAT for each subject emissions unit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a) Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the Ohio EPA DAPC, Northwest District Office.

- b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the Ohio EPA DAPC, Northwest District Office. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

10. Applicability

This Permit-to-Install is applicable only to the emissions unit(s) identified in the Permit-to-Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

11. Construction of New Sources(s) and Authorization to Install

- a) This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.
- b) If applicable, authorization to install any new emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

- c) The permittee may notify Ohio EPA of any emissions unit that is permanently shut down (i.e., the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31) by submitting a certification from the authorized official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the authorized official that the emissions unit was permanently shut down. At a minimum, notification of permanent shut down shall be made or confirmed by marking the affected emissions unit(s) as "permanently shut down" in Ohio EPA's "Air Services" along with the date the emissions unit(s) was permanently removed and/or disabled. Submitting the facility profile update will constitute notifying of the permanent shutdown of the affected emissions unit(s).
- d) The provisions of this permit shall cease to be enforceable for each affected emissions unit after the date on which an emissions unit is permanently shut down (i.e., emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31). All records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law. All reports required by this permit must be submitted for any period an affected emissions unit operated prior to permanent shut down. At a minimum, the permit requirements must be evaluated as part of the reporting requirements identified in this permit covering the last period the emissions unit operated.

No emissions unit certified by the authorized official as being permanently shut down may resume operation without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

- e) The permittee shall comply with any residual requirements related to this permit, such as the requirement to submit a deviation report, air fee emission report, or other any reporting required by this permit for the period the operating provisions of this permit were enforceable, or as required by regulation or law. All reports shall be submitted in a form and manner prescribed by the Director. All records relating to this permit must be maintained in accordance with law.

12. Permit-To-Operate Application

The permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77. The permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

13. Construction Compliance Certification

The applicant shall identify the following dates in the online facility profile for each new emissions unit identified in this permit.

- a) Completion of initial installation date shall be entered upon completion of construction and prior to start-up.



- b) Commence operation after installation or latest modification date shall be entered within 90 days after commencing operation of the applicable emissions unit.

14. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

16. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

17. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The new owner must update and submit the ownership information via the "Owner/Contact Change" functionality in Air Services once the transfer is legally completed. The change must be submitted through Air Services within thirty days of the ownership transfer date.

18. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

19. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

B. Facility-Wide Terms and Conditions

1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:
 - a) None.

C. Emissions Unit Terms and Conditions



1. P010, Process

Operations, Property and/or Equipment Description:

fluid catalytic cracker (FCC)/carbon monoxide (CO) boiler with ESP

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

(1) None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3)	14.0 lbs ammonia (NH3)/hr and 61.32 tons NH3/yr See b)(2)b.
b.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
c.	OAC rule 3745-17-11(B)(1)	91.2 lbs PE/hr
d.	OAC rule 3745-18-08(C)(5)	0.92 lb sulfur dioxide (SO2)/1,000 lbs of fresh feed
e.	40 CFR, Part 63, Subpart A	See b)(2)c.
f.	40 CFR, Part 63, Subpart UUU	500 parts per million carbon monoxide (CO) by volume, dry basis (ppmvd) at 0% oxygen, as a one-hour block average See b)(2)d. and b)(2)e.

(2) Additional Terms and Conditions

a. This administrative modification involves installation of a new continuous emission monitor (CEM) for CO on the FCC regenerator flue gas exhaust, as listed in paragraph Nos. 94, 101, 102 and 292 of the federal consent decree addendum, civil action No. SA07CA0683RF, dated 11/20/07.

The CEM was installed on 12/1/06 and certified, and a certification letter was issued to the permittee on 9/26/07, stating that the CEM is considered as certified on the date of consent decree addendum signature. Thus, CEM certification became effective on 11/20/07.

The CEM will be used for compliance demonstration and reporting purposes for the CO emission limitation of 500 ppmvd, as established in the federal consent decree addendum.

This PTI includes all previously established emissions limitations, and permit terms and conditions from PTI No. 03-17174 which was issued final on 12/14/06, and PTI No. 03-17408 administrative modification which was issued on 1/31/08.

- b. Best available technology (BAT) requirements for this emissions unit have been determined to be compliance with the terms and conditions of this permit and includes compliance with OAC rule 3745-17-07(A), OAC rule 3745-17-11(B)(1), OAC rule 3745-18-08(C)(5) and 40 CFR, Part 63, Subpart UUU.
- c. Refer to Part II - Specific Facility Terms and Conditions of the final Title V permit minor modification issued on 11/28/05; section A.10, for the requirements of 40 CFR, Part 63, Subpart A - National Emission Standards for Hazardous Air Pollutants - General Provisions.
- d. This emissions unit is subject to Maximum Achievable Control Technology (MACT) standards in 40 CFR, Part 63, Subpart UUU. Applicable rules are listed in Part II - Specific Facility Terms and Conditions, State and Federally Enforceable Section A.15 of the final Title V permit minor modification issued on 11/28/05.
- e. Pursuant to paragraph No. 94 in the federal consent decree addendum, civil action No. SA07CA0683RF, dated 11/20/07, and Table 8 in 40 CFR, Part 63, Subpart UUU, the permittee shall meet an emission limitation of 500 parts per million CO by volume, dry basis (ppmvd) at 0% oxygen, as a one-hour block average.

Pursuant to paragraph No. 102 in the federal consent decree addendum, civil action No. SA07CA0683RF, dated 11/20/07, the CO emission limitation is not applicable during periods of startup, shutdown or malfunction of this emissions unit.

- f. The previous modification of PTI No. 03-17408, issued on 1/31/08, involved installation of new continuous emission monitors (CEMS) for sulfur dioxide, nitrogen oxides and oxygen on the FCC regenerator flue gas exhaust which is located prior to the CO boiler section of this emissions unit; as listed in paragraph Nos. 61, 89 and 291 of the federal consent decree addendum, civil action No. SA07CA0683RF, dated 11/20/07. The CEMS have been installed and certified, and a certification letter was issued to the permittee on 9/26/07, stating that the CEMS are considered as certified on the date of consent decree addendum signature. Thus, CEMS certification became effective on 11/20/07.

The CEMS will be used as part of optimization studies to determine final emission limitations for sulfur dioxide and nitrogen oxides, and also for compliance demonstration and reporting purposes once the final emissions limitations are established pursuant to terms of the consent decree addendum. The permittee will then be required to submit a PTI modification application to incorporate the final emissions limitations.

c) Operational Restrictions

- (1) The permittee shall operate the electrostatic precipitator (ESP) whenever the fluid catalytic cracker unit is in operation, except during periods of startup and shutdown that are exempted pursuant to OAC rule 3745-17-07(A)(3)(a)(I) and 3745-17-07(A)(3)(b)(I), or during malfunctions that are exempted pursuant to OAC rule 3745-17-07(A)(3)(c).
- (2) The permittee shall burn only refinery fuel gas or natural gas in the CO boiler.
- (3) The ammonia injection feed rate into the ESP shall not exceed 14.0 lbs/hr.

d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall operate and maintain the continuous opacity monitoring system to continuously monitor and record the opacity of the particulate emissions from this emissions unit. The continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

The permittee shall maintain records of data obtained by the continuous opacity monitoring system including, but not limited to:

- a. percent opacity on an instantaneous (one-minute) and 6-minute block average basis;
 - b. results of daily zero/span calibration checks and the magnitude of manual calibration adjustments;
 - c. hours of operation of the emissions unit, continuous opacity monitoring system, and control equipment;
 - d. the date, time, and hours of operation of the emissions unit without the control equipment and/or the continuous opacity monitoring system;
 - e. the date, time, and hours of operation of the emissions unit during any malfunction of the control equipment and/or the continuous opacity monitoring system; as well as,
 - f. the reason (if known) and the corrective actions taken (if any) for each such event in d)(1)d. and d)(1)e.
- (2) The permittee shall maintain on-site, the document of certification received from the U.S. EPA or the Ohio EPA's Central Office verifying that the continuous opacity monitoring system has been certified to meet the requirements of 40 CFR, Part 60, Appendix B, Performance Specification 1. The letter/document of certification shall be made available to the Director (the Ohio EPA, Northwest District Office) upon request.

Each continuous monitoring system consists of all the equipment used to acquire and record data in units of all applicable standard(s), and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data processing hardware and software.

- (3) The permittee shall maintain a written quality assurance/quality control plan for the continuous opacity monitoring system, designed to ensure continuous valid and representative readings of opacity and compliance with 40 CFR, Part 60, Appendix B, Performance Specification 1. The plan shall include, at a minimum, procedures for conducting and recording daily automatic zero/span checks, and a description of preventive maintenance activities. The plan shall describe step by step procedures for ensuring accurate operation of the continuous opacity monitoring system on a continuous basis. The quality assurance/quality control plan and a logbook dedicated to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
- (4) The permittee shall install, operate, and maintain equipment to continuously monitor and record NO_x emissions for this emissions unit, in units of parts per million by volume, on a dry basis. The continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

The permittee shall maintain records of data obtained by the continuous NO_x monitoring system including, but not limited to:

- a. emissions of NO_x in parts per million on an instantaneous (one-minute) basis;
 - b. emissions of NO_x in all units of the applicable standard(s) in the appropriate averaging period;
 - c. results of quarterly cylinder gas audits;
 - d. results of daily zero/span calibration checks and the magnitude of manual calibration adjustments;
 - e. results of required relative accuracy test audit(s), including results in units of the applicable standard(s);
 - f. hours of operation of the emissions unit, continuous NO_x monitoring system, and control equipment;
 - g. the date, time, and hours of operation of the emissions unit without the control equipment and/or the continuous NO_x monitoring system;
 - h. the date, time, and hours of operation of the emissions unit during any malfunction of the control equipment and/or the continuous NO_x monitoring system; as well as,
 - i. the reason (if known) and the corrective actions taken (if any) for each such event in d)(4)g and d)(4)h).
- (5) The permittee shall maintain on-site, the document of certification received from the U.S. EPA or the Ohio EPA's Central Office documenting that the continuous NO_x monitoring

system for the FCC regenerator flue gas has been certified to meet the requirements of 40 CFR, Part 60, Appendix B, Performance Specification 2. The letter/document of certification shall be made available to the Director (the Ohio EPA, Northwest District Office) upon request.

Each continuous monitoring system consists of all the equipment used to acquire and record data in units of all applicable standard(s), and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data processing hardware and software.

- (6) The permittee shall maintain a written quality assurance/quality control plan for the continuous NO_x monitoring system for the FCC regenerator flue gas, designed to ensure continuous valid and representative readings of NO_x emissions in units of the applicable standard(s). The plan shall follow the requirements of 40 CFR, Part 60, Appendix F.

The quality assurance/quality control plan and a logbook dedicated to the continuous NO_x monitoring system must be kept on site and available for inspection during regular office hours.

The plan shall include the requirement to conduct quarterly cylinder gas audits or relative accuracy audits as required in 40 CFR, Part 60; and to conduct relative accuracy test audits in units of the standard(s), in accordance with and at the frequencies required per 40 CFR, Part 60, except as noted below.

Pursuant to paragraph No. 62 of the federal consent decree addendum, civil action No. SA07CA0683RF, dated 11/20/07, the permittee is required to:

- a. Conduct a relative test audit of the NO_x CEM at a minimum frequency of once every three years; and
 - b. Conduct cylinder gas audits on the NO_x CEM during each quarter when a relative accuracy test audit is not conducted.
- (7) The permittee shall install, operate, and maintain equipment to continuously monitor and record SO₂ emissions from this emissions unit, in units of parts per million by volume, on a dry basis. The continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR, Part 60.

The permittee shall maintain records of data obtained by the continuous SO₂ monitoring system including, but not limited to:

- a. emissions of SO₂ in parts per million on an instantaneous (one-minute) basis;
- b. emissions of SO₂ in all units of the applicable standard(s) in the appropriate averaging period;
- c. results of quarterly cylinder gas audits;
- d. results of daily zero/span calibration checks and the magnitude of manual calibration adjustments;

- e. results of required relative accuracy test audit(s), including results in units of the applicable standard(s);
 - f. hours of operation of the emissions unit, continuous SO₂ monitoring system, and control equipment;
 - g. the date, time, and hours of operation of the emissions unit without the control equipment and/or the continuous SO₂ monitoring system;
 - h. the date, time, and hours of operation of the emissions unit during any malfunction of the control equipment and/or the continuous SO₂ monitoring system; as well as,
 - i. the reason (if known) and the corrective actions taken (if any) for each such event in d)(7)g. and d)(7)h.
- (8) The permittee shall maintain on-site, the document of certification received from the U.S. EPA or the Ohio EPA's Central Office documenting that the continuous SO₂ monitoring system for the FCC regenerator flue gas has been certified to meet the requirements of 40 CFR, Part 60, Appendix B, Performance Specification 2.

The letter/document of certification shall be made available to the Director (the Ohio EPA, Northwest District Office) upon request.

Each continuous monitoring system consists of all the equipment used to acquire and record data in units of all applicable standard(s), and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data processing hardware and software.

- (9) The permittee shall maintain a written quality assurance/quality control plan for the continuous SO₂ monitoring system for the FCC regenerator flue gas, designed to ensure continuous valid and representative readings of SO₂ emissions in units of the applicable standard(s). The plan shall follow the requirements of 40 CFR, Part 60, Appendix F.

The quality assurance/quality control plan and a logbook dedicated to the continuous SO₂ monitoring system must be kept on site and available for inspection during regular office hours.

The plan shall include the requirement to conduct quarterly cylinder gas audits or relative accuracy audits as required in 40 CFR, Part 60; and to conduct relative accuracy test audits in units of the standard(s), in accordance with and at the frequencies required per 40 CFR, Part 60, except as noted below.

Pursuant to paragraph No. 90 of the federal consent decree addendum, civil action No. SA07CA0683RF, dated 11/20/07, the permittee is required to:

- a. Conduct a relative accuracy test audit of the SO₂ CEM at a minimum frequency of one every three years, and
- b. Conduct cylinder gas audits on the SO₂ CEM during each quarter when a relative accuracy test audit is not conducted,

- (10) The permittee shall install, operate and maintain equipment to continuously monitor and record oxygen (O₂) emitted from this emissions unit, in units of percent O₂. The continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR, Part 60.

The permittee shall maintain records of data obtained by the continuous O₂ monitoring system including, but not limited to:

- a. percent O₂ on an instantaneous (one-minute) basis;
 - b. results of quarterly cylinder gas audits;
 - c. results of daily zero/span calibration checks and the magnitude of manual calibration adjustments;
 - d. results of required relative accuracy test audit(s);
 - e. hours of operation of the emissions unit, continuous O₂ monitoring system;
 - f. the date, time, and hours of operation of the emissions unit without the continuous O₂ monitoring system;
 - g. the date, time, and hours of operation of the emissions unit during any malfunction of the continuous O₂ monitoring system; as well as,
 - h. the reason (if known) and the corrective actions taken (if any) for each such event in d)(10)f. and d)(10)g.
- (11) The permittee shall maintain on-site, the document of certification received from the U.S. EPA or the Ohio EPA's Central Office documenting that the continuous O₂ monitoring system for the FCC regenerator flue gas has been certified to meet the requirements of 40 CFR, Part 60, Appendix B, Performance Specification 3. The letter/document of certification shall be made available to the Director (the Ohio EPA, Northwest District Office) upon request.

Each continuous monitoring system consists of all the equipment used to acquire and record data in units of all applicable standard(s), and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data processing hardware and software.

- (12) The permittee shall maintain a written quality assurance/quality control plan for the continuous O₂ monitoring system for the FCC regenerator flue gas, designed to ensure continuous valid and representative readings of O₂ emissions in units of the applicable standard(s).

The plan shall follow the requirements of 40 CFR, Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous SO₂ monitoring system must be kept on site and available for inspection during regular office hours.

The plan shall include the requirement to conduct quarterly cylinder gas audits or relative accuracy audits as required in 40 CFR, Part 60; and to conduct relative accuracy test

audits in units of the standard(s), in accordance with and at the frequencies required per 40 CFR, Part 60, except as noted below.

Pursuant to paragraph Nos. 62, 90, 101 of the federal consent decree addendum, civil action No. SA07CA0683RF, dated 11/20/07, the permittee is required to:

- a. Conduct a relative accuracy test audit of the O₂ CEM at a minimum frequency of once every three years; and
 - b. Conduct cylinder gas audits on the O₂ CEM during each quarter when a relative accuracy test audit is not conducted.
- (13) The permittee shall operate and maintain equipment to continuously monitor and record CO emissions from this emissions unit, in units of parts per million by volume, on a dry basis. The continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR, Part 60.

The permittee shall maintain records of data obtained by the continuous CO monitoring system including, but not limited to:

- a. emissions of CO in parts per million on an instantaneous (one-minute) basis;
 - b. emissions of CO in all units of the applicable standard(s) in the appropriate averaging period;
 - c. results of quarterly cylinder gas audits;
 - d. results of daily zero/span calibration checks and the magnitude of manual calibration adjustments;
 - e. results of required relative accuracy test audit(s), including results in units of the applicable standard(s);
 - f. hours of operation of the emissions unit, continuous CO monitoring system, and control equipment;
 - g. the date, time, and hours of operation of the emissions unit without the control equipment and/or the continuous CO monitoring system;
 - h. the date, time, and hours of operation of the emissions unit during any malfunction of the control equipment and/or the continuous CO monitoring system; as well as,
 - i. the reason (if known) and the corrective actions taken (if any) for each such event in d)(13)g. and d)(13)h.
- (14) The permittee shall maintain on-site, the document of certification received from the U.S. EPA or the Ohio EPA's Central Office documenting that the continuous CO monitoring system for the FCC regenerator flue gas has been certified to meet the requirements of 40 CFR, Part 60, Appendix B, Performance Specification 4 or 4a, as appropriate. The letter/document of certification shall be made available to the Director (the Ohio EPA, Northwest District Office) upon request.

Each continuous monitoring system consists of all the equipment used to acquire and record data in units of all applicable standard(s), and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data processing hardware and software.

- (15) The permittee shall maintain a written quality assurance/quality control plan for the continuous CO monitoring system for the FCC regenerator flue gas, designed to ensure continuous valid and representative readings of CO emissions in units of the applicable standard(s). The plan shall follow the requirements of 40 CFR, Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous CO monitoring system must be kept on site and available for inspection during regular office hours.

The plan shall include the requirement to conduct quarterly cylinder gas audits or relative accuracy audits as required in 40 CFR, Part 60; and to conduct relative accuracy test audits in units of the standard(s), in accordance with and at the frequencies required per 40 CFR, Part 60, except as noted below.

Pursuant to paragraph No. 101 of the federal consent decree addendum, civil action No. SA07CA0683RF, dated 11/20/07, the permittee is required to:

- a. conduct a relative accuracy test audit of the CO CEM at a minimum frequency of once every three years; and
 - b. conduct cylinder gas audits on the CO CEM during each quarter when a relative accuracy test audit is not conducted.
- (16) For each day during which the permittee burns a fuel other than refinery fuel gas or natural gas in the CO boiler, the permittee shall maintain a record of the type and quantity of fuel burned.
- (17) The permittee shall properly install, operate, and maintain equipment to continuously monitor and record the ammonia injection feed rate into the ESP. The monitoring equipment shall be installed, calibrated, operated, and maintained in accordance with the manufacturer's recommendations, instructions, and operating manual(s).
- (18) The permit to install for this emissions unit P010 was evaluated based on the actual materials (typically coatings and cleanup materials) and the design parameters of the emissions unit's exhaust system, as specified by the permittee in the permit to install application. The Ohio EPA's "Review of New Sources of Air Toxic Emissions" policy ("Air Toxic Policy") was applied for each pollutant emitted by this emissions unit using data from the permit to install application and the ISC-PRIME (or other Ohio EPA approved model). The predicted 1-hour maximum ground-level concentration from the use of the ISC-PRIME model was compared to the Maximum Acceptable Ground-Level Concentration (MAGLC). The following summarizes the results of the modeling for the "worst case" pollutant(s):

Pollutant: ammonia

TLV (mg/m3): 54.7

Maximum Hourly Emission Rate (lbs/hr): 14.0 lbs/hr

Predicted 1-Hour Maximum Ground-Level Concentration (mg/m³): 2.027

MAGLC (mg/m³): 1,302

- (19) Physical changes to or changes in the method of operation of the emissions unit after its installation or modification could affect the parameters used to determine whether or not the "Air Toxic Policy" is satisfied. Consequently, prior to making a change that could impact such parameters, the permittee shall conduct an evaluation to determine that the "Air Toxic Policy" will still be satisfied. If, upon evaluation, the permittee determines that the "Air Toxic Policy" will not be satisfied, the permittee will not make the change. Changes that can affect the parameters used in applying the "Air Toxic Policy" include the following:
- a. changes in the composition of the materials used (typically for coatings or cleanup materials), or the use of new materials, that would result in the emission of a compound with a lower Threshold Limit Value (TLV), as indicated in the most recent version of the handbook entitled "American Conference of Governmental Industrial Hygienists (ACGIH)," than the lowest TLV value previously modeled;
 - b. changes in the composition of the materials, or use of new materials, that would result in an increase in emissions of any pollutant with a listed TLV that was proposed in the application and modeled; and
 - c. physical changes to the emissions unit or its exhaust parameters (e.g., increased/decreased exhaust flow, changes in stack height, changes in stack diameter, etc.).
- (20) If the permittee determines that the "Air Toxic Policy" will be satisfied for the above changes, the Ohio EPA will not consider the change(s) to be a "modification" under OAC rule 3745-31-01 solely due to the emissions of any type of toxic air contaminant not previously emitted, and a modification of the existing permit to install will not be required, even if the toxic air contaminant emissions are greater than the de minimis level in OAC rule 3745-15-05. If the change(s) is (are) defined as a modification under other provisions of the modification definition, then the permittee shall obtain a final permit to install prior to the change.

The permittee shall collect, record, and retain the following information when it conducts evaluations to determine that the changed emissions unit will still satisfy the "Air Toxic Policy:"

- a. a description of the parameters changed (composition of materials, new pollutants emitted, change in stack/exhaust parameters, etc.);
- b. documentation of its evaluation and determination that the changed emissions unit still satisfies the "Air Toxic Policy"; and
- c. where computer modeling is performed, a copy of the resulting computer model runs that show the results of the application of the "Air Toxic Policy" for the change.

e) Reporting Requirements

(1) The permittee shall comply with the following quarterly reporting requirements for the emissions unit and its continuous opacity monitoring system (COMS):

a. Pursuant to the monitoring, record keeping, and reporting requirements for continuous monitoring systems contained in 40 CFR Parts 60.7 and 60.13(h) and the requirements established in this permit, the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA,

Northwest District Office, documenting all instances of opacity values in excess of any limitation specified in this permit, 40 CFR, Part 60; OAC rule 3745-17-07, and any other applicable rules or regulations.

The report shall document the date, commencement and completion times, duration, and magnitude (percent opacity) of each 6-minute block average exceeding the applicable opacity limitation(s), as well as, the reason (if known) and the corrective actions taken (if any) for each exceedance. If there are no exceedances during the calendar quarter, the permittee shall submit a statement to that effect.

b. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall include the following:

- i. the facility name and address;
- ii. the manufacturer and model number of the continuous opacity monitor;
- iii. a description of any change in the equipment that comprises the COMS, including any change to the hardware, changes to the software that may affect COMS readings, and/or changes in the location of the COMS sample probe;
- iv. the excess emissions report (EER), i.e., a summary of any exceedances during the calendar quarter, as specified above;
- v. the total operating time (hours) of the emissions unit;
- vi. the total operating time of the COMS while the emissions unit was in operation;
- vii. the date, time, and duration of any/each malfunction* of the COMS, emissions unit, and/or control equipment;
- viii. the date, time, and duration of any downtime* of the COMS and/or control equipment while the emissions unit was in operation; and
- ix. the reason (if known) and the corrective actions taken (if any) for each event in e)(1)b.vii. and e)(1)b.viii.

Each report shall address the operations conducted and data obtained during the previous calendar quarter.

* each downtime and malfunction event shall be reported regardless if there is an exceedance of the opacity limit

(2) The permittee shall comply with the following quarterly reporting requirements for the emissions unit and its continuous NOx monitoring system:

a. Pursuant to the monitoring, record keeping, and reporting requirements for continuous monitoring systems contained in 40 CFR 60.7 and 60.13(h) and the requirements established in this permit, the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Northwest District Office, documenting all instances of NOx emissions in excess of any applicable limit specified in this permit, 40 CFR, Part 60; OAC Chapters 3745-14 and 3745-23, and any other applicable rules or regulations.

The report shall document the date, commencement and completion times, duration, and magnitude of each exceedance, as well as the reason (if known) and the corrective actions taken (if any) for each exceedance. Excess emissions shall be reported in units of the applicable standard(s). If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect.

b. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall include the following:

- i. the facility name and address;
- ii. the manufacturer and model number of the continuous NOx and other associated monitors;
- iii. a description of any change in the equipment that comprises the continuous emission monitoring system (CEMS), including any change to the hardware, changes to the software that may affect CEMS readings, and/or changes in the location of the CEMS sample probe;
- iv. the excess emissions report (EER), i.e., a summary of any exceedances during the calendar quarter, as specified above;
- v. the total operating time (hours) of the emissions unit;
- vi. the total operating time of the continuous NOx monitoring system while the emissions unit was in operation;
- vii. results and dates of quarterly cylinder gas audits;
- viii. unless previously submitted, results and dates of the relative accuracy test audit(s), including results in units of the applicable standard(s), (during appropriate quarter(s));
- ix. unless previously submitted, the results of any relative accuracy test audit showing the continuous NOx monitor out-of-control and the compliant results following any corrective actions;

- x. the date, time, and duration of any/each malfunction* of the continuous NOx monitoring system, emissions unit, and/or control equipment;
- xi. the date, time, and duration of any downtime* of the continuous NOx monitoring system and/or control equipment while the emissions unit was in operation; and
- xii. the reason (if known) and the corrective actions taken (if any) for each event in e)(2)b.x. and e)(2)b.xi.

Each report shall address the operations conducted and data obtained during the previous calendar quarter.

* each downtime and malfunction event shall be reported regardless if there is an exceedance of any applicable limit

- (3) The permittee shall comply with the following quarterly reporting requirements for the emissions unit and its continuous SO₂ monitoring system:

- a. Pursuant to the monitoring, record keeping, and reporting requirements for continuous monitoring systems contained in 40 CFR Parts 60.7 and 60.13(h) and the requirements established in this permit, the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Northwest District Office, documenting all instances of SO₂ emissions in excess of any applicable limit specified in this permit, 40 CFR, Part 60; OAC Chapter 3745-18, and any other applicable rules or regulations.

The report shall document the date, commencement and completion times, duration, and magnitude of each exceedance, as well as the reason (if known) and the corrective actions taken (if any) for each exceedance. Excess emissions shall be reported in units of the applicable standard(s). If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect.

- b. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall include the following:
 - i. the facility name and address;
 - ii. the manufacturer and model number of the continuous SO₂ and other associated monitors;
 - iii. a description of any change in the equipment that comprises the continuous emission monitoring system (CEMS), including any change to the hardware, changes to the software that may affect CEMS readings, and/or changes in the location of the CEMS sample probe;
 - iv. the excess emissions report (EER), i.e., a summary of any exceedances during the calendar quarter, as specified above;
 - v. the total operating time (hours) of the emissions unit;

- vi. the total operating time of the continuous SO₂ monitoring system while the emissions unit was in operation;
- vii. results and dates of quarterly cylinder gas audits;
- viii. unless previously submitted, results and dates of the relative accuracy test audit(s), including results in units of the applicable standard(s), (during appropriate quarter(s));
- ix. unless previously submitted, the results of any relative accuracy test audit showing the continuous SO₂ monitor out-of-control and the compliant results following any corrective actions;
- x. the date, time, and duration of any/each malfunction* of the continuous SO₂ monitoring system, emissions unit, and/or control equipment;
- xi. the date, time, and duration of any downtime* of the continuous SO₂ monitoring system and/or control equipment while the emissions unit was in operation; and
- xii. the reason (if known) and the corrective actions taken (if any) for each event in e)(3)b.x. and e)(3)b.xi.

Each report shall address the operations conducted and data obtained during the previous calendar quarter.

* each downtime and malfunction event shall be reported regardless if there is an exceedance of any applicable limit

- (4) The permittee shall comply with the following quarterly reporting requirements for the emissions unit and its continuous O₂ monitoring system:
 - a. Pursuant to the monitoring, record keeping, and reporting requirements for continuous monitoring systems contained in 40 CFR Parts 60.7 and 60.13(h) and the requirements established in this permit, the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Northwest District Office, documenting all instances of continuous O₂ monitoring system downtime and malfunction while the emissions unit was on line.
 - b. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall include the following:
 - i. the facility name and address;
 - ii. the manufacturer and model number of the continuous O₂ and other associated monitors;
 - iii. a description of any change in the equipment that comprises the continuous emission monitoring system (CEMS), including any change to the hardware, changes to the software that may affect CEMS readings, and/or changes in the location of the CEMS sample probe;

- iv. the total operating time (hours) of the emissions unit;
- v. the total operating time of the continuous O₂ monitoring system while the emissions unit was in operation;
- vi. results and dates of quarterly cylinder gas audits;
- vii. unless previously submitted, results and dates of the relative accuracy test audit(s) (during appropriate quarter(s));
- viii. unless previously submitted, the results of any relative accuracy test audit showing the continuous O₂ monitor out-of-control and the compliant results following any corrective actions;
- ix. the date, time, and duration of any/each malfunction* of the continuous O₂ monitoring system while the emissions unit was in operation;
- x. the date, time, and duration of any downtime* of the continuous O₂ monitoring system while the emissions unit was in operation; and
- xi. the reason (if known) and the corrective actions taken (if any) for each event in e)(4)b.ix. and e)(4)b.x.

Each report shall address the operations conducted and data obtained during the previous calendar quarter.

* each downtime and malfunction event shall be reported regardless if there is an exceedance of any applicable limit

- (5) The permittee shall comply with the following quarterly reporting requirements for the emissions unit and its continuous CO monitoring system:
 - a. Pursuant to the monitoring, record keeping, and reporting requirements for continuous monitoring systems contained in 40 CFR 60.7 and 60.13(h) and the requirements established in this permit, the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Northwest District Office, documenting all instances of CO emissions in excess of any applicable limit specified in this permit, 40 CFR, Part 60; OAC Chapter 3745-21, and any other applicable rules or regulations.

The report shall document the date, commencement and completion times, duration, and magnitude of each exceedance, as well as, the reason (if known) and the corrective actions taken (if any) for each exceedance. Excess emissions shall be reported in units of the applicable standard(s).
 - b. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall include the following:
 - i. the facility name and address;
 - ii. the manufacturer and model number of the continuous CO and other associated monitors;

- iii. continuous emission monitoring system (CEMS), including any change to the hardware, changes to the software that may affect CEMS readings, and/or changes in the location of the CEMS sample probe;
- iv. the excess emissions report (EER)*, i.e., a summary of any exceedances during the calendar quarter, as specified above;
- v. the total CO emissions for the calendar quarter (tons);
- vi. the total operating time (hours) of the emissions unit;
- vii. the total operating time of the continuous CO monitoring system while the emissions unit was in operation;
- viii. results and dates of quarterly cylinder gas audits;
- ix. unless previously submitted, results and dates of the relative accuracy test audit(s), including results in units of the applicable standard(s), (during appropriate quarter(s));
- x. unless previously submitted, the results of any relative accuracy test audit showing the continuous CO monitor out-of-control and the compliant results following any corrective actions;
- xi. the date, time, and duration of any/each malfunction** of the continuous CO monitoring system, emissions unit, and/or control equipment;
- xii. the date, time, and duration of any downtime** of the continuous CO monitoring system and/or control equipment while the emissions unit was in operation; and
- xiii. the reason (if known) and the corrective actions taken (if any) for each event in e)(5)b.xi. and e)(5)b.xii.

Each report shall address the operations conducted and data obtained during the previous calendar quarter.

* where no excess emissions have occurred or the continuous monitoring system(s) has/have not been inoperative, repaired, or adjusted during the calendar quarter, such information shall be documented in the EER quarterly report

** each downtime and malfunction event shall be reported regardless if there is an exceedance of any applicable limit

- (6) The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than refinery fuel gas or natural gas is burned in the CO boiler. Each report shall be submitted within 30 days after the deviation occurs.
- (7) The permittee shall submit deviation (excursion) reports that identify all periods of time during startup and shutdown of the emissions unit when the ESP was not in operation and the temperature of the boiler exhaust gases exceeded the temperature levels specified in OAC rule 3745-17-07(A)(3)(a)(I) and (b)(I).

- (8) The permittee shall submit deviation (excursion) reports that identify all periods of time when the ammonia injection feed rate to the ESP exceeded 14.0 lbs/hr. Each report shall be submitted within 30 days after the deviation occurs.

f) Testing Requirements

- (1) Compliance with the emission limitations in section b)(1) of these terms and conditions shall be determined in accordance with the following methods:

a. Emission Limitations:

14.0 lbs NH₃/hr and 61.32 tons NH₃/yr

Applicable Compliance Method:

The lb/hr emission limitation was established on the basis that 100% of the NH₃ injected into the ESP could exit as unreacted NH₃. Therefore provided compliance is shown with the operational restriction not to exceed an NH₃ injection feed rate into the ESP of 14.0 lbs/hr, compliance with the NH₃ lb/hr emission limitation shall be assumed.

If required, compliance with the NH₃ emission limitation shall be determined in accordance with the test methods and procedures specified in 40 CFR, Part 60, Appendix A - Methods 1 through 4 and 206.

As long as compliance with the hourly emission limitation is maintained, compliance with the annual emission limitation shall be assumed (the annual emission limitation was determined by multiplying the hourly emission limitation by 8,760 hrs/yr, and then dividing by 2,000 lbs/ton).

b. Emission Limitation:

Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by the rule.

Applicable Compliance Method:

The permittee shall demonstrate compliance with the visible particulate emission limitation above in accordance with the methods and procedures specified in 40 CFR, Part 60, Appendix A, Method 9 and the requirements specified in OAC rule 3745-17-03(B)(1).

Ongoing compliance with the opacity limitation contained in this permit, 40 CFR, Part 60, and any other applicable standard(s) shall be demonstrated through the data collected as required in the Monitoring and Record keeping Section of this permit; and through demonstration of compliance with the quality assurance/quality control plan, which shall meet the testing and recertification requirements of 40 CFR, Part 60.

c. Emission Limitation:

91.2 lbs of PE/hr

Applicable Compliance Method:

The permittee shall demonstrate compliance with the emission limitation above based upon the results of emission testing conducted in accordance with Methods 1 - 5 of 40 CFR, Part 60, Appendix A (as required in the terms and conditions for this emissions unit in the final Title V permit minor modification issued on 11/28/05.

d. Emission Limitation:

0.92 lb of SO₂/1,000 lbs of fresh feed

Applicable Compliance Method:

The permittee shall demonstrate compliance with the emission limitation above based upon the results of emission testing conducted in accordance with Methods 1 - 4 and 6 of 40 CFR, Part 60, Appendix A (as required in the terms and conditions for this emissions unit in the final Title V permit minor modification issued on 11/28/05.

Ongoing compliance with the SO₂ emission limitations contained in this permit, 40 CFR, Part 60 and any other applicable standard(s) shall be demonstrated through the data collected as required in the Monitoring and Record keeping Section of this permit; and through demonstration of compliance with the quality assurance/quality control plan, which shall meet the testing and recertification requirements of 40 CFR, Part 60.

e. Emission Limitation:

500 parts per million CO by volume, dry basis (ppmvd) at 0% oxygen, as a one-hour block average

Applicable Compliance Method:

Ongoing compliance with the CO emission limitations contained in this permit, 40 CFR, Part 63, and any other applicable standard(s) shall be demonstrated through the data collected as required in the Monitoring and Record keeping Section of this permit; and through demonstration of compliance with the quality assurance/quality control plan, which shall meet the requirements of 40 CFR, Part 60.

g) Miscellaneous Requirements

(1) None.