



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center  
122 S. Front Street  
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center  
P.O. Box 1049  
Columbus, OH 43216-1049

12/27/02

**CERTIFIED MAIL**

**RE: Final Title V Chapter 3745-77 permit**

02-43-16-0009  
CLEVELAND ELECTRIC ILLUMINATING CO., EASTLAKE  
PLANT  
Marjorie G. Twymon - 1  
76 S. Main St.  
13th Floor  
Akron, OH 44308-0000

Dear Marjorie G. Twymon - 1:

Enclosed is the Title V permit that allows you to operate the facility in the manner indicated in the permit. Because this permit may contain several conditions and restrictions, we urge you to read it carefully.

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Review Appeals Commission within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Commission. It is also requested by the Director that a copy of the appeal be served upon the Environmental Enforcement Section of the Office of the Attorney General. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission  
236 East Town Street  
Room 300  
Columbus, Ohio 43215

If you have any questions, please contact Northeast District Office.

Very truly yours,

Michael W. Ahern, Supervisor  
Field Operations and Permit Section  
Division of Air Pollution Control

cc: Northeast District Office  
File, DAPC PMU



State of Ohio Environmental Protection Agency

**FINAL TITLE V PERMIT**

Issue Date: <b>12/27/02</b>	Effective Date: <b>01/17/02</b>	Expiration Date: <b>12/27/07</b>
-----------------------------	---------------------------------	----------------------------------

This document constitutes issuance of a Title V permit for Facility ID: 02-43-16-0009 to:  
**CLEVELAND ELECTRIC ILLUMINATING CO., EASTLAKE PLANT**  
**10 ERIE ROAD**  
**Eastlake, OH 44095**

**Emissions Unit ID (Company ID)/Emissions Unit Activity Description**

B001 (BOILER #1 ) COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 1325 MMBTU/HR	B005 (BOILER #5) COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 6040 MMBTU/HR	COAL STORAGE PILE
B002 (BOILER #2) COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 1325 MMBTU/HR	B006 (GAS TURBINE) OIL-FIRED COMBUSTION GAS TURBINE FOR ELECTRIC GENERATION - 468.9 MMBTU/HR	P901 (COAL HANDLING) COAL UNLOADING AND CONVEYING SYSTEM
B003 (BOILER #3) COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 1325 MMBTU/HR	F001 (ROADS & PARKING) PAVED/UNPAVED ROADS AND PARKING AREAS	P902 (FLY ASH HANDLING) FLY ASH HANDLING AND REMOVAL SYSTEM
B004 (BOILER #4) COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 2253 MMBTU/HR	F002 (COAL PILE)	

You will be contacted approximately eighteen (18) months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency listed below. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC rule 3745-77-08(E) and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the current Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

Northeast District Office  
2110 East Aurora Road  
Twinsburg, OH 44087  
(330) 425-9171

OHIO ENVIRONMENTAL PROTECTION AGENCY

Christopher Jones  
Director

## PART I - GENERAL TERMS AND CONDITIONS

### A. *State and Federally Enforceable Section*

#### 1. **Monitoring and Related Record Keeping and Reporting Requirements**

a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:

- i. The date, place (as defined in the permit), and time of sampling or measurements.
- ii. The date(s) analyses were performed.
- iii. The company or entity that performed the analyses.
- iv. The analytical techniques or methods used.
- v. The results of such analyses.
- vi. The operating conditions existing at the time of sampling or measurement.

*(Authority for term: OAC rule 3745-77-07(A)(3)(b)(i))*

b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

*(Authority for term: OAC rule 3745-77-07(A)(3)(b)(ii))*

c. The permittee shall submit required reports in the following manner:

i. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.  
*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*

ii. **All reporting required in accordance with the OAC rule 3745-77-07(A)(3)(c) with respect to emission limitations, operational restrictions, and control device operating parameter limitations shall be submitted in the following manner:**

- (a) Written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations ; (ii) the probable cause of such deviations; and (iii) any corrective actions or preventive measures taken, shall be promptly made to the appropriate Ohio EPA District Office or local air agency. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, i.e., in Part III of this Title V permit, the written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year, and shall cover the previous calendar quarters. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. These written reports shall satisfy the requirements (in part) of OAC rule 3745-77-

07(A)(3)(c)(i) and (ii) pertaining to the submission of monitoring reports every six months and the requirements (in part) of OAC rule 3745-77-07(A)(3)(c)(iii) pertaining to the prompt reporting of all deviations. See B.6 below if no deviations occurred during the quarter.

*(Authority for term: OAC rules 3745-77-07(A)(3)(c)(i), (ii) and (iii))*

- (b) Any malfunction, as defined in OAC rule 3745-15-06(B)(1), shall be promptly reported to the Ohio EPA in accordance with OAC rule 3745-15-06. In addition, to fulfill the deviation reporting requirements for this Title V permit, written reports that identify each malfunction that occurred during each calendar quarter shall be submitted, at a minimum, quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year, and shall cover the previous calendar quarters.

In identifying each deviation caused by a malfunction, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. For a specific malfunction, if this information has been provided in a written report that was submitted in accordance with OAC rule 3745-15-06, the permittee may simply reference that written report to identify the deviation. Also, if a deviation caused by a malfunction is identified in a written report submitted pursuant to paragraph (a) above, a separate report is not required for that malfunction pursuant to this paragraph. Nevertheless, all malfunctions, including those reported only verbally in accordance with OAC rule 3745-15-06, must be reported in writing, at a minimum, on a quarterly basis.

Any scheduled maintenance, as defined in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation, operational restriction, and control device operating parameter limitation shall be reported in the same manner as described above for malfunctions. These written reports for malfunctions (and scheduled maintenance projects, if appropriate) shall satisfy the requirements (in part) of OAC rule 3745-77-07(A)(3)(c)(iii) pertaining to the prompt reporting of all deviations.

*(Authority for term: OAC rules 3745-77-07(A)(3)(c)(iii))*

iii. **For monitoring, record keeping, and reporting requirements:**

Written reports that identify any deviations from the federally enforceable monitoring, record keeping, and reporting requirements contained in this permit shall be submitted to the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year, for the previous six calendar months. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. These semi-annual written reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c)(i) and (ii) pertaining to the reporting of any deviations related to the monitoring, record keeping, and reporting requirements. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report which states that no deviations occurred during that period.

*(Authority for term: OAC rules 3745-77-07(A)(3)(c)(i) and (ii))*

- iv. Each written report shall be signed by a responsible official certifying that, "based on information and belief formed after reasonable inquiry, the statements and information in the report (including any written malfunction reports required by OAC rule 3745-15-06 that are referenced in the deviation reports) are true, accurate, and complete."  
*(Authority for term: OAC rule 3745-77-07(A)(3)(c)(iv))*

## 2. **Scheduled Maintenance/Malfunction Reporting**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit(s) or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in OAC rule 3745-15-06, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).  
*(Authority for term: OAC rule 3745-77-07(A)(3)(c)(iii))*

## 3. **Risk Management Plans**

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.  
*(Authority for term: OAC rule 3745-77-07(A)(4))*

## 4. **Title IV Provisions**

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.  
*(Authority for term: OAC rule 3745-77-07(A)(5))*

## 5. **Severability Clause**

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.  
*(Authority for term: OAC rule 3745-77-07(A)(6))*

## 6. **General Requirements**

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.

- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause, in accordance with A.10 below. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

*(Authority for term: OAC rule 3745-77-07(A)(7))*

#### **7. Fees**

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.

*(Authority for term: OAC rule 3745-77-07(A)(8))*

#### **8. Marketable Permit Programs**

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.

*(Authority for term: OAC rule 3745-77-07(A)(9))*

#### **9. Reasonably Anticipated Operating Scenarios**

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these general terms and conditions shall apply to all operating scenarios authorized in this permit.

*(Authority for term: OAC rule 3745-77-07(A)(10))*

#### **10. Reopening for Cause**

This Title V permit will be reopened prior to its expiration date under the following conditions:

- a. Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the

permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.

- b. This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.
- c. The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.
- d. The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.  
*(Authority for term: OAC rules 3745-77-07(A)(12) and 3745-77-08(D))*

#### **11. Federal and State Enforceability**

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

*(Authority for term: OAC rule 3745-77-07(B))*

#### **12. Compliance Requirements**

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
  - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
  - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.
  - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.

- iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
  - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
  - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.
- d. Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) and the Administrator of the U.S. EPA in the following manner and with the following content:
  - i. Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted on or before April 30th of each year during the permit term.
  - ii. Compliance certifications shall include the following:
    - (a) An identification of each term or condition of this permit that is the basis of the certification.
    - (b) The permittee's current compliance status.
    - (c) Whether compliance was continuous or intermittent.
    - (d) The method(s) used for determining the compliance status of the source currently and over the required reporting period.
    - (e) Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.
  - iii. Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.

*(Authority for term: OAC rules 3745-77-07(C)(1),(2),(4) and (5) and ORC section 3704.03(L))*

### **13. Permit Shield**

- a. Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.
- b. This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.

*(Authority for term: OAC rule 3745-77-07(F))*

**14. Operational Flexibility**

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the appropriate Ohio EPA District Office or local air agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the Administrator of the U.S. EPA and the appropriate District Office of the Ohio EPA or local air agency as soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).

*(Authority for term: OAC rules 3745-77-07(H)(1) and (2))*

**15. Emergencies**

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.

*(Authority for term: OAC rule 3745-77-07(G))*

**16. Off-Permit Changes**

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

- a. The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition.
- b. The permittee provides contemporaneous written notice of the change to the Director and the Administrator of the U.S. EPA, except that no such notice shall be required for changes that qualify as insignificant emission levels or activities as defined in OAC rule 3745-77-01(U). Such written notice shall describe each such change, the date of such change, any change in emissions or pollutants emitted, and any federally applicable requirement that would apply as a result of the change.
- c. The change shall not qualify for the permit shield under OAC rule 3745-77-07(F).
- d. The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes.
- e. The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit to install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.

(For purposes of clarification, the permittee can refer to Engineering Guide #63 that is available in the STARSHIP software package.)

*(Authority for term: OAC rule 3745-77-07(I))*

**17. Compliance Method Requirements**

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Fed. Reg. 8314, Feb. 24, 1997), in the context of any future proceeding.

*(This term is provided for informational purposes only.)*

**18. Insignificant Activities**

Each insignificant activity that has one or more applicable requirements shall comply with those applicable requirements.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**19. Permit to Install Requirement**

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**20. Air Pollution Nuisance**

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**B. State Only Enforceable Section**

**1. Reporting Requirements Related to Monitoring and Record Keeping Requirements**

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (i) any deviations (excursions) from emission limitations, operational restrictions, and

control device operating parameter limitations that have been detected by the testing, monitoring, and record keeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

**2. Records Retention Requirements**

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

**3. Inspections and Information Requests**

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

**4. Scheduled Maintenance/Malfunction Reporting**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

**5. Permit Transfers**

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

**6. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)**

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

## Part II - Specific Facility Terms and Conditions

### A. State and Federally Enforcable Section

1. This facility is subject to the applicable requirements specified in OAC Chapter 3745-25. In accordance with Ohio EPA Engineering Guide #64, the emission control action programs, as specified in OAC rule 3745-25-03, shall be developed and submitted within 60 days after receiving notification from the Ohio EPA.
2. All asbestos renovation and demolition activities conducted at this facility shall be performed in accordance with the applicable requirements specified in 40 CFR Part 61 and OAC Chapter 3745-20.
3. Nitrogen Oxides (NOx) Budget Trading Program

OAC Chapter 3745-14

**3.a** Office of Regulatory Information System Facility Code - 2837

**3.b** The following regulated electrical generating units are subject to the applicable requirements specified in OAC Chapter 3745-14 and the annual NOx allowance allocations listed below:

Emissions Unit	Annual Allowance for Calendar Years 2004 and 2005	Annual Allowance for Calendar Years 2006 and 2007
B001 - Boiler #1	214	209
B002 - Boiler #2	230	225
B003 - Boiler #3	251	246
B004 - Boiler #4	371	363
B005 - Boiler #5	974	953
B006 - GT	1	1

- 3.c** The emissions units identified in Section A.3.b above are NOx budget units under OAC rule 3745-14-01(C)(1). [OAC rule 3745-14-01(C)(1)(a)(i)]
- 3.d** The NOx authorized account representative shall submit a complete NOx budget permit application in accordance with the deadlines specified in paragraphs (B)(2) and (B)(3) of OAC rule 3745-14-03. The NOx authorized account representative shall also submit, in a timely manner, any supplemental information that the Director determines is necessary in order to review a NOx budget permit application and issue or deny a NOx budget permit.  
[OAC rules 3745-14-01(E)(1)(a)(i), 3745-14-01(E)(1)(a)(ii), and 3745-14-03(B)(1)]
- 3.e** Beginning May 31, 2004, the owners and operators of each NOx budget source and each NOx budget unit at the source shall hold NOx allowances available for compliance deductions under paragraph (E) of OAC rule 3745-14-06, as of the NOx allowance transfer deadline, in the unit's compliance account and the source's overdraft account in an amount not less than the total NOx emissions for the control period from the unit, as determined in accordance with OAC rule 3745-14-08, plus any amount necessary to account for actual utilization under paragraph (C)(5) of OAC rule 3745-14-05 for the control period.  
[OAC rules 3745-14-01(E)(3)(a) and 3745-14-01(E)(3)(c)]
- 3.f** NOx allowances shall be held in, deducted from, or transferred among NOx allowance tracking system accounts in accordance with OAC rules 3745-14-05, 3745-14-06, 3745-14-07, and 3745-14-09.  
[OAC rule 3745-14-01(E)(3)(d)]
- 3.g** A NOx allowance shall not be deducted, in order to comply with the requirement under paragraph (E)(3)(a) of OAC rule 3745-14-01, for a control period in a year prior to the year for which the NOx allowance was allocated.  
[OAC rule 3745-14-01(E)(3)(e)]

**A. State and Federally Enforcable Section (continued)**

**3.h** Each ton of NO<sub>x</sub> emitted in excess of the NO<sub>x</sub> budget emission limitation, as defined in OAC rule 3745-14-01(B)(2)(yy), shall constitute a separate violation of OAC Chapter 3745-14, the Clean Air Act, and applicable Ohio law. The owners and operators of a NO<sub>x</sub> budget unit that has excess emissions in any control period shall surrender the NO<sub>x</sub> allowances required for deduction under paragraph (E)(4)(a) of OAC rule 3745-14-06 and pay any fine, penalty, or assessment or comply with any other remedy imposed under paragraph (E)(4)(c) of OAC rule 3745-14-06.

[OAC rules 3745-14-01(E)(3)(b), 3745-14-01(E)(4)(a) and 3745-14-01(E)(4)(b)]

**3.i** When recorded by the Administrator pursuant to OAC rules 3745-14-06 and 3745-14-07, every allocation, transfer, or deduction of a NO<sub>x</sub> allowance to or from a NO<sub>x</sub> budget unit's compliance account or the overdraft account of the source where the unit is located is deemed to amend automatically, and become a part of, any NO<sub>x</sub> budget permit of the NO<sub>x</sub> budget unit by operation of law without any further review.

[OAC rule 3745-14-01(E)(3)(h)]

**3.j** Except as provided below, the Director shall revise the NO<sub>x</sub> budget permit, as necessary, in accordance with OAC rule 3745-77-08.

Each NO<sub>x</sub> budget permit is deemed to incorporate automatically the definitions of terms under paragraph (B) of OAC rule 3745-14-01 and, when recorded by the Administrator, in accordance with OAC rules 3745-14-06 and 3745-14-07, every allocation, transfer, or deduction of a NO<sub>x</sub> allowance to or from the compliance accounts of the NO<sub>x</sub> budget units covered by the permit or the overdraft account of the NO<sub>x</sub> budget source covered by the permit.

[OAC rules 3745-14-03(D)(2) and 3745-14-03(E)(1)]

**3.k** The owner or operator of a NO<sub>x</sub> budget unit shall comply with the prohibitions under OAC rule 3745-14-08(A)(5).

[OAC rule 3745-14-08(A)(5)]

**3.l** The owners and operators of the NO<sub>x</sub> budget unit shall keep on site at the source each of the following documents for a period of five years from the date the document is created: (This period may be extended for cause, at any time prior to the end of five years, in writing by the Director or Administrator.)

i. the account certificate of representation for the NO<sub>x</sub> authorized account representative for the NO<sub>x</sub> budget unit and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with paragraph (D) of OAC rule 3745-14-02, provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the submission of a new account certificate or representation changing the NO<sub>x</sub> authorized account representative;

ii. all emission monitoring information, in accordance with OAC rule 3745-14-08;

iii. copies of all reports, compliance certifications, and other submissions and all records made or required under the NO<sub>x</sub> budget trading program; and

iv. copies of all documents used to complete a NO<sub>x</sub> budget permit application and any other submission under the NO<sub>x</sub> budget trading program or to demonstrate compliance with the requirements of the NO<sub>x</sub> budget trading program.

[OAC rule 3745-14-01(E)(5)(a)(i) through (iv)]

**A. State and Federally Enforcable Section (continued)**

- 3.m** The permittee shall operate and maintain equipment to continuously monitor and record nitrogen oxides emissions from these emissions units in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software. This includes all systems required to monitor the NO<sub>x</sub> emission rate, NO<sub>x</sub> concentration, heat input rate, and stack flow rate, in accordance with 40 CFR Parts 75.71 and 75.72.

The permittee shall comply with the initial and re-certification procedures of 40 CFR Part 75. The permittee shall maintain on-site documentation from the USEPA or the Ohio EPA that the continuous nitrogen oxides monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous nitrogen oxides monitoring system: emissions of nitrogen oxides in lb/mmBtu actual heat input on an hourly average basis, emissions of nitrogen oxides in lbs/hr, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

Whenever the monitoring system fails to meet the quality assurance or data validation requirements of 40 CFR Part 75, data shall be substituted using the applicable procedures in Subpart D, Appendix D, or Appendix E of 40 CFR Part 75.

[OAC rules 3745-14-01(E)(2)(a), 3745-14-01(E)(5)(a)(ii), 3745-14-08(A)(2)(a) through (A)(2)(d), 3745-14-08(B)(1), and 3745-14-08(C)(1)]

- 3.n** The permittee shall comply with the monitoring plan requirements of 40 CFR Part 75.62, except that the monitoring plan shall also include all of the information required by Subpart H of 40 CFR Part 75.  
[OAC rule 3745-14-08(E)(2)(a)]
- 3.o** The NO<sub>x</sub> authorized account representative of the NO<sub>x</sub> budget unit shall submit the reports and compliance certifications required under the NO<sub>x</sub> budget trading program, including those under OAC rules 3745-14-04 and 3745-14-08, to the Director and Administrator.  
[OAC rule 3745-14-01(E)(5)(b)]
- 3.p** Each submission under the NO<sub>x</sub> budget trading program shall be submitted, signed, and certified by the NO<sub>x</sub> authorized account representative for each NO<sub>x</sub> budget source on behalf of which the submission is made. Each such submission shall include the following certification statement by the NO<sub>x</sub> authorized account representative:

"I am authorized to make this submission on behalf of the owners and operators of the NO<sub>x</sub> budget sources or NO<sub>x</sub> budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

If the NO<sub>x</sub> authorized account representative for a NO<sub>x</sub> budget unit subject to an acid rain emission limitation who signed and certified any submission that is made under Subpart F or G of 40 CFR Part 75 and which includes data and information required under OAC rule 3745-14-08 or Subpart H of 40 CFR Part 75 is not the same person as the designated representative or the alternate designated representative for the unit under 40 CFR Part 72, then the submission shall also be signed by the designated representative or the alternate designated representative.

[OAC rules 3745-14-02(A)(5) and 3745-14-08(E)(1)(b)]

**A. State and Federally Enforcable Section (continued)**

- 3.q** The NOx authorized account representative shall submit quarterly reports that include all of the data and information required in Subpart H of 40 CFR Part 75 for each NOx budget unit (or group of units using a common stack) and the data and information in Subpart G of 40 CFR Part 75. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30 and October 30 of each year and shall be submitted in the manner specified in Subpart H of 40 CFR Part 75 and 40 CFR Part 75.64.  
[OAC rules 3745-14-08(E)(4)(a) and 3745-14-08(E)(4)(c)(i)]
- 3.r** The NOx authorized account representative shall submit to the Administrator a compliance certification in support of each quarterly report based on a reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The compliance certification shall state that:
- i. the monitoring data submitted were recorded in accordance with the applicable requirements of OAC rule 3745-14-08 and 40 CFR Part 75, including the quality assurance procedures and specifications; and
  - ii. for a unit with add-on NOx emission controls and for all hours where data are substituted in accordance with 40 CFR Part 75.34(a)(1), the add-on emission control were operating within the range of parameters listed in the quality assurance program under Appendix B of 40 CFR Part 75 and the substitute values do not systematically underestimate the NOx emissions.  
[OAC rule 3745-14-08(E)(4)(d)(i) and (ii)]
- 3.s** The NOx authorized account representative for a NOx budget unit shall submit written notice of monitoring system certification and re-certification test dates to the Director and the Administrator in accordance with 40 CFR Part 75.61. The NOx authorized account representative shall submit a certification application to the Administrator, U.S. EPA, Region V Office, and the Director within forty-five days after completing all initial or re-certification tests required under paragraph (B) of OAC rule 3745-14-08, including the information required under Subpart H of 40 CFR Part 75.  
[OAC rules 3745-14-08(D) and 3745-14-08(E)(3)]
- 3.t** For each control period in which one or more NOx budget units at a source are subject to the NOx budget emission limitation, the NOx authorized account representative of the source shall submit to the Director and the Administrator, by November 30 of that year, a compliance certification report for each source covering all such units.

The NOx authorized account representative shall include the following elements in the compliance certification report, in a format prescribed by the Administrator, concerning each unit at the source and subject to the NOx budget emission limitation for the control period covered by the report:

- i. identification of each NOx budget unit;
- ii. at the NOx authorized account representative's option, the serial numbers of the NOx allowances that are to be deducted from each unit's compliance account under paragraph (E) of OAC rule 3745-14-06 for the control period;
- iii. at the NOx authorized account representative's option, for units sharing a common stack and having NOx emissions that are not monitored separately or apportioned in accordance with OAC rule 3745-14-08, the percentage of allowances that is to be deducted from each unit's compliance account under paragraph (E)(5) of OAC rule 3745-14-06; and
- iv. the compliance certification under paragraph (A)(3) of OAC rule 3745-14-04.  
[OAC rules 3745-14-04(A)(1) and 3745-14-04(A)(2)]

**A. State and Federally Enforcable Section (continued)**

**3.u** In the compliance certification report under Section A.3.t.iv above, the NOx authorized account representative shall certify, based upon reasonable inquiry of those persons with the primary responsibility for operating the source and the NOx budget units at the source in compliance with the NOx budget trading program, whether each NOx budget unit for which the compliance certification is submitted was operated during the calendar year covered by the report in compliance with the requirements of the NOx budget trading program applicable to the unit, including all the following:

- i. whether the unit was operated in compliance with the NOx budget emission limitation;
- ii. whether the monitoring plan that governs the unit has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute NOx emissions to the unit, in accordance with OAC rule 3745-14-08;
- iii. whether all the NOx emissions from the unit, or group of units (including the unit) using a common stack, were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with OAC rule 3745-14-08, and if conditional data were reported, the permittee shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report submissions have been made; and
- iv. whether the facts that form the basis for certification under OAC rule 3745-14-08 of each monitor at the unit or group of units (including the unit) using a common stack, or for using an excepted monitoring method or alternative monitoring method approved under OAC rule 3745-14-08, if any, have changed.

If a change is required to be reported under Section A.3.u.iv above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor re-certification.

[OAC rule 3745-14-04(A)(3)]

**3.v** The NOx authorized account representative shall submit a complete NOx budget permit renewal application for the NOx budget source covering the NOx budget units at the source in accordance with paragraph (E) of OAC rule 3745-77-08.

[OAC rule 3745-14-03(B)(3)(a)]

**3.w** The emission measurements recorded and reported in accordance with OAC rule 3745-14-08 shall be used to determine compliance by the unit with the NOx budget emission limitation under paragraph (E)(3) of OAC rule 3745-14-01.

[OAC rule 3745-14-01(E)(2)(b)]

**3.x** The permittee shall develop and maintain a written quality assurance/quality control plan for each continuous NOx monitoring system designed to ensure continuous valid and representative readings of NOx emissions in units of the applicable standard. The plan shall follow the requirements of 40 CFR Part 75, Appendix B. The quality assurance/quality control plan and a logbook dedicated to the continuous NOx monitoring system must be kept on-site and available for inspection during regular office hours.

[OAC rules 3745-14-08(A)(2)(c) and 3745-14-08(A)(2)(d)]

**4.** The permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain. The permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

**B. State Only Enforceable Section**

1. The following insignificant emissions units are located at this facility:

T001 - Tank #1 (200,000-gallon fuel oil storage tank);  
T002 - Tank #2 (2,000,000-gallon fuel oil storage tank);  
T003 - Tank #3 (1,800-gallon fuel oil storage tank);  
T004 - Tank #4 (6,000-gallon kerosene storage tank);  
Z005 - Tank #5 (30,000-gallon fuel oil storage tank);  
Z006 - Tank #6 (20,000-gallon fuel oil storage tank);  
Z007 - Tank #7 (10,000-gallon diesel storage tank);  
Z008 - Tank #8 (6,000-gallon kerosene storage tank);  
Z009 - Tank #9 (5,000-gallon waste oil tank);  
Z010 - Tank #10 (5,000-gallon transformer oil tank);  
Z011 - Tank #11 (5,000-gallon transformer oil tank);  
Z012 - Tank #12 (1,800-gallon fuel oil storage tank);  
Z013 - Tank #13 (1,500-gallon diesel storage tank);  
Z014 - Tank #14 (4,500-gallon sulfuric acid tank);  
Z015 - Diesel Engine #1;  
Z016 - Diesel Engine #2;  
Z017 - Diesel Engine #3;  
Z018 - Diesel Engine #4; and  
Z019 - Diesel Engine #5.

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations as well as any emission limitations and/or control requirements contained within a permit to install for the emissions unit. There are no permit to install emission limitations or control requirements for the insignificant emissions units listed above.

**Part III - Terms and Conditions for Emissions Units**

**Emissions Unit ID:** BOILER #1 (B001)

**Activity Description:** COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 1325 MMBTU/HR

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 1325 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
	OAC rule 3745-18-49(G)	Sulfur dioxide emissions shall not exceed 5.64 lbs/mmBtu actual heat input.

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

### III. Monitoring and/or Record Keeping Requirements

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous opacity monitoring system consists of all the equipment used to acquire data and includes the data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, and the results of the analyses for ash content, sulfur content, and heat content and the average daily and rolling, 30-day weighted average emission rates of sulfur dioxide in lb/mmBtu actual heat input. The analyses for ash content, sulfur content, and heat content shall be determined in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D5865, Gross Calorific Value of Coal and Coke, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Northeast District Office.

### III. Monitoring and/or Record Keeping Requirements (continued)

4. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

### IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

#### **IV. Reporting Requirements (continued)**

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.I. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

#### **V. Testing Requirements**

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Northeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

- 1.a A comprehensive written report on the results of the emission test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Northeast District Office.
2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of paragraphs A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 1325 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).		

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

- A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
- A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

**Part III - Terms and Conditions for Emissions Units**

**Emissions Unit ID:** BOILER #2 (B002)

**Activity Description:** COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 1325 MMBTU/HR

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 1325 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
	OAC rule 3745-18-49(G)	Sulfur dioxide emissions shall not exceed 5.64 lbs/mmBtu actual heat input.

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

### III. Monitoring and/or Record Keeping Requirements

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous opacity monitoring system consists of all the equipment used to acquire data and includes the data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, and the results of the analyses for ash content, sulfur content, and heat content and the average daily and rolling, 30-day weighted average emission rates of sulfur dioxide in lb/mmBtu actual heat input. The analyses for ash content, sulfur content, and heat content shall be determined in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D5865, Gross Calorific Value of Coal and Coke, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Northeast District Office.

### III. Monitoring and/or Record Keeping Requirements (continued)

4. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

### IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

#### **IV. Reporting Requirements (continued)**

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.I. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

#### **V. Testing Requirements**

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Northeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

- 1.a A comprehensive written report on the results of the emission test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Northeast District Office.
2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of paragraphs A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 1325 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).		

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

1. A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
2. A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

**Part III - Terms and Conditions for Emissions Units**

**Emissions Unit ID:** BOILER #3 (B003)

**Activity Description:** COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 1325 MMBTU/HR

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 1325 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
	OAC rule 3745-18-49(G)	Sulfur dioxide emissions shall not exceed 5.64 lbs/mmBtu actual heat input.

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

### III. Monitoring and/or Record Keeping Requirements

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous opacity monitoring system consists of all the equipment used to acquire data and includes the data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, and the results of the analyses for ash content, sulfur content, and heat content and the average daily and rolling, 30-day weighted average emission rates of sulfur dioxide in lb/mmBtu actual heat input. The analyses for ash content, sulfur content, and heat content shall be determined in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D5865, Gross Calorific Value of Coal and Coke, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Northeast District Office.

### III. Monitoring and/or Record Keeping Requirements (continued)

4. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

### IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

#### **IV. Reporting Requirements (continued)**

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.I. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

#### **V. Testing Requirements**

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Northeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

- 1.a A comprehensive written report on the results of the emission test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Northeast District Office.
2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of paragraphs A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 1325 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).		

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

1. A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
2. A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

**Part III - Terms and Conditions for Emissions Units**

**Emissions Unit ID:** BOILER #4 (B004)

**Activity Description:** COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 2253 MMBTU/HR

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 2253 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
	OAC rule 3745-18-49(G)	Sulfur dioxide emissions shall not exceed 5.64 lbs/mmBtu actual heat input.

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

### III. Monitoring and/or Record Keeping Requirements

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous opacity monitoring system consists of all the equipment used to acquire data and includes the data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, and the results of the analyses for ash content, sulfur content, and heat content and the average daily and rolling, 30-day weighted average emission rates of sulfur dioxide in lb/mmBtu actual heat input. The analyses for ash content, sulfur content, and heat content shall be determined in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D5865, Gross Calorific Value of Coal and Coke, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Northeast District Office.

### III. Monitoring and/or Record Keeping Requirements (continued)

4. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

### IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

#### **IV. Reporting Requirements (continued)**

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.I. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

#### **V. Testing Requirements**

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Northeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

- 1.a A comprehensive written report on the results of the emission test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Northeast District Office.
2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of paragraphs A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 2253 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

1. A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
2. A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

**Part III - Terms and Conditions for Emissions Units**

**Emissions Unit ID:** BOILER #5 (B005)

**Activity Description:** COAL-FIRED UTILITY BOILER FOR ELECTRIC GENERATION - 6040 MMBTU/HR

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 6040 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
	OAC rule 3745-18-49(G)	Sulfur dioxide emissions shall not exceed 5.64 lbs/mmBtu actual heat input.

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

### III. Monitoring and/or Record Keeping Requirements

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous opacity monitoring system consists of all the equipment used to acquire data and includes the data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, and the results of the analyses for ash content, sulfur content, and heat content and the average daily and rolling, 30-day weighted average emission rates of sulfur dioxide in lb/mmBtu actual heat input. The analyses for ash content, sulfur content, and heat content shall be determined in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D5865, Gross Calorific Value of Coal and Coke, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Northeast District Office.

### III. Monitoring and/or Record Keeping Requirements (continued)

4. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

### IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Northeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

#### **IV. Reporting Requirements (continued)**

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.I and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.I. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

#### **V. Testing Requirements**

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Northeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

- 1.a A comprehensive written report on the results of the emission test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Northeast District Office.
2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of paragraphs A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Pulverized coal-fired, dry bottom, utility boiler having a nominal heat input capacity of 6040 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).		

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

1. A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
2. A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

**Part III - Terms and Conditions for Emissions Units**

**Emissions Unit ID:** GAS TURBINE (B006)

**Activity Description:** OIL-FIRED COMBUSTION GAS TURBINE FOR ELECTRIC GENERATION - 468.9 MMBTU/HR

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Distillate oil-fired (i.e., numbers 1 and 2, kerosene and diesel fuels, but excluding number 4) combustion gas turbine for electric generation having a nominal heat input capacity of 469 mmBtu/hr.	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)	Particulate emissions shall not exceed .040 lb/mmBtu actual heat input.
	OAC rule 3745-18-06(F)	Sulfur dioxide emissions shall not exceed 0.5 lb/mmBtu actual heat input.

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

1. The quality of the oil burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation specified in Section A.I above.
2. The permittee shall burn only distillate oils (i.e., numbers 1 and 2, kerosene and diesel fuels, but excluding number 4) in this emissions unit.

### III. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

- a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). A shipment may be comprised of multiple tank truck loads from the same supplier's batch, and the quality of the oil for those loads may be represented by a single batch analysis from the supplier. The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).

- b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).

2. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D240 and D4294), or equivalent methods as approved by the Director.
3. For each day during which the permittee burns a fuel other than distillate oils (i.e., numbers 1 and 2, kerosene and diesel fuels, but excluding number 4), the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

### IV. Reporting Requirements

1. The permittee shall notify the Director (the Ohio EPA, Northeast District Office) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon the calculated sulfur dioxide emission rates from Section A.III above. The notification shall include a copy of such record and shall be sent to the Director (the Ohio EPA, Northeast District Office) within 45 days after the deviation occurs.
2. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than distillate oils was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

### V. Testing Requirements

1. Compliance with the emission limitations in Section A.I.1 of these terms and conditions shall be determined in accordance with the following methods:
  - 1.a Emission Limitation-  
Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method-

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

## **V. Testing Requirements (continued)**

- 1.b** Emission Limitation-  
Particulate emissions shall not exceed .040 lb/mmBtu actual heat input.

Applicable Compliance Method-

Compliance may be based upon an emission factor of 0.0043 lb/mmBtu. This emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (04/00).

If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(10).

- 1.c** Emission Limitation-  
Sulfur dioxide emissions shall not exceed 0.5 lb/mmBtu actual heat input.

Applicable Compliance Method-

Compliance with the allowable sulfur dioxide emission limitation may be demonstrated by documenting that the sulfur content of each shipment of oil received or each daily sample collected during a calendar month meets the limitation.

If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

## **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** ROADS & PARKING (F001)  
**Activity Description:** PAVED/UNPAVED ROADS AND PARKING AREAS

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
paved roadways and parking areas (see Section A.1.2.a)	OAC rule 3745-17-07(B)(7)(a)(ii) (see Section A.1.2.a)	no visible particulate emissions except for 6 minutes during any 60-minute period
	OAC rule 3745-17-08(B), (B)(2)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.1.2.f through A.1.2.j)
unpaved roadways and parking areas (see Section A.1.2.b)	OAC rule 3745-17-07(B)(7)(a)(ii) (see Section A.1.2.k)	no visible particulate emissions except for 13 minutes during any 60-minute period
	OAC rule 3745-17-08(B), (B)(8), (B)(9)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.1.2.c, A.1.2.d, A.1.2.e, A.1.2.g, A.1.2.i, and A.1.2.j)

## 2. Additional Terms and Conditions

- 2.a** The paved roadways and parking areas that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:

Paved Roadways:

Gate #1/Coal Pile Entrance, asphalt and chip and tar surfaces, from Erie Road to around the coal pile runoff retention basin and around the coal pile (parallel with the railroad tracks) to the back of the plant building. Also, two shorter branch roads near the Gate #1 entrance, that lead to the coal pile and the chemical waste treatment building.

Gate #2/Main Entrance, asphalt, from Erie Road to the paved main parking lot at the plant entrance, and branch roadways to and around the ash silos.

Gate #3/Contractors Entrance, asphalt, from Erie Road to the unpaved, gravel base surface.

From the Oily Waste Basin to the Ash Waste Basin unpaved access roadway, asphalt surface.

Paved Parking Areas:

Main Parking Lot at plant entrance, asphalt surface.

- 2.b** The unpaved roadways and parking areas that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:

Unpaved Roadways:

Gate #3/Contractors Entrance, gravel, from the paved asphalt surface to the Guard Shack. And from the Guard Shack to the Oily Waste Basin.

From the Oily Waste Basin to the Ash Waste Basin, gravel surface.

Around the 138 KV Yard, gravel, roadways encircling the 138 KV Yard and a branch road to the Gate #3 contractors haul roadway.

Unpaved Parking Areas:

Gate #3 car and trailer parking lot, dirt and gravel.

- 2.c** The permittee shall employ reasonably available control measures on all paved roadways and parking areas for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to treat the paved roadways and parking areas by flushing with water, sweeping, and/or watering at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.d** The permittee shall promptly remove, in such a manner as to minimize or prevent resuspension, earth and/or other material from paved streets onto which such material has been deposited by trucking or earth moving equipment or erosion by water or other means.
- 2.e** The permittee shall employ reasonably available control measures on the unpaved shoulders of all paved roadways for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to treat the unpaved shoulders of all paved roadways with water and/or any other suitable dust suppression chemicals at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.

## **2. Additional Terms and Conditions (continued)**

- 2.f** The permittee shall employ reasonably available control measures on all unpaved roadways and parking areas for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to treat the unpaved roadways and parking areas with water and/or any other suitable dust suppression chemicals at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.g** The needed frequencies of implementation of the control measures shall be determined by the permittee's inspections pursuant to the monitoring section of this permit. Implementation of the control measures shall not be necessary for a paved or unpaved roadway or parking area that is covered with snow and/or ice or if precipitation has occurred that is sufficient for that day to ensure compliance with the above-mentioned applicable requirements. Implementation of any control measure may be suspended if unsafe or hazardous driving conditions would be created by its use.
- 2.h** Any unpaved roadway or parking area, which during the term of this permit is paved or takes the characteristics of a paved surface due to the application of certain types of dust suppressants, may be controlled with the control measure(s) specified above for paved surfaces. Any unpaved roadway or parking area that takes the characteristics of a paved roadway or parking area due to the application of certain types of dust suppressants shall remain subject to the visible emission limitation for unpaved roadways and parking areas. Any unpaved roadway or parking area that is paved shall be subject to the visible emission limitation for paved roadways and parking areas.
- 2.i** Open-bodied vehicles transporting materials likely to become airborne shall have such materials covered at all times if the control measure is necessary for the materials being transported.
- 2.j** Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-17-08.
- 2.k** This rule citation reflects the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider this revised rule as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of these limitations as a revision to the Ohio SIP for particulate matter.

## **II. Operational Restrictions**

**None**

### III. Monitoring and/or Record Keeping Requirements

1. Except as otherwise provided in this section, the permittee shall perform inspections of the roadways and parking areas in accordance with the following frequencies:

Paved Roadways and Parking Areas:

All paved roadways and parking areas listed in Section A.I.2.a above.

Minimum Inspection Frequency:

daily

Unpaved Roadways and Parking Areas:

All unpaved roadways and parking areas listed in Section A.I.2.b above.

Minimum Inspection Frequency:

daily

2. The purpose of the inspections is to determine the need for implementing the above-mentioned control measures. The inspections shall be performed during representative, normal traffic conditions. No inspection shall be necessary for a roadway or parking area that is covered with snow and/or ice or if precipitation has occurred that is sufficient for that day to ensure compliance with the above-mentioned applicable requirements. Any required inspection that is not performed due to any of the above identified events shall be performed as soon as such event(s) has (have) ended, except if the next required inspection is within one week.
3. The permittee may, upon receipt of written approval from the Ohio EPA, Northeast District Office, modify the above-mentioned inspection frequencies if operating experience indicates that less frequent inspections would be sufficient to ensure compliance with the above-mentioned applicable requirements. Such modified inspection frequencies would be considered a minor or significant modification that would be subject to the Title V permit modification requirements in paragraphs (C)(1) and (C)(3) of OAC rule 3745-77-08.
4. The permittee shall maintain records of the following information:
  - a. the date and reason any required inspection was not performed, including those inspections that were not performed due to snow and/or ice cover or precipitation;
  - b. the date of each inspection where it was determined by the permittee that it was necessary to implement the control measures;
  - c. the dates the control measures were implemented; and
  - d. on a calendar quarter basis, the total number of days the control measures were implemented and the total number of days where snow and/or ice cover or precipitation were sufficient to not require the control measures.

The information required in 4.d. shall be kept separately for (i) the paved roadways and parking areas and (ii) the unpaved roadways and parking areas, and shall be updated on a calendar quarter basis within 30 days after the end of each calendar quarter.

#### **IV. Reporting Requirements**

1. The permittee shall submit quarterly deviation reports that identify any of the following occurrences:
  - a. each day during which an inspection was not performed by the required frequency, excluding an inspection which was not performed due to an exemption for snow and/or ice cover or precipitation; and
  - b. each instance when a control measure, that was to be implemented as a result of an inspection, was not implemented.
2. The quarterly deviation reports shall be submitted in accordance with General Term and Condition A.1.c.ii of this permit.

#### **V. Testing Requirements**

1. Compliance with the emission limitations for the paved and unpaved roadways and parking areas identified above shall be determined in accordance with Test Method 22 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources," as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(4)(a) through (B)(4)(d) of OAC rule 3745-17-03.\*

\*The procedures relating to Test Method 22 reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing the procedures was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the procedures as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the procedures as a revision to the Ohio SIP for particulate matter.

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
paved roadways and parking areas (see Section A.1.2.a)	none	none
unpaved roadways and parking areas (see Section A.1.2.b)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

1. If there are no deviations during a calendar quarter that must be reported pursuant to the reporting requirements of this permit, the permittee shall submit a quarterly report, in accordance with paragraph B.6 of the General Terms and Conditions of this permit, which states that no deviations occurred during that quarter.

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** COAL PILE (F002)  
**Activity Description:** COAL STORAGE PILE

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
load-in or load-out of the coal storage pile (see Section A.1.2.a for the identification of the coal storage pile)	OAC rule 3745-17-07(B)(7)(b)	visible particulate emissions shall not exceed 20% opacity, as a 3-minute average (see Section A.1.2.h)
	OAC rule 3745-17-08(B), (B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.1.2.b, A.1.2.c, and A.1.2.g)
operation of vehicles on top of the coal storage pile, excluding emissions from the combustion of fuels in such vehicles (i.e., pile working)	OAC rule 3745-17-07(B)(7)(c)	visible particulate emissions shall not exceed 20% opacity, as a 3-minute average (see Section A.1.2.h)
	OAC rule 3745-17-08(B), (B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.1.2.d, A.1.2.f, and A.1.2.g)
wind erosion from the coal storage pile	OAC rule 3745-17-07(B)(7)(d)	no visible emissions except for 13 minutes during any 60-minute period (see Section A.1.2.h)
	OAC rule 3745-17-08(B), (B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.1.2.e through A.1.2.g)

##### 2. Additional Terms and Conditions

- 2.a The coal storage pile that is covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 is listed below:

plant coal storage pile

## **2. Additional Terms and Conditions (continued)**

- 2.b** The permittee shall employ reasonably available control measures on all coal load-in and load-out operations associated with the coal storage piles for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to treat the coal load-in and load-out operations with water and/or any other suitable dust suppression chemicals at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.c** The above-mentioned control measures shall be employed for each coal load-in and load-out operation of each storage pile if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measures are necessary to ensure compliance with the above-mentioned applicable requirements. Any required implementation of the control measures shall continue during any such operation until further observation confirms that use of the measures is unnecessary.
- 2.d** The permittee shall employ reasonably available control measures on all pile working operations associated with the coal storage piles for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to treat the pile working operations with water and/or any other suitable dust suppression chemicals at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.e** The permittee shall employ reasonably available control measures for wind erosion from pile surfaces associated with the coal storage piles for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to treat the pile working operations with water and/or any other suitable dust suppression chemicals at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.f** The above-mentioned control measures shall be employed for each pile working operation and wind erosion from each pile if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measures are necessary to ensure compliance with the above-mentioned applicable requirements. Implementation of the control measures shall not be necessary for a coal storage pile that is covered with snow and/or ice or if precipitation has occurred that is sufficient for that day to ensure compliance with the above-mentioned applicable requirements.
- 2.g** Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-17-08.
- 2.h** The emission limitation and rule citation reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing the limitation and rule citation was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the emission limitation and rule citation as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the limitation and rule citation as a revision to the Ohio SIP for particulate matter.

## **II. Operational Restrictions**

**None**

### III. Monitoring and/or Record Keeping Requirements

1. Except as otherwise provided in this section, the permittee shall perform inspections of each coal load-in operation at each coal storage pile in accordance with the following frequencies:  
  
coal storage pile identification:  
  
plant coal storage pile  
  
minimum coal load-in inspection frequency:  
  
daily
2. Except as otherwise provided in this section, the permittee shall perform inspections of each coal load-out operation at each coal storage pile in accordance with the following frequencies:  
  
coal storage pile identification:  
  
plant coal storage pile  
  
minimum coal load-out inspection frequency:  
  
daily
3. Except as otherwise provided in this section, the permittee shall perform inspections of each pile working operation associated with each coal storage pile in accordance with the following frequencies:  
  
coal storage pile identification:  
  
plant coal storage pile  
  
minimum coal pile working inspection frequency:  
  
daily
4. Except as otherwise provided in this section, the permittee shall perform inspections of the wind erosion from pile surfaces associated with each coal storage pile in accordance with the following frequencies:  
  
coal storage pile identification:  
  
plant coal storage pile  
  
minimum wind erosion inspection frequency:  
  
daily
5. No inspection shall be necessary for wind erosion from the surface of a pile when the pile is covered with snow and/or ice and for any storage pile activity if precipitation has occurred that is sufficient for that day to ensure compliance with the above-mentioned applicable requirements. Any required inspection that is not performed due to any of the above identified events shall be performed as soon as such event(s) has (have) ended, except if the next required inspection is within one week.
6. The purpose of the inspections is to determine the need for implementing the control measures specified in this permit for coal load-in or load-out of a storage pile, pile working operations, and wind erosion from the surface of a coal storage pile. The inspections shall be performed during representative, normal storage pile operating conditions.

### III. Monitoring and/or Record Keeping Requirements (continued)

7. The permittee may, upon receipt of written approval from the Ohio EPA, Northeast District Office, modify the above-mentioned inspection frequencies if operating experience indicates that less frequent inspections would be sufficient to ensure compliance with the above-mentioned applicable requirements. Such modified inspection frequencies would be considered a minor or significant modification that would be subject to the Title V permit modification requirements in paragraphs (C)(1) and (C)(3) of OAC rule 3745-77-08.
8. The permittee shall maintain records of the following information:
  - a. the date and reason any required inspection was not performed, including those inspections that were not performed due to snow and/or ice cover or precipitation;
  - b. the date of each inspection where it was determined by the permittee that it was necessary to implement the control measures;
  - c. the dates the control measures were implemented; and
  - d. on a calendar quarter basis, the total number of days the control measures were implemented and the total number of days where snow and/or ice cover or precipitation were sufficient to not require the control measures.

The information required in 8.d. shall be kept separately for (i) the coal load-in operations, (ii) the coal load-out operations, (iii) the coal pile working operations, and (iv) the coal pile surfaces (wind erosion), and shall be updated on a calendar quarter basis within 30 days after the end of each calendar quarter.

### IV. Reporting Requirements

1. The permittee shall submit quarterly deviation reports that identify any of the following occurrences:
  - a. each day during which an inspection was not performed by the required frequency, excluding an inspection which was not performed due to an exemption for snow and/or ice cover or precipitation; and
  - b. each instance when a control measure, that was to be implemented as a result of an inspection, was not implemented.
2. The quarterly deviation reports shall be submitted in accordance with General Term and Condition A.1.c.ii of this permit.

### V. Testing Requirements

1. Compliance with the visible particulate emission limitations identified above shall be determined in accordance with the following methods:
  - 1.a Emission Limitation:  
visible particulate emissions shall not exceed 20% opacity, as a 3-minute average for coal load-in or load-out of the coal storage pile

Applicable Compliance Method:

Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a) and (B)(3)(b) of OAC rule 3745-17-03\*

## V. Testing Requirements (continued)

- 1.b** Emission Limitation:  
visible particulate emissions shall not exceed 20% opacity, as a 3-minute average for pile working operations on top of the coal storage pile

Applicable Compliance Method:

Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a), (B)(3)(b) and (B)(3)(e) of OAC rule 3745-17-03\*

- 1.c** Emission Limitation:  
no visible emissions except for 13 minutes during any 60-minute period for wind erosion from the coal storage pile surfaces

Applicable Compliance Method:

Test Method 22 as set forth in "Appendix on Test Methods" in 40 CFR Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(4)(a) through (B)(4)(c) of OAC rule 3745-17-03\*

\*The procedures related to Test Methods 9 and 22 reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing these procedures was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the procedures as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the procedures as a revision to the Ohio SIP for particulate matter.

## VI. Miscellaneous Requirements

1. A Notice of Violation was issued for the Cleveland Electric Illuminating Company's Eastlake Power Plant by the Ohio EPA, Northeast District Office on September 18, 2002. The Notice of Violation was issued to address an air pollution nuisance related to the coal pile operations at the facility. The permittee submitted a plan and schedule of corrective action on October 2, 2002 that included the following:
  - a. Formation of 4 distinct coal piles - 2 inactive coal piles (1 eastern coal and 1 western coal) and 2 active coal piles (1 eastern coal and 1 western coal.) The inactive coal piles have been sealed with a commercial sealant and will be resealed immediately after any pile working operation or disturbance. A windscreen has also been installed on the inactive eastern coal pile to minimize the effect of high winds out of the north/northeast. In addition, the surface area of the active coal piles has been reduced. These corrective actions were completed by November 15, 2002.
  - b. Installation and operation of additional dust suppression sprayers at the beginning and end of the "F" conveyor belt to treat the coal in the active western pile. The additional dust suppression sprayers at the beginning and end of the "F" conveyor belt will be installed and operational by December 31, 2002.
  - c. Evaluation of the effectiveness and durability of the test windscreen (fabric mesh type) installed along a portion of the plant's fence line adjacent to the Timberlake neighborhood. A decision about installing this type of windscreen along the entire fence line adjacent to the Timberlake neighborhood will be made by April 1, 2003.

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
load-in or load-out of the coal storage pile (see Section A.1.2.a for the identification of the coal storage pile)	none	none
operation of vehicles on top of the coal storage pile, excluding emissions from the combustion of fuels in such vehicles (i.e., pile working)	none	none
wind erosion from the coal storage pile	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

1. If there are no deviations during a calendar quarter that must be reported pursuant to the reporting requirements of this permit, the permittee shall submit a quarterly report, in accordance with paragraph B.8 of the General Terms and Conditions of this permit, which states that no deviations occurred during that quarter.

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

**Part III - Terms and Conditions for Emissions Units**

**Emissions Unit ID:** COAL HANDLING (P901)  
**Activity Description:** COAL UNLOADING AND CONVEYING SYSTEM

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
coal unloading from barges, railcars, or trucks (see Section A.I.2.a), coal conveyors (see Section A.I.2.b), coal handling (see Section A.I.2.c), and coal transfer points (see Section A.I.2.d)	OAC rule 3745-17-07(B)(7)(b)	visible particulate emissions shall not exceed 20% opacity, as a 3- minute average
	OAC rule 3745-17-08(B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.e through A.I.2.g)

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Radial conveyor stacker for coal storage pile load-in, with a 1,200 tons per hour capacity.	OAC rule 3745-31-05(A)(3) PTI No. 02-14406	Visible particulate emissions shall not exceed 20% opacity, as a 3-minute average.  The permittee shall employ the following best available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust:  the material transfer point from the existing conveyor arm 'F' to the conveyor arm of the radial stacker shall be 100% enclosed;  the conveyor arm of the radial stacker shall be 75% enclosed;  the radial stacker shall be equipped with a telescopic chute and 2 water spray cannons, each of which is rated 175 gallons per minute;  particulate emissions shall not exceed 4.0 tpy.

## 2. Additional Terms and Conditions

- 2.a** The coal unloading stations for barges, railcars, or trucks that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:

railcar rotary dumper house

- 2.b** The coal conveyors that are covered by this permit and subject to the requirements of OAC rules 3745-17-07, 3745-17-08, and/or 3745-31-05 are listed below:

'B' belt (reclaim conveyor)

'D' belt (dumper house to crusher house conveyor)

'E' belt (reclaim conveyor)

'F' belt (conveyor)

'FF' belt (radial stacker/conveyor)

'K' belt (coal bunker conveyor for emissions units B001-4)

'N' belt (crusher house to transfer tower conveyor)

'P' belt (transfer tower to southeast junction tower conveyor)

'Q' belt (southeast junction tower to coal bunker conveyor for emissions unit B005)

## 2. Additional Terms and Conditions (continued)

- 2.c** The coal handling operations that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:

dumper house

crusher house

- 2.d** The coal transfer points that are covered by this permit and subject to the requirements of OAC rules 3745-17-07, 3745-17-08, and/or 3745-31-05 are listed below:

dumper house (railcar dumper with 'D' belt)

crusher house ('B', 'D', 'F', 'K' and 'N' belts)

transfer tower ('N' belt to 'P' belt)

southeast junction tower ('P' belt to 'Q' belt)

'FF' belt at radial stacker/conveyor

new radial stacker/conveyor at stacker drop point

'K' belt with indoor 'L' belt

'Q' belt with indoor 'U' belt

- 2.e** The permittee shall employ reasonably or best available control measures, as appropriate, on all coal unloading stations for barges, railcars and/or trucks, coal conveyors, coal handling operations, and coal transfer points for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to use adequate enclosures to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.f** For each coal unloading station, coal conveyor, coal handling operation, and coal transfer point that is not adequately enclosed, such unloading station, conveyor, handling operation or transfer point shall be treated with water and/or suitable dust suppression chemicals if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measures are necessary to ensure compliance with the above-mentioned applicable requirements. Any required implementation of the control measures shall continue during operation of any coal unloading station, coal conveyor, coal handling, or coal transfer point until further observation confirms that use of the control measures is unnecessary.
- 2.g** Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rules 3745-17-08 and 3745-31-05.

## II. Operational Restrictions

**None**

### III. Monitoring and/or Record Keeping Requirements

1. Except as otherwise provided in this section, for coal unloading stations that are not adequately enclosed, the permittee shall perform inspections of such coal unloading stations in accordance with the following frequencies:

coal unloading station identification:

railcar rotary dumper house

minimum inspection frequency:

daily

2. Except as otherwise provided in this section, for coal conveyors that are not adequately enclosed, the permittee shall perform inspections of such coal conveyors in accordance with the following frequencies:

coal conveyor identification:

'B' belt

'D' belt

'E' belt

'F' belt

'K' belt

'N' belt

'P' belt

'Q' belt

minimum inspection frequency:

daily for all listed conveyors

3. Except as otherwise provided in this section, for coal handling operations that are not adequately enclosed, the permittee shall perform inspections of such coal handling operations in accordance with the following frequencies

coal handling operation identification:

dumper house

crusher house

minimum inspection frequency:

daily for all listed coal handling operations

### III. Monitoring and/or Record Keeping Requirements (continued)

4. Except as otherwise provided in this section, for coal transfer points that are not adequately enclosed, the permittee shall perform inspections of such coal transfer points in accordance with the following frequencies:

coal transfer point identification:

dumper house (railcar dumper with 'D' belt)

crusher house ('B', 'D', 'F', 'K' and 'N' belts)

transfer tower ('N' belt to 'P' belt)

southeast junction tower ('P' belt to 'Q' belt)

'F' belt at stacker point

'K' belt with indoor 'L' belt

'Q' belt with indoor 'U' belt

minimum inspection frequency:

daily for all listed transfer points

5. The above-mentioned inspections shall be performed during representative, normal operating conditions.
6. The permittee may, upon receipt of written approval from the Ohio EPA, Northeast District Office, modify the above-mentioned inspection frequencies if operating experience indicates that less frequent inspections would be sufficient to ensure compliance with the above-mentioned applicable requirements. Such modified inspection frequencies would be considered a minor or significant modification that would be subject to the Title V permit modification requirements in paragraphs (C)(1) and (C)(3) of OAC rule 3745-77-08.
7. The permittee shall maintain records of the following information:
- the date and reason any required inspection was not performed;
  - the date of each inspection where it was determined by the permittee that it was necessary to implement the control measures;
  - the dates the control measures were implemented; and
  - on a calendar quarter basis, the total number of days the control measures were implemented.

The information in 7.d. shall be kept separately for (i) the coal unloading stations, (ii) the coal conveyors, (iii) the coal handling operations, and (iv) the coal transfer points, and shall be updated on a calendar quarter basis within 30 days after the end of each calendar quarter.

### IV. Reporting Requirements

1. The permittee shall submit quarterly deviation reports that identify any of the following occurrences:
- each day during which an inspection was not performed by the required frequency; and
  - each instance when a control measure, that was to be performed as a result of an inspection, was not implemented.

#### **IV. Reporting Requirements (continued)**

2. The quarterly deviation reports shall be submitted in accordance with General Term and Condition A.1.c.ii of this permit.

#### **V. Testing Requirements**

1. Compliance with the emission limitations for coal unloading, conveyors, handling operations, and transfer points identified above shall be determined in accordance with Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a) and (B)(3)(b) of OAC rule 3745-17-03.\*

\*The procedures related to Test Method 9 reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing these procedures was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the procedures as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the procedures as a revision to the Ohio SIP for particulate matter.

2. Emission Limitation:  
Particulate emissions shall not exceed 4.0 tpy.

**Applicable Compliance Method:**

Compliance with the annual particulate emission limitation shall be based upon an emission factor of 0.00076 lb/ton of coal handled, multiplied by 1,200 tons/hour, which is the maximum number of tons of coal per hour that can be handled by this emissions unit, by 8,760 hours/year, and then by the conversion factor of 1.0 ton/2,000 lbs to determine the maximum potential emissions, in tons per year. The emission factor is derived from USEPA reference document AP-42, 5th Ed., "Compilation of Emission Factors", Section 13.2.4, Equation No. 1 (1/95).

#### **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
coal unloading from barges, railcars, or trucks (see Section A.1.2.a), coal conveyors (see Section A.1.2.b), coal handling (see Section A.1.2.c), and coal transfer points (see Section A.1.2.d)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

- If there are no deviations during a calendar quarter that must be reported pursuant to the reporting requirements of this permit, the permittee shall submit a quarterly report, in accordance with paragraph B.8 of the General Terms and Conditions of this permit, which states that no deviations occurred during that quarter.

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

### Part III - Terms and Conditions for Emissions Units

**Emissions Unit ID:** FLY ASH HANDLING (P902)  
**Activity Description:** FLY ASH HANDLING AND REMOVAL SYSTEM

#### A. State and Federally Enforceable Section

##### I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
fly ash and/or bottom ash pneumatic conveying and handling to silos, and fly ash and/or bottom ash silo load-out into trucks and/or railcars	OAC rule 3745-17-07(B)(7)(b)	visible particulate emissions shall not exceed 20% opacity, as a 3-minute average
	OAC rule 3745-17-08(B)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.a through A.I.2.d)
4 fly ash and/or bottom ash silo vents (each with baghouse)	OAC rule 3745-17-07(A)	visible particulate emissions shall not exceed 20% opacity, as a 6-minute average, except as provided by rule
	OAC rule 3745-17-11(B)(1)	particulate emissions shall not exceed 6.16 lbs/hr

##### 2. Additional Terms and Conditions

- 2.a The permittee shall employ reasonable available control measures on all fly ash and/or bottom ash pneumatic conveying equipment for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to maintaining total enclosure of such equipment to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.b The permittee shall employ reasonable available control measures for operations employing the dumping of fly ash and/or bottom ash from storage silos to trucks for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to apply sufficient water to the fly ash and/or bottom ash during any load-out from storage silos to trucks to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.

## **2. Additional Terms and Conditions (continued)**

- 2.c** The permittee shall employ reasonably available control measures for operations employing pneumatic loading of fly ash and/or bottom ash from storage silos to trucks or railcars for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to use coaxial spouts or other mechanisms that tightly fit to the tank hatch of the truck or railcar to prevent leaks and vent the displaced air from the tank to the baghouse serving the vent of the storage silo to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.d** Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-17-08.

## **II. Operational Restrictions**

**None**

## **III. Monitoring and/or Record Keeping Requirements**

- 1.** The permittee shall perform daily checks, while the equipment is in operation, for any visible emissions of fugitive dust escaping from any fly ash and/or bottom ash pneumatic conveying systems, for any unusual visible emissions from baghouses serving fly ash and/or bottom ash storage silos, and of the effectiveness of the water addition to the fly ash and/or bottom ash during load-out from storage silos into dump trucks to ensure compliance with the above-mentioned applicable requirements during silo load-out. A record of the necessary and completed corrective actions resulting from the daily checks shall be maintained by the permittee.

## **IV. Reporting Requirements**

- 1.** The permittee shall submit reports in accordance with the reporting requirements of the General Terms and Conditions which identify each day that the observations required under the monitoring section of this permit were not performed and each day that any corrective measures required to be taken pursuant to the monitoring section of this permit were not performed.

## **V. Testing Requirements**

- 1.** Compliance with the visible particulate emission limitations in Section A.I shall be determined in accordance with the following methods:
- 1.a** Emission Limitation:  
visible particulate emissions shall not exceed 20% opacity, as a 3-minute average for fly ash and/or bottom ash pneumatic conveying to silos and fly ash and/or bottom ash silo load-out into trucks and/or railcars
- Applicable Compliance Method:  
Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a) and (B)(3)(b) of OAC rule 3745-17-03\*
- 1.b** Emission Limitation:  
visible particulate emissions shall not exceed 20% opacity, as a 6-minute average, except as provided by rule
- Applicable Compliance Method:  
Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the procedures specified in OAC rule 3745-17-03(B)(1).

## **V. Testing Requirements (continued)**

- 1.c** Emission Limitation:  
particulate emissions shall not exceed 6.16 lbs/hr

**Applicable Compliance Method:**

If required by the Ohio EPA, Northeast District Office, compliance shall be demonstrated using Test Methods 1 through 5 as set forth in "Appendix on Test Methods" in 40 CFR Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996; otherwise, compliance shall be demonstrated by the absence of any visible emissions from the baghouse serving any silo vents and using Test Method 22 as set forth in "Appendix on Test Methods" in 40 CFR Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(4)(a) through (B)(4)(c) of OAC rule 3745-17-03\*

\*The procedures related to Test Methods 9 and 22 reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing the procedures was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the procedures as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the procedures as a revision to the Ohio SIP for particulate matter.

## **VI. Miscellaneous Requirements**

**None**

**B. State Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
fly ash and/or bottom ash pneumatic conveying and handling to silos, and fly ash and/or bottom ash silo load-out into trucks and/or railcars	none	none
3 fly ash and/or bottom ash silo vents (each with baghouse)	none	none

**2. Additional Terms and Conditions**

None

**II. Operational Restrictions**

None

**III. Monitoring and/or Record Keeping Requirements**

None

**IV. Reporting Requirements**

- If there are no deviations during a calendar quarter that must be reported pursuant to the reporting requirements of this permit, the permittee shall submit a quarterly report, in accordance with paragraph B.8 of the General Terms and Conditions of this permit, which states that no deviations occurred during that quarter.

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

\*\*\*\*\*  
**THIS IS THE LAST PAGE OF THE PERMIT**  
\*\*\*\*\*