



State of Ohio Environmental Protection Agency

P.O. Box 1049, 1800 WaterMark Dr.
Columbus, Ohio 43266-0149
(614) 644-3020
FAX (614) 644-2329

RECEIVED - SWD AIR
POLLUTION CONTROL

MAR 9 1993

George V. Voinovich
Governor
Donald R. Schregardus
Director

Re: Permit to Install
Hamilton County
Application No: 14-2834
SYNTHETIC MINOR

CERTIFIED MAIL

March 3, 1993

GENERAL ELECTRIC AIRCRAFT ENGINES
STEVE MARKS
1 NEUMAN WAY MAIL DROP N123
EVENDALE, OH 45215-6301

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions I urge you to read it carefully.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Board of Review pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review
236 East Town Street, Room 300
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo, Manager
Field Operations & Permit Section
Division of Air Pollution Control

cc: US EPA
CINCINNATI AIR POLLUTION , DAPC



Permit to Install Terms and Conditions

Application No. 14-2834
APS Premise No. 1431150060
Permit Fee: \$150.00

Name of Facility: GENERAL ELECTRIC AIRCRAFT ENGINES

Person to Contact: STEVE MARKS

Address: 1 NEUMAN WAY MAIL DROP N123
EVENDALE, OH 45215-6301

Location of proposed source(s): 1 NEUMAN WAY, BLDG 700 SE
EVENDALE, OHIO

Description of proposed source(s):
3-1,600 KILOWATT DIESEL ENGINE GENERATORS (SMALL BORE).


Date of Issuance: March 3, 1993

Effective Date: March 3, 1993

The above named entity is hereby granted a permit to install for the above described source(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Director

TERMINATION OF PERMIT TO INSTALL

Substantial construction for installation must take place within 18 months of the effective date of this permit. This deadline may be extended by up to 12 months, if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

NOTICE OF INSPECTION

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above-named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, or to examine records or reports pertaining to the construction, modification or installation of the source(s) of environmental pollutants identified within this permit.

CONSTRUCTION OF NEW SOURCE(S)

The proposed source(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

If the construction of the proposed source(s) has already begun or has been completed prior to the date the Director of the Ohio Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of Ohio Administrative Code (OAC) Rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities prove to be inadequate or cannot meet applicable standards.

GENERAL ELECTRIC AIRCRAFT ENGINES

Application No. 14-2834

Page 3 of 6

March 3, 1993

PERMIT TO INSTALL FEE

In accordance with Ohio Revised Code 3745.11, the specified Permit to Install fee must be remitted within 15 days of the effective date of this permit to install.

PUBLIC DISCLOSURE

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC Rule 3745-49-03.

APPLICABILITY

This Permit to Install is applicable only to the contaminant sources identified. Separate application must be made to the Director for the installation or modification of any other contaminant sources.

BEST AVAILABLE TECHNOLOGY

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

PERMIT TO OPERATE APPLICATION

A Permit to Operate application and a \$15 application fee must be submitted to the appropriate field office for each air contaminant source in this Permit to Install. In accordance with OAC Rule 3745-35-02, the application shall be made at least 90 days prior to start-up of the source.

AIR EMISSION SUMMARY

The air contaminant sources listed below comprise the Permit to Install for GENERAL ELECTRIC AIRCRAFT ENGINES located in Hamilton County. The sources listed below shall not exceed the emission limits/control requirements contained in the table. This condition in no way limits the applicability of any other state or federal regulations. Additionally, this condition does not limit the applicability of additional special terms and conditions of this permit.

GENERAL ELECTRIC AIRCRAFT ENGINES

Application No. 14-2834

Page 4 of 6

March 3, 1993

<u>Ohio EPA Source Number</u>	<u>Source Identification/Description</u>	<u>BAT Determination</u>	<u>Applicable Federal and OAC Rules</u>	<u>Permit Allowable Mass Emissions and/or Control & Usage Requirements</u>
P231	1600 KW Steam Generator (Small Bore) EA-271(A)	Use of #2 Fuel Oil and Limited Operating Hours	3745-31-05 3745-15-07 3745-17-07 3745-17-11 (B)(5)(a)	.25 lb/MMBTU PM 8.0 lbs/hr SO ₂ 49.1 lbs/hr NO _x 9.6 lbs/hr CO 1.6 lbs/hr OC
P234	1600 KW Steam Generator (Small Bore) EA-271(B)	Use of #2 Fuel Oil and Limited Operating Hours	3745-31-05 3745-15-07 3745-17-07 3745-17-11 (B)(5)(a)	.25 lb/MMBTU PM 8.0 lbs/hr SO ₂ 49.1 lbs/hr NO _x 9.6 lbs/hr CO 1.6 lbs/hr OC
P235	1600 KW Steam Generator (Small Bore) EA-271(C)	Use of #2 Fuel Oil and Limited Operating Hours	3745-31-05 3745-15-07 3745-17-07 3745-17-11 (B)(5)(a)	.25 lb/MMBTU PM 8.0 lbs/hr SO ₂ 49.1 lbs/hr NO _x 9.6 lbs/hr CO 1.6 lbs/hr OC

SUMMARY

TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

<u>Pollutant</u>	<u>Tons/Year</u>
OC	1.26
CO	7.59
NO _x	38.9
SO ₂	6.33
PM _{2.5} /PM ₁₀	0.78

RECORD(S) RETENTION AND AVAILABILITY

All records required by this Permit to Install shall be retained on file for a period of not less than two years unless otherwise indicated by Ohio Environmental Protection Agency. All records shall be made available to the Director, or any authorized representative of the Director, for review during normal business hours.

GENERAL ELECTRIC AIRCRAFT ENGINES

Application No. 14-2834

Page 5 of 6

March 3, 1993

REPORTING REQUIREMENTS

Unless otherwise specified, reports required by the Permit to Install need only be submitted to SW Ohio Air Pollution Control Agency 1632 Central Parkway, Cincinnati, Ohio 45210.

WASTE DISPOSAL

The owner/operator shall comply with any applicable state and federal requirements governing the storage, treatment, transport and disposal of any waste material generated by the operation of the sources.

MAINTENANCE OF EQUIPMENT

This source and its associated air pollution control system(s) shall be maintained regularly in accordance with good engineering practices and the recommendations of the respective manufacturers in order to minimize air contaminant emissions.

AIR POLLUTION NUISANCES PROHIBITED

The air contaminant source(s) identified in this permit may not cause a public nuisance in violation of OAC Rule 3745-15-07.

CONSTRUCTION COMPLIANCE CERTIFICATION

The applicant shall provide Ohio EPA with written certification (see enclosed form) that the facility has constructed in accordance with the permit to install application and the terms and conditions of the permit to install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

GENERAL ELECTRIC AIRCRAFT ENGINES

Application No. 14-2834

Page 6 of 6

March 3, 1993

ADDITIONAL SPECIAL TERMS AND CONDITIONS

1. General Electric shall not exceed a total of 1584 operating hours for Sources P231, P234 and P235 over a 365-day rolling average.
2. Sources P231, P234 and P235 shall use no fuel other than #2 fuel oil.
3. In order to ensure Federal enforceability for the first 12-calendar months of operation, General Electric shall not exceed the following hours of operation for the specific time period for P231, P234 and P235 combined:

<u>Month</u>	<u>Total Hours of Operation</u>
1-6	792
1-7	924
1-8	1056
1-9	1188
1-10	1320
1-11	1452
1-12	1584

After the first 12-calendar months General Electric shall comply with the 1584 hours per year limit based on a 365 day rolling average.

4. General Electric shall maintain daily records of operating hours for each generator, the cumulative sum for all three generators and the calculated rolling 365 day total hours of operation. These daily records shall be retained in the company's files for a period of not less than three years and shall be made available to the Director, or any authorized representative of the Director, for review during normal business hours.

This facility shall submit semiannual reports to the Hamilton County Department of Environmental Services which state the total operating hours for all three generators based on a 365 day rolling average. These reports shall be submitted by February 15 and August 15 of each year and cover the previous six calendar months.