

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

This version of facility specific terms and conditions was converted from a database format to an HTML file during an upgrade of the Ohio EPA, Division of Air Pollution Control's permitting software. Every attempt has been made to convert the terms and conditions to look and substantively conform to the permit issued or being drafted in STARS. However, the format of the terms may vary slightly from the original. In addition, although it is not expected, there is a slight possibility that a term and condition may have been inadvertently "left out" of this reproduction during the conversion process. Therefore, if this version is to be used as a starting point in drafting a new version of a permit, it is imperative that the entire set of terms and conditions be reviewed to ensure they substantively mimic the issued permit. The official version of any permit issued final by Ohio EPA is kept in the Agency's Legal section. The Legal section may be contacted at (614) 644-3037.

In addition to the terms and conditions, hyperlinks have been inserted into the document so you may more readily access the section of the document you wish to review.

Finally, the term language under "Part III" and before "I. Applicable Emissions Limitations..." has been added to aid in document conversion, and was not part of the original issued permit.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

Part II - Specific Facility Terms and Conditions

a State and Federally Enforceable Section

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

b State Only Enforceable Section

1. The following insignificant emissions units are located at this facility:

Z001 - G-743 Generator set
Z002 - K-60 Generator set
Z003 - K-33 Generator set
Z004 - K-33 Generator set
Z005 - K-33 Generator set
Z006 - K-33 Generator set
Z007 - 100ENBA Generator set.

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations, as well as any emissions limitations and/or control requirements contained within a Permit to Install for the emissions unit.

[Go to Part III for Emissions Unit B002](#)

[Go to Part III for Emissions Unit B003](#)

[Go to Part III for Emissions Unit B005](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0285030180 Emissions Unit ID: B002 Issuance type: Title V Proposed Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
30 mm Btu/hr gas-fired standby boiler	OAC 3745-17-10	0.020 pound of particulate emissions per million Btu input
	OAC 3745-17-07	20% opacity as a six-minute average, except as provided by rule

2. Additional Terms and Conditions

- (a) None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):
 - a. Emission Limitation
0.020 pound of particulate emissions per million Btu input

Applicable Compliance Method
Multiply the particulate emissions factor of 1.9* pounds of particulate emissions per million cubic feet of natural gas combusted by the inverse of the heat content of the natural gas, in Btu per cubic foot, as

supplied by the gas supplier. (*Emission factor from AP - 42, Table 1.4 -2.)

- b. Emission Limitation
20% opacity as a six-minute average, except as provided by rule
- Applicable Compliance Method
OAC rule 3745-17-03(B)(1), if requested.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

[Go to the top of this document](#)

Facility ID: 0285030180 Emissions Unit ID: B002 Issuance type: Title V Proposed Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. **Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
30 mm Btu/hr gas-fired standby boiler		
2. Additional Terms and Conditions		
1. None		

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. **Operational Restrictions**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. **Monitoring and/or Record Keeping Requirements**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. **Reporting Requirements**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. **Testing Requirements**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0285030180 Emissions Unit ID: B003 Issuance type: Title V Proposed Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
60 mm Btu/hr Riley stoker coal fired boiler with multiclone and sidestream baghouse	OAC 3745-17-07	20% opacity as a six-minute average, except as provided by rule
	OAC 3745-17-10	0.35 pound of particulate emissions per million Btu actual heat input
	OAC 3745-18-91 (H)	5.4 pounds of sulfur dioxide emissions per million Btu actual heat input

2. Additional Terms and Conditions

- (a) None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. The quality of the coal burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation of 5.4 pounds of sulfur dioxide per million Btu input.
2. The pressure drop across the baghouse shall be maintained within the range of 0.3-6.0 inches of water while the emissions unit is in operation.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect representative grab samples of the coal burned in this emissions unit on a daily basis. The coal sampling shall be performed in accordance with ASTM method D2234, Collection of a Gross Sample of Coal. At the end of each calendar month, all of the grab samples which were collected during that calendar month shall be combined into one composite sample.

Each monthly composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content, and heat content shall be: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isothermal Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval by the Ohio EPA Northeast District Office.

2. The permittee shall maintain monthly records of the total quantity of coal burned, and the results of the analyses for ash content, sulfur content, and heat content.
3. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the

visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain records of all data obtained by the continuous opacity monitoring system including, but not limited to percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

4. A statement of certification of the existing continuous opacity monitoring system shall be maintained on site and shall consist of a letter from the Ohio EPA detailing the results of an Agency review of the certification tests and a statement by the Agency that the system is considered certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. Proof of certification shall be made available to the Director (the Ohio EPA Northeast District Office) upon request.
5. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous opacity monitoring system designed to ensure continuous valid and representative readings of opacity. The plan shall include, as a minimum, conducting and recording daily automatic zero/span checks, provisions for conducting a quarterly audit of the continuous opacity monitoring system, and a description of preventive maintenance activities. The plan shall describe step by step procedures for ensuring that sections 7.1.4, 7.4.1, 7.4.2, and Table 1-1 of Performance Specification 1 are maintained on a continuous basis. The quality assurance/quality control plan and a logbook dedicated to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
6. The permittee shall properly maintain equipment to monitor the pressure drop across the baghouse while the emissions unit is in operation. The monitoring equipment shall be calibrated, operated, and maintained in accordance with the manufacturer's recommendations, instructions, and operating manual(s). The permittee shall record the pressure drop across the baghouse on daily basis.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA Northeast District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. Quarterly reports shall be submitted concerning the quality and quantity of the coal burned in this emissions unit. These reports shall include the following information for the emissions unit for each calendar month during the calendar quarter:
 - a. the total quantity of coal burned (tons);
 - b. the average ash content (percent) of the coal burned;
 - c. the average sulfur content (percent) of the coal burned;
 - d. the average heat content (Btu/pound) of the coal burned; and
 - e. the average sulfur dioxide emissions rate (pounds sulfur dioxide/mmBtu actual heat input) from the coal burned.

These quarterly reports shall be submitted by February 15, May 15, August 15, and November 15 of each year and shall cover the data obtained during the previous calendar quarters.
3. The permittee shall submit pressure drop deviation (excursion) reports that identify all periods of time during which the pressure drop across the baghouse did not comply with the allowable range specified above.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. Compliance with the emission limitation(s) in section A.I. of these terms and conditions shall be determined in accordance with the following method(s):
 - a. Emission Limitation
20% opacity as a six-minute average, except as provided by rule

Applicable Compliance Method
OAC rule 3745-17-03(B)(1), if requested.
 - b. Emission Limitation
5.4 pounds of sulfur dioxide emissions per million Btu actual heat input

Applicable Compliance Method
Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.1. and the applicable equation in OAC rule 3745-18-04(F). An alternative means of calculating sulfur dioxide emissions may be employed if such means is demonstrated to be more accurate in this specific instance than the above method to the satisfaction of the Director (the Ohio EPA Northeast District Office) and the Director (the Ohio EPA Northeast District Office) provides written approval of same.
 - c. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable particulate mass emission rate of 0.35 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA Northeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- c. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA Northeast District Office.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

[Go to the top of this document](#)

Facility ID: 0285030180 Emissions Unit ID: B003 Issuance type: Title V Proposed Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. **Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or

control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
60 mm Btu/hr Riley stoker coal fired boiler with multiclone and sidestream baghouse		
2. Additional Terms and Conditions		
1. None		

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0285030180 Emissions Unit ID: B005 Issuance type: Title V Proposed Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
38.5 mm Btu/hr gas-fired standby boiler	OAC 3745-17-10	0.020 pound of particulate emissions per million Btu input
	OAC 3745-17-07	20% opacity as a six-minute average, except as provided by rule

2. **Additional Terms and Conditions** 40 CFR 60 Subpart Dc See A.III.1.
- (a) None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. Pursuant to 40 CFR, Subpart Dc, the permittee shall record and maintain records of the amounts of each fuel combusted during each day.
2. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):
- a. Emission Limitation
0.020 pound of particulate emissions per million Btu input
- Applicable Compliance Method
Multiply the particulate emissions factor of 1.9* pounds of particulate emissions per million cubic feet of natural gas combusted by the inverse of the heat content of the natural gas, in Btu per cubic foot, as supplied by the gas supplier. (*Emission factor from AP - 42, Table 1.4 -2.)
- b. Emission Limitation
20% opacity as a six-minute average, except as provided by rule
- Applicable Compliance Method
OAC rule 3745-17-03(B)(1), if requested.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0285030180 Issuance type: Title V Proposed Permit

[Go to the top of this document](#)

Facility ID: 0285030180 Emissions Unit ID: B005 Issuance type: Title V Proposed Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. **Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
38.5 mm Btu/hr gas-fired standby boiler	OAC 3745-31-05 PTI No. 02-4976	3.37 tons particulate emissions per year; 0.20 pound NOx per mm Btu and 33.73 tons NOx per year.

2. **Additional Terms and Conditions**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. **Operational Restrictions**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. **Monitoring and/or Record Keeping Requirements**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. **Reporting Requirements**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. **Testing Requirements**

1. Compliance with the emission limitations in Section B.I. of these terms and conditions shall be determined in accordance with the following methods:

Emission Limitation:
0.20 pound NOx per mm BTU

Applicable Compliance Method:
Multiply the emission factor of 100* pounds of NOx emissions per million cubic feet of natural gas combusted by the reciprocal of the number of BTUs in a cubic foot of natural gas, as provided by the natural gas supplier. (*Emission factor from AP-42, Table 1.4-1.)

Emission Limitation:
33.73 tons NOx per year

Applicable Compliance Method:
Multiply the emission factor of 100* pounds of NOx emissions per million cubic feet of natural gas combusted by the number of cubic feet combusted per year, which is in pounds NOx per year. Divide this number by 2000 to get tons NOx per year. (*Emission factor from AP-42, Table 1.4-1.)

Emission Limitation:
2.34 tons particulate emissions per year

Applicable Compliance Method:
Multiply the emission factor of 1.9* pounds of PM emissions per million cubic feet of natural gas combusted by the number of cubic feet combusted per year, which is in pounds PM per year. Divide this number by 2000 to get tons PM per year. (*Emission factor from AP-42, Table 1.4-2.)

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

1. None