



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL
FRANKLIN COUNTY**

CERTIFIED MAIL

Street Address:

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov.
Center

Application No: 01-8060

DATE: October 14, 1999

Model Landfill LFG Power Station
Leslie M Cook
7700 San Felipe Suite 400
Houston, TX 77063

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Review Appeals Commission pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed within thirty (30) days after the notice of the Directors action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Commission. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
236 East Town Street, Room 300
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo
Field Operations and Permit Section
Division of Air Pollution Control

cc: USEPA
DAPC, CDO



STATE OF OHIO ENVIRONMENTAL PROTECTION AGENCY

**Permit To Install
Terms and
Conditions**

**Issue Date: October 14, 1999
Effective Date: October 14, 1999**

FINAL PERMIT TO INSTALL 01-8060

Application Number: 01-8060
APS Premise Number: 0125002421
Permit Fee: **\$1600**
Name of Facility: Model Landfill LFG Power Station
Person to Contact: Leslie M Cook
Address: 7700 San Felipe Suite 400
Houston, TX 77063

Location of proposed air contaminant source(s) [emissions unit(s)]:
**3299 Jackson Pike
Jackson Township, Ohio**

Description of proposed emissions unit(s):
4 IC ENGINES FOR COMBUSTION OF LANDFILL GAS TO PRODUCE ELECTRICITY.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Director

Part I - GENERAL TERMS AND CONDITIONS**A. State and Federally Enforceable Permit To Install General Terms and Conditions****1. Monitoring and Related Recordkeeping and Reporting Requirements**

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be

made to the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See B.11 below if no deviations occurred during the quarter.

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted to the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
- iv. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit To Install fees within 30 days after the issuance of this Permit To Install.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:

- i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
- ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit To Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this Permit To Install is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within thirty (30) days after commencing operation of the source(s) covered by this permit.

Model Landfill LFG Power Station

Facility ID: **0125002421**

PTI Application: **01-8060**

October 14, 1999

B. State Only Enforceable Permit To Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

4. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

Model Landfill LFG Power Station

Facility ID: **0125002421**

PTI Application: **01-8060**

October 14, 1999

5. Termination of Permit To Install

This permit to install shall terminate within eighteen months of the effective date of the permit to install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

6. Construction of New Sources(s)

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities prove to be inadequate or cannot meet applicable standards.

7. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999****8. Applicability**

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

9. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

10. Construction Compliance Certification

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the facility has been constructed in accordance with the Permit To Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

11. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

C. Permit To Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

<u>Pollutant</u>	<u>Tons Per Year</u>
NO _x	102.4
CO	106.8
OC	12
PE	6.4
SO ₂	3.6

Model Landfill LFG Power Station

Facility ID: **0125002421**

PTI Application: **01-8060**

October 14, 1999

Part II -Facility Specific Terms and Conditions

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

None

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

None

Emissions Unit ID: **P001**

Model Landfill LFG Power Station

Facility ID: **0125002421**

PTI Application: **01-8060**

October 14, 1999

Part III - Special Terms and Conditions for Specific Emissions Unit(s)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
14 mmBtu/hr IC Engine #1, for combustion of landfill gas to produce electricity	OAC rule 3745-17-11(B)	0.062 pound PE/mmBtu, actual heat input
	OAC rule 3745-17-07(A)	visible PE shall not exceed 20 percent opacity, as a six-minute average, except as otherwise provided by rule
	OAC rule 3745-18-06(G)	0.5 lb SO ₂ /mmBtu of actual heat input

2. **Additional Terms and Conditions**

- 2.a None

II. Operational Restrictions

1. The permittee shall install, calibrate, maintain and operate according to the manufacturer's specifications a device at the inlet to the combustion engine which completely shuts off gas flow to the engine when the engine is not operating.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving each emissions unit. The presence or absence of any visible emissions shall be noted in an operations log for each unit. If visible emissions are observed, the permittee shall also note the following in the operations log:

13

Model Landfill LFG Power Station

PTI Application: **01-8060**

October 14, 1999

Facility ID: **0125002421**

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

- a. the color of the emissions;
- b. whether the emissions are representative of normal operations;
- c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
- d. the total duration of any visible emission incident; and,
- e. any corrective actions taken to eliminate the visible emissions.

IV. Reporting Requirements

1. The permittee shall submit semiannual written reports which (a) identify all days during which any visible particulate emissions were observed from the stack serving the emissions unit and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Director (the appropriate Ohio EPA district office or local air agency) by January 31 and July 31 of each year and shall cover the previous 6-month period.

V. Testing Requirements

1. Emission testing requirements The permittee shall conduct, or have conducted, emission testing for one of the emissions units P001-P004 in accordance with the following requirements:
 - a. the emission testing shall be conducted within 6 months after installation of the combustion engines;
 - b. the emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for particulate emissions (PE).
 - c. the following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): PE - Method 5. The test method is located in 40 CFR Part 60, Appendix A; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA district office or local air agency.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to

Emissions Unit ID: **P001****Model Landfill LFG Power Station**Facility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results of the emission test(s).

Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s).

2. Compliance Methods Requirements Compliance with the emission limitation(s) established in this permit shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.062 pound PE/mmBtu, actual heat input.

Applicable Compliance Method: Compliance with the 0.062 pound PE/mmBtu, actual heat input, shall be determined in accordance with the performance test requirement, as detailed in section A.V.1 of the terms and conditions of this permit [and OAC rule 3745-17-03(B)(8)].

- b. Emission Limitation: visible PE shall not exceed 20 percent opacity, as a six-minute average, except as otherwise provided by rule

Applicable Compliance Method: OAC rule 3745-17-03(B)(1). The permittee shall monitor compliance with this visible PE limitation through the monitoring/record keeping and reporting requirements of this permit.

- c. Emission Limitation: 0.5 lb SO₂/mmBtu, actual heat input

Applicable Compliance Method: Compliance with the 0.5 pound PE/mmBtu, actual heat input, shall be demonstrated by multiplying the maximum inlet gas flow of 0.02612 MMscf/hr by an AP-42 emission factor of 7.786 lb/MMscf and then dividing by the actual heat input of 14 mmBtu.

VI. Miscellaneous Requirements

None

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
14 mmBtu/hr IC Engine #1, for combustion of landfill gas to produce electricity	OAC rule 3745-31-05 (A)(3)	0.42 pound NOx/mmBtu, actual heat input (5.84 pounds NOx/hour, 25.6 tons NOx/year) 0.44 pound CO/mmBtu, actual heat input (6.1 pounds CO/hour, 26.7 tons CO/year) 0.05 pound OC/mmBtu, actual heat input (0.68 pounds OC/hour, 3.0 tons OC/year) 0.026 pound PE/mmBtu, actual heat input (0.37 pound PE/hour), 1.6 tons/year 0.20 lb SO ₂ /hr, 0.89 ton SO ₂ /yr see B.I.2.a

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999****2. Additional Terms and Conditions**

- 2.a** The use of lean burn and gas pretreatment technologies have been determined to be BAT for this emissions unit.

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

1. Emission testing requirements The permittee shall conduct, or have conducted, emission testing for one of the emissions units P001-P004 in accordance with the following requirements:
- a. the emission testing shall be conducted within 6 months after installation of the combustion engines;
 - b. the emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for nitrogen oxides (NO_x), carbon monoxide (CO) and organic compounds (OC);
 - c. the following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): NO_x - Method 7, OC - Method 25 or 25A (as applicable), and CO - Method 10. All 3 test methods are located in 40 CFR Part 60, Appendix A; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA district office or local air agency.

Emissions Unit ID: **P001****Model Landfill LFG Power Station**Facility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results of the emission test(s).

Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s).

2. Compliance Methods Requirements Compliance with the emission limitation(s) established in this permit shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.42 pound NO_x/mmBtu, actual heat input (5.84 pounds NO_x/hour), 25.6 tons/year

Applicable Compliance Method: Compliance with the hourly NO_x emission limitation of 5.84 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual NO_x emission limitation of 25.6 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- b. Emission Limitation: 0.44 pound CO/mmBtu, actual heat input (6.1 pounds CO/hour), 26.7 tons/year

Applicable Compliance Method: Compliance with the hourly CO emission limitation of 6.1 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual CO emission limitation of 26.7 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- c. Emission Limitation: 0.05 pound OC/mmBtu, actual heat input (0.68 pounds OC/hour), 3.0 tons/year

Applicable Compliance Method: Compliance with the hourly OC emission limitation of 0.68 pounds shall be determined in accordance with the performance test requirement, as

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

detailed in section B.V.1 of the terms and conditions of this permit. The annual OC emission limitation of 3.0 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- d. Emission Limitation: 0.026 pound PE/mmBtu, actual heat input (0.37 pound PE/hour), 1.6 tons/year

Applicable Compliance Method: Compliance with the hourly PE limitation of 0.37 pound shall be determined in accordance with the performance test requirement, as detailed in section A.V.1 of the terms and conditions of this permit. The annual PE limitation of 1.6 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- e. Emission Limitation: 0.20 lb SO₂/hr, 0.89 ton SO₂/yr

Applicable Compliance Method: Compliance with the hourly limitation of 0.20 pound SO₂/hr shall be demonstrated by multiplying the maximum inlet gas flow of 0.02612 MMSCF/hr by an AP-42 emission factor of 7.786 lb/MMSCF. The annual SO₂ limitation of 0.89 ton is based on the hourly emission rate multiplied by 8760 hours/year.

Model Landfill LFG Power Station
PTI Application: **01-8060**
October 14, 1999

Emissions Unit ID: **P001**
Facility ID: **0125002421**

VI. Miscellaneous Requirements

None

Part III - Special Terms and Conditions for Specific Emissions Unit(s) [Continued]

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
14 mmBtu/hr IC Engine #2, for combustion of landfill gas to produce electricity	OAC rule 3745-17-11(B)	0.062 pound PE/mmBtu, actual heat input
	OAC rule 3745-17-07(A)	visible PE shall not exceed 20 percent opacity, as a six-minute average, except as otherwise provided by rule
	OAC rule 3745-18-06(G)	0.5 lb SO ₂ /mmBtu, actual heat input

2. **Additional Terms and Conditions**

- 2.a None

II. Operational Restrictions

1. The permittee shall install, calibrate, maintain and operate according to the manufacturer's specifications a device at the inlet to the combustion engine which completely shuts off gas flow to the engine when the engine is not operating.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving each emissions unit. The presence or absence of any visible emissions shall be noted in an operations log for each unit. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;

Emissions Unit ID: P002

- b. whether the emissions are representative of normal operations;
- c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
- d. the total duration of any visible emission incident; and,
- e. any corrective actions taken to eliminate the visible emissions.

IV. Reporting Requirements

1. The permittee shall submit semiannual written reports which (a) identify all days during which any visible particulate emissions were observed from the stack serving the emissions unit and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Director (the appropriate Ohio EPA district office or local air agency) by January 31 and July 31 of each year and shall cover the previous 6-month period.

V. Testing Requirements

1. Emission testing requirements The permittee shall conduct, or have conducted, emission testing for one of the emissions units P001-P004 in accordance with the following requirements:
 - a. the emission testing shall be conducted within 6 months after installation of the combustion engines;
 - b. the emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for particulate emissions (PE).
 - c. the following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): PE - Method 5. The test method is located in 40 CFR Part 60, Appendix A; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA district office or local air agency.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results of the emission test(s).

Model Landfill LFG Power Station

DTI Application: **01 0060**

Facility ID: **0125002421**

Emissions Unit ID: **P002**

October 14, 1999

Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s).

2. Compliance Methods Requirements Compliance with the emission limitation(s) established in this permit shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.062 pound PE/mmBtu, actual heat input.

Applicable Compliance Method: Compliance with the 0.062 pound PE/mmBtu, actual heat input, shall be determined in accordance with the performance test requirement, as detailed in section A.V.1 of the terms and conditions of this permit [and OAC rule 3745-17-03(B)(8)].

- b. Emission Limitation: visible PE shall not exceed 20 percent opacity, as a six-minute average, except as otherwise provided by rule

Applicable Compliance Method: OAC rule 3745-17-03(B)(1). The permittee shall monitor compliance with this visible PE limitation through the monitoring/record keeping and reporting requirements of this permit.

- c. Emission Limitation: 0.5 lb SO₂/mmBtu, actual heat input

Applicable Compliance Method: Compliance with the 0.5 pound PE/mmBtu, actual heat input, shall be demonstrated by multiplying the maximum inlet gas flow of 0.02612 MMSCF/hr by an AP-42 emission factor of 7.786 lb/MMSCF and then dividing by the actual heat input of 14 mmBtu.

VI. Miscellaneous Requirements

None

October 14, 1999

B. State Only Enforceable Section**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
14 mmBtu/hr IC Engine #2, for combustion of landfill gas to produce electricity	OAC rule 3745-31-05 (A)(3)	0.42 pound NO _x /mmBtu, actual heat input (5.84 pounds NO _x /hour, 25.6 tons NO _x /year) 0.44 pound CO/mmBtu, actual heat input (6.1 pounds CO/hour, 26.7 tons CO/year) 0.05 pound OC/mmBtu, actual heat input (0.68 pounds OC/hour, 3.0 tons OC/year) 0.026 pound PE/mmBtu, actual heat input (0.37 pound PE/hour), 1.6 tons/year 0.20 lb SO ₂ /hr, 0.89 ton SO ₂ /yr see B.I.2.a

October 14, 1999

2. Additional Terms and Conditions

- 2.a** The use of lean burn and gas pretreatment technologies have been determined to be BAT for this emissions unit.

II. Operational Restrictions

None

October 14, 1999

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

1. Emission testing requirements The permittee shall conduct, or have conducted, emission testing for one of the emissions units P001-P004 in accordance with the following requirements:
 - a. the emission testing shall be conducted within 6 months after installation of the combustion engines;
 - b. the emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for nitrogen oxides (NO_x), carbon monoxide (CO) and organic compounds (OC);
 - c. the following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): NO_x - Method 7, OC - Method 25 or 25A (as applicable), and CO - Method 10. All 3 test methods are located in 40 CFR Part 60, Appendix A; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA district office or local air agency.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results of the emission test(s).

Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to

Emissions Unit ID: P002

witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s).

2. Compliance Methods Requirements Compliance with the emission limitation(s) established in this permit shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.42 pound NO_x/mmBtu, actual heat input (5.84 pounds NO_x/hour), 25.6 tons/year

Applicable Compliance Method: Compliance with the hourly NO_x emission limitation of 5.84 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual NO_x emission limitation of 25.6 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- b. Emission Limitation: 0.44 pound CO/mmBtu, actual heat input (6.1 pounds CO/hour), 26.7 tons/year

Applicable Compliance Method: Compliance with the hourly CO emission limitation of 6.1 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual CO emission limitation of 26.7 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- c. Emission Limitation: 0.05 pound OC/mmBtu, actual heat input (0.68 pounds OC/hour), 3.0 tons/year

Applicable Compliance Method: Compliance with the hourly OC emission limitation of 0.68 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual OC emission limitation of 3.0 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- d. Emission Limitation: 0.026 pound PE/mmBtu, actual heat input (0.37 pound PE/hour), 1.6 tons/year

Applicable Compliance Method: Compliance with the hourly PE limitation of 0.37 pound shall be determined in accordance with the performance test requirement, as detailed in section A.V.1 of the terms and conditions of this permit. The annual PE limitation of 1.6 tons is based on the hourly emission rate multiplied by 8760 hours/year.

October 14, 1999

Emissions Unit ID: **P002**

October 14, 1999

e. Emission Limitation: 0.20 lb SO₂/hr, 0.89 ton SO₂/yr

Applicable Compliance Method: Compliance with the hourly limitation of 0.20 pound SO₂/hr shall be demonstrated by multiplying the maximum inlet gas flow of 0.02612 MMscf/hr by an AP-42 emission factor of 7.786 lb/MMSCF. The annual SO₂ limitation of 0.89 ton is based on the hourly emission rate multiplied by 8760 hours/year.

VI. Miscellaneous Requirements

None

Part III - Special Terms and Conditions for Specific Emissions Unit(s) [Continued]

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
14 mmBtu IC Engine #3, for combustion of landfill gas to produce electricity	OAC rule 3745-17-11(B)	0.062 pound PE/mmBtu, actual heat input
	OAC rule 3745-17-07(A)	visible PE shall not exceed 20 percent opacity, as a six-minute average, except as otherwise provided by rule
	OAC rule 3745-18-06(G)	0.5 lb SO ₂ /mmBtu, actual heat input

2. **Additional Terms and Conditions**

- 2.a None

II. Operational Restrictions

1. The permittee shall install, calibrate, maintain and operate according to the manufacturer's specifications a device at the inlet to the combustion engine which completely shuts off gas flow to the engine when the engine is not operating.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving each

Emissions Unit ID: **P003****Model Landfill LFG Power Station**Facility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

emissions unit. The presence or absence of any visible emissions shall be noted in an operations log for each unit. If visible emissions are observed, the permittee shall also note the following in the operations log:

- a. the color of the emissions;
- b. whether the emissions are representative of normal operations;
- c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
- d. the total duration of any visible emission incident; and,
- e. any corrective actions taken to eliminate the visible emissions.

IV. Reporting Requirements

1. The permittee shall submit semiannual written reports which (a) identify all days during which any visible particulate emissions were observed from the stack serving the emissions unit and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Director (the appropriate Ohio EPA district office or local air agency) by January 31 and July 31 of each year and shall cover the previous 6-month period.

V. Testing Requirements

1. Emission testing requirements The permittee shall conduct, or have conducted, emission testing for one of the emissions units P001-P004 in accordance with the following requirements:
 - a. the emission testing shall be conducted within 6 months after installation of the combustion engines;
 - b. the emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for particulate emissions (PE).
 - c. the following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): PE - Method 5. The test method is located in 40 CFR Part 60, Appendix A; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA district office or local air agency.

Model Landfill LFG Power Station

Facility ID: **0125002421**

PTI Application: **01-8060**

October 14, 1999

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results of the emission test(s).

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s).

2. Compliance Methods Requirements Compliance with the emission limitation(s) established in this permit shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.062 pound PE/mmBtu, actual heat input.

Applicable Compliance Method: Compliance with the 0.062 pound PE/mmBtu, actual heat input, shall be determined in accordance with the performance test requirement, as detailed in section A.V.1 of the terms and conditions of this permit [and OAC rule 3745-17-03(B)(8)].

- b. Emission Limitation: visible PE shall not exceed 20 percent opacity, as a six-minute average, except as otherwise provided by rule

Applicable Compliance Method: OAC rule 3745-17-03(B)(1). The permittee shall monitor compliance with this visible PE limitation through the monitoring/record keeping and reporting requirements of this permit.

- c. Emission Limitation: 0.5 lb SO₂/mmBtu, actual heat input

Applicable Compliance Method: Compliance with the 0.5 pound PE/mmBtu, actual heat input, shall be demonstrated by multiplying the maximum inlet gas flow of 0.02612 MMSCF/hr by an AP-42 emission factor of 7.786 lb/MMSCF and then dividing by the actual heat input of 14 mmBtu.

VI. Miscellaneous Requirements

None

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999****B. State Only Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
14 mmBtu/hr IC Engine #3, for combustion of landfill gas to produce electricity	OAC rule 3745-31-05 (A)(3)	0.42 pound NO _x /mmBtu, actual heat input (5.84 pounds NO _x /hour, 25.6 tons NO _x /year) 0.44 pound CO/mmBtu, actual heat input (6.1 pounds CO/hour, 26.7 tons CO/year) 0.05 pound OC/mmBtu, actual heat input (0.68 pounds OC/hour, 3.0 tons OC/year) 0.026 pound PE/mmBtu, actual heat input (0.37 pound PE/hour), 1.6 tons/year 0.20 lb SO ₂ /hr, 0.89 ton SO ₂ /yr see B.I.2.a

2. Additional Terms and Conditions

- 2.a** The use of lean burn and gas pretreatment technologies have been determined to be BAT

Model Landfill LFG Power Station

PTI Application: **01-8060**

October 14, 1999

Facility ID: **0125002421**

for this emissions unit.

II. Operational Restrictions

None

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999****III. Monitoring and/or Recordkeeping Requirements**

None

IV. Reporting Requirements

None

V. Testing Requirements

1. Emission testing requirements The permittee shall conduct, or have conducted, emission testing for one of the emissions units P001-P004 in accordance with the following requirements:
 - a. the emission testing shall be conducted within 6 months after installation of the combustion engines;
 - b. the emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for nitrogen oxides (NO_x), carbon monoxide (CO) and organic compounds (OC);
 - c. the following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): NO_x - Method 7, OC - Method 25 or 25A (as applicable), and CO - Method 10. All 3 test methods are located in 40 CFR Part 60, Appendix A; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA district office or local air agency.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results of the emission test(s).

Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s).

2. Compliance Methods Requirements Compliance with the emission limitation(s) established in this permit shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.42 pound NO_x/mmBtu, actual heat input (5.84 pounds NO_x/hour), 25.6 tons/year

Applicable Compliance Method: Compliance with the hourly NO_x emission limitation of 5.84 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual NO_x emission limitation of 25.6 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- b. Emission Limitation: 0.44 pound CO/mmBtu, actual heat input (6.1 pounds CO/hour), 26.7 tons/year

Applicable Compliance Method: Compliance with the hourly CO emission limitation of 6.1 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual CO emission limitation of 26.7 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- c. Emission Limitation: 0.05 pound OC/mmBtu, actual heat input (0.68 pounds OC/hour), 3.0 tons/year

Applicable Compliance Method: Compliance with the hourly OC emission limitation of 0.68 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual OC emission limitation of 3.0 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- d. Emission Limitation: 0.026 pound PE/mmBtu, actual heat input (0.37 pound PE/hour), 1.6 tons/year

Applicable Compliance Method: Compliance with the hourly PE limitation of 0.37 pound shall be determined in accordance with the performance test requirement, as detailed in section A.V.1 of the terms and conditions of this permit. The annual PE limitation of 1.6

Model Landfill LFG Power Station

PTI Application: **01-8060**

October 14, 1999

Facility ID: **0125002421**

tons is based on the hourly emission rate multiplied by 8760 hours/year.

Model Landfill LFG Power StationFacility ID: **0125002421**PTI Application: **01-8060****October 14, 1999**

- e. Emission Limitation: 0.20 lb SO₂/hr, 0.89 ton SO₂/yr

Applicable Compliance Method: Compliance with the hourly limitation of 0.20 pound SO₂/hr shall be demonstrated by multiplying the maximum inlet gas flow of 0.02612 MMscf/hr by an AP-42 emission factor of 7.786 lb/MMSCF. The annual SO₂ limitation of 0.89 ton is based on the hourly emission rate multiplied by 8760 hours/year.

VI. Miscellaneous Requirements

None

October 14, 1999

Part III - Special Terms and Conditions for Specific Emissions Unit(s) [Continued]**A. State and Federally Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
14 mmBtu IC Engine #4, for combustion of landfill gas to produce electricity	OAC rule 3745-17-11(B)	0.062 pound PE/mmBtu, actual heat input
	OAC rule 3745-17-07(A)	visible PE shall not exceed 20 percent opacity, as a six-minute average, except as otherwise provided by rule
	OAC rule 3745-18-06(G)	0.5 lb SO ₂ /mmBtu, actual heat input

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

1. The permittee shall install, calibrate, maintain and operate according to the manufacturer's specifications a device at the inlet to the combustion engine which completely shuts off gas flow to the engine when the engine is not operating.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall perform weekly checks, when the emissions unit is in operation and when the

Model Landfill LFG Power StationDTI Application: **01 0060**Facility ID: **0125002421**Emissions Unit ID: **P004**

weather conditions allow, for any visible particulate emissions from the stack serving each emissions unit. The presence or absence of any visible emissions shall be noted in an operations log for each unit. If visible emissions are observed, the permittee shall also note the following in the operations log:

October 14, 1999

- a. the color of the emissions;
- b. whether the emissions are representative of normal operations;
- c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
- d. the total duration of any visible emission incident; and,
- e. any corrective actions taken to eliminate the visible emissions.

IV. Reporting Requirements

1. The permittee shall submit semiannual written reports which (a) identify all days during which any visible particulate emissions were observed from the stack serving the emissions unit and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Director (the appropriate Ohio EPA district office or local air agency) by January 31 and July 31 of each year and shall cover the previous 6-month period.

V. Testing Requirements

1. Emission testing requirements The permittee shall conduct, or have conducted, emission testing for one of the emissions units P001-P004 in accordance with the following requirements:
 - a. the emission testing shall be conducted within 6 months after installation of the combustion engines;
 - b. the emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for particulate emissions (PE).
 - c. the following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): PE - Method 5. The test method is located in 40 CFR Part 60, Appendix A; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA district office or local air agency.

October 14, 1999

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the

October 14, 1999

emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results of the emission test(s).

Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s).

2. Compliance Methods Requirements Compliance with the emission limitation(s) established in this permit shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.062 pound PE/mmBtu, actual heat input.

Applicable Compliance Method: Compliance with the 0.062 pound PE/mmBtu, actual heat input, shall be determined in accordance with the performance test requirement, as detailed in section A.V.1 of the terms and conditions of this permit [and OAC rule 3745-17-03(B)(8)].

- b. Emission Limitation: visible PE shall not exceed 20 percent opacity, as a six-minute average, except as otherwise provided by rule

Applicable Compliance Method: OAC rule 3745-17-03(B)(1). The permittee shall monitor compliance with this visible PE limitation through the monitoring/record keeping and reporting requirements of this permit.

- c. Emission Limitation: 0.5 lb SO₂/mmBtu, actual heat input

Applicable Compliance Method: Compliance with the 0.5 pound PE/mmBtu, actual heat input, shall be demonstrated by multiplying the maximum inlet gas flow of 0.02612 MMSCF/hr by an AP-42 emission factor of 7.786 lb/MMSCF and then dividing by the actual heat input of 14 mmBtu.

VI. Miscellaneous Requirements

None

B. State Only Enforceable Section**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
14 mmBtu IC Engine #4, for combustion of landfill gas to produce electricity	OAC rule 3745-31-05 (A)(3)	0.42 pound NO _x /mmBtu, actual heat input (5.84 pounds NO _x /hour, 25.6 tons NO _x /year) 0.44 pound CO/mmBtu, actual heat input (6.1 pounds CO/hour, 26.7 tons CO/year) 0.05 pound OC/mmBtu, actual heat input (0.68 pounds OC/hour, 3.0 tons OC/year) 0.026 pound PE/mmBtu, actual heat input (0.37 pound PE/hour), 1.6 tons/year 0.20 lb SO ₂ /hr, 0.89 ton SO ₂ /yr see B.I.2.a

2. Additional Terms and Conditions

- 2.a The use of lean burn and gas pretreatment technologies have been determined to be BAT for this emissions unit.

October 14, 1999

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

1. Emission testing requirements The permittee shall conduct, or have conducted, emission testing for one of the emissions units P001-P004 in accordance with the following requirements:
 - a. the emission testing shall be conducted within 6 months after installation of the combustion engines;
 - b. the emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for nitrogen oxides (NO_x), carbon monoxide (CO) and organic compounds (OC);
 - c. the following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): NO_x - Method 7, OC - Method 25 or 25A (as applicable), and CO - Method 10. All 3 test methods are located in 40 CFR Part 60, Appendix A; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA district office or local air agency.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA district office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA district office's or local air agency's refusal to accept the results

October 14, 1999

of the emission test(s).

Personnel from the appropriate Ohio EPA district office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA district office or local air agency within 30 days following completion of the test(s).

2. Compliance Methods Requirements Compliance with the emission limitation(s) established in this permit shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.42 pound NO_x/mmBtu, actual heat input (5.84 pounds NO_x/hour), 25.6 tons/year

Applicable Compliance Method: Compliance with the hourly NO_x emission limitation of 5.84 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual NO_x emission limitation of 25.6 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- b. Emission Limitation: 0.44 pound CO/mmBtu, actual heat input (6.1 pounds CO/hour), 26.7 tons/year

Applicable Compliance Method: Compliance with the hourly CO emission limitation of 6.1 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual CO emission limitation of 26.7 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- c. Emission Limitation: 0.05 pound OC/mmBtu, actual heat input (0.68 pounds OC/hour), 3.0 tons/year

Applicable Compliance Method: Compliance with the hourly OC emission limitation of 0.68 pounds shall be determined in accordance with the performance test requirement, as detailed in section B.V.1 of the terms and conditions of this permit. The annual OC emission limitation of 3.0 tons is based on the hourly emission rate multiplied by 8760

Model Landfill LFG Power Station

DTI Application: 01 0060

Facility ID: 0125002421

Emissions Unit ID: P004

hours/year.

- d. Emission Limitation: 0.026 pound PE/mmBtu, actual heat input (0.37 pound PE/hour), 1.6 tons/year

Applicable Compliance Method: Compliance with the hourly PE limitation of 0.37 pound shall be determined in accordance with the performance test requirement, as detailed in section A.V.1 of the terms and conditions of this permit. The annual PE limitation of 1.6 tons is based on the hourly emission rate multiplied by 8760 hours/year.

- e. Emission Limitation: 0.20 lb SO₂/hr, 0.89 ton SO₂/yr

Applicable Compliance Method: Compliance with the hourly limitation of 0.20 pound SO₂/hr shall be demonstrated by multiplying the maximum inlet gas flow of 0.02612 MMscf/hr by an AP-42 emission factor of 7.786 lb/MMSCF. The annual SO₂ limitation of 0.89 ton is based on the hourly emission rate multiplied by 8760 hours/year.

VI. Miscellaneous Requirements

None