



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

RE: DRAFT PERMIT TO INSTALL MODIFICATION

CUYAHOGA COUNTY

Application No: 13-04321

Fac ID: 1318008401

CERTIFIED MAIL

	TOXIC REVIEW
	PSD
	SYNTHETIC MINOR
	CEMS
	MACT
	NSPS
	NESHAPS
	NETTING
	MAJOR NON-ATTAINMENT
	MODELING SUBMITTED
	GASOLINE DISPENSING FACILITY

DATE: 10/12/2006

Heidtman Steel Products, Incorporated
Glenn Meeks
360 Lavoy Road
Erie, MI 48133

You are hereby notified that the Ohio Environmental Protection Agency has made a draft action recommending that the Director issue a Permit to Install modification for the air contaminant source(s) [emissions unit(s)] shown on the enclosed draft permit modification. This draft action is not an authorization to begin construction or modification of your emissions unit(s). The purpose of this draft is to solicit public comments on the proposed installation. A public notice concerning the draft permit will appear in the Ohio EPA Weekly Review and the newspaper in the county where the facility will be located. Public comments will be accepted by the field office within 30 days of the date of publication in the newspaper. Any comments you have on the draft permit modification should be directed to the appropriate field office within the comment period. A copy of your comments should also be mailed to Robert Hodanbosi, Division of Air Pollution Control, Ohio EPA, P.O. Box 1049, Columbus, OH, 43266-0149.

A Permit to Install modification may be issued in proposed or final form based on the draft action, any written public comments received within 30 days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting. Upon issuance of a final Permit to Install modification a fee of **\$ 625** will be due. Please do not submit any payment now.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469. If you have any questions about this draft permit, please contact the field office where you submitted your application, or Mike Ahern, Field Operations & Permit Section at (614) 644-3631.

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section
Division of Air Pollution Control

CC: USEPA

CLAA

PA

PUBLIC NOTICE

ISSUANCE OF DRAFT PERMIT TO INSTALL **13-04321** FOR AN AIR CONTAMINANT SOURCE FOR
Heidtman Steel Products, Incorporated

On 10/12/2006 the Director of the Ohio Environmental Protection Agency issued a draft action of a Permit To Install an air contaminant source for **Heidtman Steel Products, Incorporated**, located at **4600 Heidtman Parkway, Cleveland, Ohio**.

Installation of the air contaminant source identified below may proceed upon final issuance of Permit To Install 13-04321:

Administrative modification of PTI No. 13-04321 to modify limits per a stack test.

Comments concerning this draft action, or a request for a public meeting, must be sent in writing to the address identified below no later than thirty (30) days from the date this notice is published. All inquiries concerning this draft action may be directed to the contact identified below.

David Hearne, Cleveland City Health Department, Division of the Environment, 1925 St. Clair Avenue, Cleveland, OH 44114 [(216)664-2324]



Permit To Install

Issue Date: To be entered upon final issuance

Terms and Conditions

Effective Date: To be entered upon final issuance

DRAFT MODIFICATION OF PERMIT TO INSTALL 13-04321

Application Number: 13-04321

Facility ID: 1318008401

Permit Fee: **To be entered upon final issuance**

Name of Facility: Heidtman Steel Products, Incorporated

Person to Contact: Glenn Meeks

Address: 360 Lavoy Road
Erie, MI 48133

Location of proposed air contaminant source(s) [emissions unit(s)]:
4600 Heidtman Parkway
Cleveland, Ohio

Description of proposed emissions unit(s):

Administrative modification of PTI No. 13-04321 to modify limits per a stack test.

The above named entity is hereby granted a modification to the permit to install described above pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this modification does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans included in the application, the above described source(s) of pollutants will be granted the necessary operating permits.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Director

Part I - GENERAL TERMS AND CONDITIONS

A. Permit to Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

4. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and

regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

6. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

7. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

8. Termination of Permit to Install

This Permit to Install shall terminate within eighteen months of the effective date of the Permit to Install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

9. Construction of New Sources(s)

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions

may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

10. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

11. Applicability

This Permit To Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate Permit To Install for the installation or modification of any other emissions unit(s) are required for any emissions unit for which a Permit To Install is required.

12. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

13. Source Operation and Operating Permit Requirements After Completion of Construction

This facility is permitted to operate each source described by this Permit to Install for a period of up to one year from the date the source commenced operation. This permission to operate is granted only if the facility complies with all requirements contained in this

permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the emissions unit(s) covered by this permit.

14. Construction Compliance Certification

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the facility has been constructed in accordance with the Permit to Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

15. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit to Install fees within 30 days after the issuance of this Permit to Install.

B. Permit to Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

**SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS**

<u>Pollutant</u>	<u>Tons Per Year</u>
HCl (PE)	0.92

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P001 - Steel pickling line using heated hydrochloric acid controlled by a wet scrubber	OAC rule 3745-31-05(A)(3)	HCl emissions shall not exceed 0.21 lb/hr and 0.92 TPY The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-07(A).
	OAC rule 3745-17-07(A)	Visible particulate emissions from any stack shall not exceed 20 percent opacity as a six minute average, except as specified by rule.
	OAC rule 3745-17-11(B)	The particulate emission limitation specified by this rule is less stringent than the particulate (HCl) emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

2. **Additional Terms and Conditions**

- 2.a None

B. Operational Restrictions

1. The scrubber water flow rate shall be continuously maintained at a value of not less than 1.5 gallons per minute at all times while the emissions unit is in operation.

C. Monitoring and/or Recordkeeping Requirements

1. The permittee shall properly install, operate and maintain equipment to monitor the water flow rate while the emissions unit is in operation. The monitoring devices shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, instructions, and operating manuals. The permittee shall record the scrubber flow rate (gallons per minute) once a shift on a daily basis.

D. Reporting Requirements

1. The permittee shall submit scrubber flow rate quarterly deviation (excursion) reports to the Cleveland Division of Air Quality (CDAQ) that identify each shift of each day during which the scrubber flow rate, in gallons per minute, was less than 1.5 gallons per minute. If there are no deviations during the quarter, the permittee is not required to submit a "no deviation" report.

E. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.1 of the terms and conditions shall be determined in accordance with the following method(s):

a. Emission Limitation

0.21 lb HCl/hr

Applicable Compliance Method

Allowable emissions are based on potential emissions. Compliance with this short-term limit may be determined using the following one-time calculation below.

$(0.0022 \text{ lb HCl/ton material processed}) * (96 \text{ tons material processed/hr}) = 0.21 \text{ lb HCl/hr}$

Compliance shall be determined by performing a stack test, using U.S. EPA test Method 26A of 40 CFR Part 60, Appendix A in accordance with Section E.2 below.

b. Emission Limitation

0.92 TPY HCl

Applicable Compliance Method

The annual emission limitation was established by multiplying the hourly emission rate by 8760 hours of operation per year and dividing by 2000 pounds per ton. Therefore, compliance with the annual emission limitation shall be assumed provided compliance is maintained with the pounds per hour limitation.

c. Emission Limitation

20% opacity, as a 6-minute average

Applicable Compliance Method

If required, compliance shall be determined by visible emission evaluations performed in accordance with OAC rule 3745-17-03(B)(1) using the methods and procedures specified in U.S. EPA Reference Method 9.

2. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:

The emission testing shall be conducted within 3 months after beginning operation of this emissions unit.

The emission testing shall be conducted to demonstrate compliance with the allowable rate of HCL emissions and the opacity limitation for visible particulate emissions.

The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): Method 26A of 40 CFR Part 60, Appendix A for HCL emissions and Method 9 for the opacity limitation. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Cleveland Division of Air Quality (Cleveland DAQ).

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Cleveland DAQ. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Cleveland DAQ's refusal to accept the results of the emission test(s).

Personnel from the Cleveland DAQ shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid

characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Cleveland DAQ within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Cleveland DAQ.

F. Miscellaneous Requirements

1. Modeling to demonstrate compliance with the Ohio EPA's "Air Toxic Policy" was not necessary because the emissions unit's maximum annual emissions for each toxic compound will be less than 1.0 ton. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any pollutant that has a listed TLV to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.