



State of Ohio Environmental Protection

Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**J001 (Loading Rack) a bulk petroleum terminal
gasolinetank truck loading rack**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

J001 (Loading Rack)
a bulk petroleum terminal gasoline tank truck loading rack

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: J001 (Loading Rack) a bulk petroleum terminal gasolinetank truck loading rack

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**P002 (Air Stripper)
a groundwater extraction air stripper, 500 gal/min**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,



Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: J001 (Loading Rack) a bulk petroleum terminal gasolinetank truck loading rack



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

P002 (Air Stripper)
a groundwater extraction air stripper, 500 gal/min

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Draft State Permit To Operate - General Terms and Conditions

Facility Name: **BP Exploration & Oil Inc - Dayton Terminal**
Facility ID: **08-57-04-0266**
Emissions Unit: **J001 (Loading Rack) a bulk petroleum terminal gasolinetank
truck loading rack**

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: P002 (Air Stripper)
a groundwater extraction air stripper, 500 gal/min

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

State of Ohio Environmental Protection Agency

Street Address:
Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:
Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**P003 (Soil Vapor Unit)
a soil vapor extraction unit**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,



Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: P002 (Air Stripper)
a groundwater extraction air stripper, 500 gal/min



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

P003 (Soil Vapor Unit)
a soil vapor extraction unit

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Draft State Permit To Operate - General Terms and Conditions

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: P002 (Air Stripper)
a groundwater extraction air stripper, 500 gal/min

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: P003 (Soil Vapor Unit)
a soil vapor extraction unit

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T002 (Storage Tank 7)
domed external floating roof gasoline above ground
storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,



Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: P003 (Soil Vapor Unit)
a soil vapor extraction unit



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T002 (Storage Tank 7)
domed external floating roof gasoline above ground storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Draft State Permit To Operate - General Terms and Conditions

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: P003 (Soil Vapor Unit)
a soil vapor extraction unit

To be signed upon final issuance

Christopher Jones
Director

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T002 (Storage Tank 7)
domed external floating roof gasoline above ground storage tank (AST)

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T002 (Storage Tank 7)
domed external floating roof gasoline above ground storage tank (AST)

cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T002 (Storage Tank 7)
domed external floating roof gasoline above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T003 (Storage Tank 8)
domed external floating roof gasoline above ground
storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

A handwritten signature in black ink that reads "Thomas G. Rigo". The signature is written in a cursive style.

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T002 (Storage Tank 7)
domed external floating roof gasoline above ground storage
tank (AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T003 (Storage Tank 8)
domed external floating roof gasoline above ground storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T002 (Storage Tank 7)
domed external floating roof gasoline above ground storage
tank (AST)

OHIO ENVIRONMENTAL PROTECTION AGENCY

To be signed upon final issuance

Christopher Jones
Director

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T003 (Storage Tank 8)
domed external floating roof gasoline above ground storage
tank (AST)

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T003 (Storage Tank 8)
domed external floating roof gasoline above ground storage
tank (AST)

cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T003 (Storage Tank 8)
domed external floating roof gasoline above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T004 (Storage Tank 10)
domed external floating roof gasoline above ground
storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

A handwritten signature in black ink that reads "Thomas G. Rigo". The signature is written in a cursive style.

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T003 (Storage Tank 8)
domed external floating roof gasoline above ground storage
tank (AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T004 (Storage Tank 10)
domed external floating roof gasoline above ground storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T003 (Storage Tank 8)
domed external floating roof gasoline above ground storage
tank (AST)

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

To be signed upon final issuance

Christopher Jones
Director

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T004 (Storage Tank 10)
domed external floating roof gasoline above ground storage
tank (AST)

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T004 (Storage Tank 10)
domed external floating roof gasoline above ground storage
tank (AST)

cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T004 (Storage Tank 10)
domed external floating roof gasoline above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T005 (Storage Tank 16)
fixed roof distillate above ground storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

A handwritten signature in black ink that reads "Thomas G. Rigo". The signature is written in a cursive style.

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T004 (Storage Tank 10)
domed external floating roof gasoline above ground storage
tank (AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T005 (Storage Tank 16)
fixed roof distillate above ground storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T004 (Storage Tank 10)
domed external floating roof gasoline above ground storage
tank (AST)

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T005 (Storage Tank 16)
fixed roof distillate above ground storage tank (AST)

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T005 (Storage Tank 16)
fixed roof distillate above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T006 (Storage Tank 11)
fixed roof distillate above ground storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

A handwritten signature in black ink that reads "Thomas G. Rigo".

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T005 (Storage Tank 16)
fixed roof distillate above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T006 (Storage Tank 11)
fixed roof distillate above ground storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Draft State Permit To Operate - General Terms and Conditions

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T005 (Storage Tank 16)
fixed roof distillate above ground storage tank (AST)

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T006 (Storage Tank 11)
fixed roof distillate above ground storage tank (AST)

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T008 (Storage Tank 1)
internal floating roof gasoline above ground storage tank
(AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,



Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T006 (Storage Tank 11)
fixed roof distillate above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T008 (Storage Tank 1)
internal floating roof gasoline above ground storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Draft State Permit To Operate - General Terms and Conditions

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T006 (Storage Tank 11)
fixed roof distillate above ground storage tank (AST)

To be signed upon final issuance

Christopher Jones
Director

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T008 (Storage Tank 1)
internal floating roof gasoline above ground storage tank
(AST)

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T008 (Storage Tank 1)
internal floating roof gasoline above ground storage tank
(AST)

cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T008 (Storage Tank 1)
internal floating roof gasoline above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T011 (Storage Tank 6)
fixed roof distillate above ground storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

A handwritten signature in black ink that reads "Thomas G. Rigo".

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T008 (Storage Tank 1)
internal floating roof gasoline above ground storage tank
(AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T011 (Storage Tank 6)
fixed roof distillate above ground storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T008 (Storage Tank 1)
internal floating roof gasoline above ground storage tank
(AST)

OHIO ENVIRONMENTAL PROTECTION AGENCY

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T011 (Storage Tank 6)
fixed roof distillate above ground storage tank (AST)

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T012 (Storage Tank 15)
internal floating roof gasoline above ground storage tank
(AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,



Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T011 (Storage Tank 6)
fixed roof distillate above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T012 (Storage Tank 15)
internal floating roof gasoline above ground storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Draft State Permit To Operate - General Terms and Conditions

Facility Name: **BP Exploration & Oil Inc - Dayton Terminal**
Facility ID: **08-57-04-0266**
Emissions Unit: **T011 (Storage Tank 6)**
fixed roof distillate above ground storage tank (AST)

To be signed upon final issuance

Christopher Jones
Director

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T012 (Storage Tank 15)
internal floating roof gasoline above ground storage tank
(AST)

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T012 (Storage Tank 15)
internal floating roof gasoline above ground storage tank
(AST)

cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T012 (Storage Tank 15)
internal floating roof gasoline above ground storage tank (AST)



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T013 (Storage Tank 5)
fixed roof horizontal storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

A handwritten signature in black ink that reads "Thomas G. Rigo". The signature is written in a cursive style.

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T012 (Storage Tank 15)
internal floating roof gasoline above ground storage tank
(AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T013 (Storage Tank 5)
fixed roof horizontal storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T012 (Storage Tank 15)
internal floating roof gasoline above ground storage tank
(AST)

OHIO ENVIRONMENTAL PROTECTION AGENCY

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T013 (Storage Tank 5)
fixed roof horizontal storage tank (AST)

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T013 (Storage Tank 5)
fixed roof horizontal storage tank (AST)



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T020 (Storage Tank 19)
fixed roof horizontal storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

A handwritten signature in black ink that reads "Thomas G. Rigo". The signature is written in a cursive, flowing style.

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T013 (Storage Tank 5)
fixed roof horizontal storage tank (AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T020 (Storage Tank 19)
fixed roof horizontal storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Draft State Permit To Operate - General Terms and Conditions

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T013 (Storage Tank 5)
fixed roof horizontal storage tank (AST)

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T020 (Storage Tank 19)
fixed roof horizontal storage tank (AST)

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T020 (Storage Tank 19)
fixed roof horizontal storage tank (AST)



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

06/19/02

CERTIFIED MAIL

RE: Draft Chapter 3745-35 Permit To Operate

**T021 (Storage Tank 20)
fixed roof horizontal storage tank (AST)**

BP Exploration & Oil Inc - Dayton Terminal (08-57-04-0266)
LeAnne Kunce
4800 E 49th St CC-II 112D
Cleveland, OH 44125

Dear LeAnne Kunce:

You are hereby notified that the Ohio Environmental Protection Agency Division of Air Pollution Control has recommended that the Director issue a draft permit for the emission unit(s) included in the enclosed draft permit document(s). The purpose of the draft permit document is to solicit public comments on the proposed permit. A public notice concerning the draft permit(s) will appear in the "Ohio EPA Weekly Review" and the newspaper in the county where the emission unit(s) will be located. Comments from the public and any affected parties will be accepted by the field office within thirty (30) days of the date of publication in the newspaper.

A permit to operate may be issued in proposed or final form based on the preliminary determination, any written public comments received within thirty (30) days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting if one is requested.

If you have any questions about this draft permit, please contact the RAPCA at (937) 225-4435

Very truly yours,

A handwritten signature in black ink that reads "Thomas G. Rigo". The signature is written in a cursive, flowing style.

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: RAPCA
File, DAPC PMU

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T020 (Storage Tank 19)
fixed roof horizontal storage tank (AST)



State of Ohio Environmental Protection Agency

Draft Permit To Operate An Emissions Unit

Effective Date: To be entered upon final issuance

Expiration Date: To be entered upon final issuance

This document constitutes issuance to:

Facility ID: 08-57-04-0266
BP Exploration & Oil Inc - Dayton Terminal
621 Brandt Pike
Dayton, OH 45404-0000

of a permit to operate for:

T021 (Storage Tank 20)
fixed roof horizontal storage tank (AST)

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Draft State Permit To Operate - General Terms and Conditions

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T020 (Storage Tank 19)
fixed roof horizontal storage tank (AST)

To be signed upon final issuance

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit.

Facility Name: BP Exploration & Oil Inc - Dayton Terminal
Facility ID: 08-57-04-0266
Emissions Unit: T021 (Storage Tank 20)
fixed roof horizontal storage tank (AST)

Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

RAPCA
451 West Third Street
PO Box 972
Dayton, OH 45422
(937) 225-4435

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.