

**OHIO'S PUBLIC WATER SYSTEMS
ANNUAL COMPLIANCE REPORT**

FOR

CALENDAR YEAR 2007

**OHIO ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF DRINKING AND GROUND WATERS
JULY 1, 2008**

TABLE OF CONTENTS

Introduction 1

The Drinking Water Program: An Overview 1

Regulated Public Water Systems in Ohio 2

Annual State PWS Compliance Report 3

Maximum Contaminant Level 3

Treatment Techniques 4

Monitoring 4

Consumer Notification 4

Maximum Residual Disinfectant Level 4

Compliance Table Summary Analysis 5

Organic Contaminants 8

Inorganic Contaminants 11

Radionuclide Contaminants 13

Total Coliform Regulations 14

Surface Water Treatment Regulations 16

Lead and Copper Regulations 18

Consumer Confidence Report Requirements 19

Compliance Summary 20

Ohio EPA’s Public Water System Compliance Assistance 21

Listing of Maximum Contaminant Level and Treatment Technique Violations . 22

Report Availability and Contact Information 23

APPENDIX A: COMPLIANCE SUMMARY TABLE

APPENDIX B: MCL and TT VIOLATION LISTING

List of Tables

Table 1.	Public Water System Summary by Category Type	2
Table 2.	Public Water System Summary by Source Type	3
Table 3.	Public Water System Summary by Population Categories	3
Table 4.	Violation Totals and Compliance Rates per Contaminant Group	5
Table 5.	Violation Totals for 2007.	6
Table 6.	Violation Totals and Compliance Rates for Individual MCL Contaminant Group Constituents	7
Table 7.	Enforcement Action Code Types	22

List of Figures

Figure 1.	Percentage Distribution of PWSs with Violations per System Type and Population Served Category	6
Figure 2.	Systems with Organic Contaminant Monitoring/Reporting Violations by Population Categories	10
Figure 3.	Systems with Organic Contaminant Monitoring/Reporting Violations by System Type	10
Figure 4.	Systems with Inorganic Contaminant Monitoring/Reporting Violations by System Type	12
Figure 5.	Systems with Inorganic Contaminant Monitoring/Reporting Violations by Population Categories	13
Figure 6.	Community Systems with Radionuclide Contaminant Monitoring/Reporting Violations by Population Categories	14
Figure 7.	Systems with Total Coliform MCL (Acute and Non-Acute) and Significant Monitoring/Reporting Violations by Population Categories	15
Figure 8.	Systems with Total Coliform MCL (Acute and Non-Acute) and Significant Monitoring/Reporting Violations by System Type	16
Figure 9.	Systems with Surface Water Treatment Rule Monitoring/Reporting and Treatment Technique Violations by System Type	17
Figure 10.	Systems with Surface Water Treatment Rule Monitoring/Reporting and Treatment Technique Violations by Population Categories	17
Figure 11.	Systems with Lead and Copper Significant Initial and Follow-up/Routine Monitoring/Reporting Violations by Population Categories	18
Figure 12.	Systems with Lead and Copper Significant Initial and Follow-up/Routine Monitoring/Reporting Violations by System Type	19
Figure 13.	Systems with Consumer Confidence Report Violations by Population Categories	20

Introduction

The 1996 Amendments to the Safe Drinking Water Act require each State to prepare an Annual Compliance Report summarizing violations incurred by public water systems. The Annual Compliance Report is to be compiled by the State and submitted to U.S. EPA and made available to the public. This report summarizes compliance rates and the number and types of violations generated as a result of various public water systems failing to meet certain Safe Drinking Water Act requirements for calendar year 2007.

Ohio's 2007 Annual Compliance Report contains an overview of the Public Water System Supervision Program in Ohio; provides summary information on the number, types and population served for public water systems; explains the requirements of the Annual Compliance Report; defines the primary categories for which violation information is summarized; a summary table of the number and types of violations; an analysis of public water system compliance with the regulations; and a list of public water system violations for the maximum contaminant level and treatment technique categories.

The method of calculating compliance rates for this report is consistent with the expectations of U.S. EPA to measure progress toward meeting a series of compliance goals for the public water supply program. Compliance rates for this report are based on the number of violations or number of public water systems in violation compared to the total number of water systems subject to the specific monitoring/reporting requirement or health standard of interest. Prior to the 2006 Annual Compliance Report, Ohio's Annual Compliance Report compared violations to the number of water systems subject to specific monitoring/reporting requirements during that specific calendar year. Because some water systems are not required to monitor for certain contaminants every calendar year, the different methods yield different compliance rates in some categories.

The Drinking Water Program: An Overview

U.S. EPA established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 and 1996 Amendments, U.S. EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs). For some regulations, U.S. EPA establishes treatment techniques in lieu of an MCL to control unacceptable levels of contaminants in water by measuring the level of treatment. The Agency also regulates how often public water systems (PWSs) monitor their water for contaminants and report the monitoring results to the States or U.S. EPA. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M/R) requirements. However, the M/R requirements vary dependent on which contaminant is being evaluated and the source water used by a system (surface water systems and systems that use ground water under the direct influence of surface water typically monitor more frequently than a ground water system). Finally, public water systems are required to notify the public when they have violated these regulations. The 1986 Amendments and further revisions under the 1996 Amendments to the SDWA require public notification to include a clear and understandable explanation of the nature of the violation, its potential adverse health effects, steps that the public water system is undertaking to correct the violation and the possibility for the need to obtain alternative water supplies during the violation.

The SDWA allows States to seek U.S. EPA approval to administer their own PWSS Programs. The authority to run a PWSS Program is called primacy. To receive primacy, States must meet certain requirements in the SDWA and the regulations, including the adoption of drinking water regulations that are at least as stringent as the Federal regulations and provide a demonstration that they can enforce the program requirements. *Ohio is a primacy state.*

Regulated Public Water Systems in Ohio

In Ohio, a public water system is defined as a system that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of public water systems (PWS):

- community water systems serve at least fifteen service connections used by year-round residents or regularly serve at least twenty-five year-round residents (e.g. cities; mobile home parks)
- nontransient noncommunity systems serve at least twenty-five of the same persons over six months per year (e.g. schools; businesses)
- transient noncommunity systems serves at least 25 different persons over 60 days per year (e.g. rest stops; parks)

These three type of systems use either a ground water source, surface water source, or use ground water under the direct influence of surface water. In addition, Ohio regulates the drinking water systems associated with agricultural migrant labor camps as defined by the Ohio Department of Agriculture even though they may not meet the minimum number of people or service connections. For this report when the acronym “PWS” is used, it means systems of all types unless specified in greater detail. In Ohio, 5,340 public water systems serve approximately 11.1 million people daily with an average production of approximately 1.7 billion gallons of water per day. This yields an average water use of 153 gallons per person per day. Table 1 summarizes the total number and percentage of active public water systems per type with the corresponding total population served daily. Table 2 summarizes the number of public water systems by source type.

The total number and percentage of PWS by population categories are presented in Table 3. An interesting note from this table is that 12 PWS, less than 1 percent of the total systems in the state, serve over 40 percent of the entire Ohio population.

Table 1. Public Water System Summary by Category Type

PWS Category Type	Number of PWS per Category	Percentage of each PWS Type	Total Population Served Daily per Category
Community (CWS)	1,296	24%	10,414,078
Non-Transient Non-Community (NTNC)	918	17%	229,338
Transient Non-Community (TNC)	3,126	59%	457,391
Total	5,340	100%	11,100,807

Table 2. Public Water System Summary by Source Type

PWS Category Type	Surface Waters	Ground Waters	Purchased Surface Waters	Purchased Ground Waters
Community (CWS)	119	895	177	105
Non-Transient Non-Community (NTNC)	6	902	3	7
Transient Non-Community (TNC)	17	3,088	7	14
Total	142	4,885	187	126

Table 3. Public Water System Summary by Population Categories

PWS Populations Categories	Number of PWS per Category	Percentage of the Total PWS for each Category	Total Population Served Daily per Category
Population: 25 - 500	4,358	81.6%	552,245
Population: 501 - 3,300	660	12.4%	823,702
Population: 3,301 - 10,000	160	3%	969,668
Population: 10,001 - 100,000	150	2.8%	3,892,699
Population: Greater than 100,000	12	0.2%	4,862,493
Total	5,340	100%	11,100,807

Annual State PWS Compliance Report

Ohio EPA submits data to U.S. EPA's Safe Drinking Water Information System (SDWIS/FED) on a quarterly basis. The data includes PWS inventory statistics, the incidence of MCL, major monitoring, treatment technique violations, and the enforcement actions taken against violators. This Annual Compliance Report provides a total annual representation of the number of violations for each of the four categories listed in section 1414(c)(3)(A)(i) of the Safe Drinking Water Act re-authorization, as well as consumer notification requirements. This report will analyze violation and compliance information for the 2007 calendar year using four categories: MCLs, treatment techniques, significant monitoring violations, and consumer notifications. This report was generated with the data available in Ohio EPA's database as of May 2008.

1. *Maximum Contaminant Level*

Under the SDWA, U.S. EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as MCLs. When a PWS exceeds an MCL, it is required to notify the public of the violation within 24 hours for acute violations that may pose an acute risk to human health (e.g. nitrate; total coliform), and within 30

days for nonacute MCL violations (e.g. volatile organic chemicals; synthetic organic chemicals). In addition, the water system must continue to monitor regularly, as well as take steps to correct the contamination problem.

2. *Treatment Techniques*

For some regulations, the U.S. EPA establishes treatment techniques (TTs) in lieu of an MCL to control unacceptable levels of certain contaminants by a measurement of the treatment process. Treatment techniques have been established for viruses, some bacteria, turbidity, lead and copper and disinfection by-product precursors.

3. *Monitoring*

A PWS is required to monitor and verify that the levels of contaminants present in the water do not exceed the MCL. If a PWS fails to have its water tested as required, then a monitoring violation occurs. A monitoring violation also includes failure to report test results correctly to the State. These violations occur when a system misses one or more of several sampling events, or samples but does so outside the required time period. When a PWS fails to have its water tested as required, it is required to notify the public of the violation. For a system monitoring less frequently than quarterly, it is required to sample for the contaminant(s) missed, in order to return to compliance.

Return to Compliance

As noted in the definition of monitoring violations, systems which monitor less frequently than quarterly can return to compliance by monitoring before their next scheduled monitoring period. In this report, return to compliance rates were determined for inorganic contaminants; nitrate; nitrite; regulated volatile organic contaminants; synthetic organic contaminants; total trihalomethanes; haloacetic acids; and radiological contaminants, as a group.

Significant Monitoring Violations

For this report, significant monitoring violations are defined as any major monitoring violation that has occurred during the specified report interval. A major monitoring violation occurs when no samples were taken or no results are reported during a compliance period.

4. *Consumer Notification*

Every Community Water System is required to deliver to its customers a brief annual water quality report - a Consumer Confidence Report (CCR). This report is to include some educational material, and provide information on the source water, the levels of any detected contaminants, and compliance with drinking water regulations.

Significant Consumer Notification Violations

A significant consumer notification violation occurred if a community water system completely failed to provide its customers the required annual water quality report.

5. *Maximum Residual Disinfectant Level*

U.S. EPA sets national limits on residual levels of disinfectants in drinking water to reduce the risk of exposure to disinfection byproducts formed when PWSs add chemical disinfectants for either primary or residual treatment. These limits are known as Maximum Residual Disinfectant Levels (MRDLs).

Compliance Table Summary Analysis

A summary table of PWS compliance rates and violations for the 2007 calendar year is included in

Appendix A. The information summarized in the table includes the total number of PWS required to comply with individual contaminant requirements; total number of violations; total number of systems with a violation; and percent compliance achieved for a particular regulated contaminant in three different violation categories. These violation categories are MCL, Treatment Technique and Monitoring/CCR. The regulatory contaminant categories include: organic contaminants, inorganic contaminants, and radionuclide contaminants, all of which are classified as the MCL contaminant group; total coliform bacteria regulations (TCR); surface water treatment regulations (SWTR); interim enhanced surface water treatment regulations (IESWTR); lead and copper regulations, and CCR notifications.

Violation totals and compliance rates for each of the contaminant groups are presented in Table 4. Compliance rates are based on the total number of systems required to comply with each of the contaminant categories. For example, the 89 % SWTR compliance rate is based on 142 systems required to meet surface water treatment requirements with 15 systems failing to fully comply during some portion of the year.

Table 4. Violation Totals and Compliance Rates per Contaminant Group Category

Contaminant Category	MCL			Treatment Technique			Monitoring or CCR notifications		
	Violations	No. of Systems in Violation	Comp. Rate	Violations	No. of Systems in Violation	Comp. Rate	Violations	No. of Systems in Violation	Comp. Rate
MCL Contaminant Group ¹	339	116	98%				1,656	455	91%
TCR ²	371	283	95%				1,427	941	82%
SWTR ³				51	15	89%	2	1	99%
Lead and Copper				4	4	99%	104	98	95%
CCR ⁴							53	52	96%
TOC ⁵				2	1	99%	6	3	98%
IESWTR ⁶ and LT1 ⁷				3	2	99%	2	2	99%

¹MCL Contaminant Group includes volatile organic, synthetic organic, inorganic, total trihalomethanes, haloacetic acid, nitrate and nitrite chemicals and radiological contaminants

²Total Coliform Rule

³SurfaceWwater Treatment Rule

⁴consumer confidence reports

⁵total organic carbon


⁶Interim Enhanced Surface Water Treatment Rule

⁷Long Term Enhanced Surface Water Treatment Rule

Table 5. State of Ohio Violation Totals for 2007

	MCL	Monitoring	CCR	Treatment Technique	Totals
Number of Community Systems in Violation	78	186	52	9	276
Number of Community Violations	206	718	53	21	1,000
Number of Nontransient Systems in Violation	105	206	NA	0	269
Number of Nontransient Violations	218	1,042	NA	0	1,262
Number of Transient Systems in Violation	213	825	NA	8	910
Number of Transient Violations	287	1,445	NA	35	1,767
Total Number of Systems in Violation	399	1,217	52	17	1,455
Total Number of Violations	711	3,205	53	56	4,029

Figure 1.



As depicted in Figure 1, of all water systems with at least one violation, 63 percent were associated with TNC water systems, 18 percent with NTNC water systems and 19 percent with CWS. Of the PWS having one or more violations, 88 percent were associated with a population served category of fewer than 500 people per day.

Approximately 80 percent of the violations in Ohio occur because public water systems fail to monitor and report for various required contaminants in the period as specified on an individual system monitoring schedule provided by the Director of Ohio EPA or by rule, or as a result of failing to collect follow-up or repeat samples. An average of 19 percent of systems returned to compliance following their violation(s) (see the definition of “return to compliance” for the list of contaminants included in the calculation). A detailed analysis of each contaminant group and violation category is presented below. When sufficient data was available, charts displaying the number of water systems with a violation per system type and population categories have been prepared and included in this report.

MCL Contaminant Group

The total number of violations and total number of water systems with at least one violation in the MCL Contaminant Group is presented in more detail in Table 6.

Table 6. Violation Totals and Compliance Rates for the Individual MCL Contaminant Group Constituents

Contaminant Category	MCL				Monitoring Requirements			
	Violations	No. of Systems in Violation	No. of Systems Required to Monitor	Comp. Rate	Violations	No. of Systems in Violation	No. of Systems Required to Monitor	Comp. Rate
VOCs ¹	3	2	1929	99.9%	1,050	45	1929	98.0%
SOCs ²	0	0	1929	100.0%	6	2	1929	99.0%
TTHMs ³	92	34	1483	98.0%	75	74	1483	95.0%
HAAs ⁴	32	14	1483	99.0%	73	73	1483	95.0%
IOCs ⁵	205	71	1929	96.0%	159	52	1929	97.0%
Nitrate	7	5	5066	99.9%	262	246	5066	95.0%
Nitrite	0	0	5066	100.0%	0	0	5066	100.0%
Rads ⁶	0	0	1026	100.0%	30	10	1026	99.0%

¹volatile organic chemicals

²synthetic organic chemicals

³total trihalomethanes

⁴haloacetic acids

⁵inorganic chemicals

⁶radiological contaminants

Organic Contaminants

The organic contaminants group summarized in the Compliance Table include: volatile organic chemicals (VOCs); synthetic organic chemicals (SOCs); total trihalomethanes (TTHMs) and haloacetic acids (HAAs).

VOCs are predominantly used as solvents, degreasers, cleaning solutions, dry cleaning fluids, and components of pesticides and plastics. These chemicals are described as volatile because of their tendency to evaporate. They generally enter drinking water systems through spills and improper disposal. VOCs are monitored by all community and nontransient noncommunity systems. PWS are placed on one of three schedules based on source type and past monitoring history: one sample quarterly, one sample annually, or one sample in 3 years. During the three year compliance period from 2005 through 2007, approximately 1,929 public water systems were required to sample at least once for VOCs. A significant difference to note between monitoring for VOCs and other contaminant groups is that every time a PWS samples for VOCs, they are required to have the sample analyzed for 21 regulated VOC compounds using one analytical method which scans for all of the compounds. So, for each missed VOCs sample, a PWS would have 21 violations for the regulated VOC compounds. This creates an artificially high number of violations for the VOCs group as well as the total number of violations issued in Ohio. For 2007, there are 1050 individual VOC compound M/R violations. This really represents 50 VOCs samples which were not collected. During 2007, 45 of the approximately 1,929 public water systems required to sample during the three year compliance period from 2005 through 2007 failed to collect one or more samples which resulted in a M/R violation. Overall compliance for the VOC M/R is 98 percent. Approximately 64 percent of the VOC M/R violations were associated with nontransient noncommunity systems and all but one of the VOC M/R violations were attributed to systems serving 3,300 or fewer persons. Two systems exceeded one of the VOC MCLs.

VOC Contaminant Group Highlights

- ▶ 1,929 public water systems required to collect VOC samples
- ▶ 99.9 percent compliance with all VOC MCLs
- ▶ 98 percent of the public water systems are in compliance for the VOC M/R category
- ▶ 1050 individual VOC M/R violations
- ▶ 99 percent of the VOC M/R violations occurred at PWS serving less than 3,300 people

SOCs, which includes primarily pesticides, are monitored by all community and nontransient noncommunity PWS. Some of the SOC are monitored more often than others because they are used in large quantities on Ohio farm fields, like alachlor, atrazine, and simazine. Based on Ohio's pesticide study, some systems are required to monitor more frequently during time periods which are most likely to see occurrence of the contaminants.

Ground water systems monitor for alachlor, atrazine, and simazine at least once every three years. If a ground water system has a detection for one of these SOC, they are required to monitor at a minimum on a quarterly basis.

Because Ohio's surface water systems are more vulnerable to pesticide contamination, they typically are required to monitor for alachlor, atrazine, and simazine at a much greater frequency than ground water systems, including every-other-week May thru July for systems that have a history of elevated pesticide levels in their finished water.

All systems are required to monitor the remaining 14 SOC once every three years if they have a mean nitrate measurement greater than 2 mg/L. Nitrate is used as an indicator of a system's susceptibility. Monitoring waivers are granted for systems that have a mean nitrate concentration less than or equal to 2

mg/L. The waivers are granted for a 3-year period and must be renewed when that period lapses.

Approximately 1,929 public water systems were required to sample for one or more of the SOC compounds during the three year compliance period from 2005 through 2007. During 2007, there were 2 public water systems that failed to collect one or more SOC samples which resulted in a M/R violation. No public water systems exceeded an SOC MCL during 2007. The overall M/R compliance rate for 2007 was 99 percent.

SOC Contaminant Group Highlights

- ▶ 1,929 public water systems required to sample for SOCs
- ▶ 100 percent compliance with all SOCs MCLs
- ▶ 99 percent of the public water systems were in compliance for all SOCs M/R
- ▶ 100 percent of the M/R violations occurred at PWS serving less than 500 people

TTHMs are classified as organic disinfection by-products. They are created when organic and inorganic compounds react with the disinfectant added to the water. (It is important to note that disinfectants are an important part of the control of water-borne pathogens.) TTHMs are sampled in the distribution systems of community and noncommunity PWS that treat their water with any combination of chlorine, chloramines, chlorine dioxide or ozone. Community water systems and nontransient noncommunity surface water systems serving less than 10,000 persons, and nontransient noncommunity ground water systems that disinfect were required to sample for TTHMs beginning in 2004.

During the three year compliance period from 2005 through 2007, approximately 1,483 PWSs were required to monitor for TTHMs. During the 2007 calendar year, there were 74 systems that failed to monitor, and 34 systems exceeded the MCL of 0.080 milligrams per liter (mg/L). Compliance with the TTHM MCL is determined by calculating a running annual average at the end of each quarter. Some people who drink water containing TTHMs in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

HAAs are another class of organic disinfection by-products that form when a disinfectant reacts with organic matter in the water. Community water systems and nontransient noncommunity surface water systems serving less than 10,000 persons, and nontransient noncommunity ground water systems that disinfect were required to sample for HAAs beginning in 2004.

Approximately 1,483 PWSs were required to monitor quarterly for haloacetic acids during the three year compliance period from 2005 through 2007. For 2007, there were 73 systems that failed to monitor for haloacetic acids, and 14 systems exceeded the MCL of 0.060 mg/L.

TTHMs and HAAs Contaminant Group Highlights

- ▶ 1,483 public water systems required to sample for TTHMs during the 3 year compliance period
 - ▶ 1,483 public water systems required to sample for HAAs during the 3 year compliance period
 - ▶ 98 percent compliance with the TTHMs MCL
 - ▶ 99 percent compliance with the HAAs MCL
 - ▶ 95 percent compliance for TTHMs and HAAs M/R
 - ▶ 72 percent of the TTHM/HAAs M/R violations occurred at PWS serving less than 500 people
- Figures 2 and 3 show VOCs, SOCs, TTHMs, and HAAs violation numbers by population categories and system types, respectively. For specific information on each contaminant, such as the number of PWSs required to sample a contaminant in 2007 and how many violations occurred for that contaminant, please

refer to the Appendix A Compliance Table.

Figure 2.





Figure 3.



Inorganic Contaminants

The inorganic contaminant group summarized in the Appendix A Compliance Table includes metals (e.g. chromium, cadmium, mercury, etc.) and non-metal contaminants (e.g. asbestos, cyanide, nitrate, etc.). Many of these naturally occurring chemicals are also used in different manufacturing processes. Nitrate and nitrite are separated out as a group from the other IOCs for monitoring purposes and they are discussed in a separate section below. Both IOCs and Nitrate/Nitrite violation numbers are shown in Figures 4 and 5.

IOCs are monitored by all community and nontransient noncommunity PWS. Most IOCs are monitored by surface water systems on an annual basis and by ground water systems once in 3 years. One exception is asbestos, which is monitored once in 9 years. During the three year compliance period from 2005 through 2007, approximately 1,929 public water systems were required to sample for at least one of the 12 individual IOC chemicals. The overall M/R compliance rate for the IOCs contaminant group is 97 percent. Of the 52 water systems with an IOCs M/R violation, approximately 20 percent were community water systems, and 80 percent were noncommunity water systems. However, 96 percent of all M/R violations were associated with water systems serving less than 500 people. Beginning on January 1, 2006, the MCL for arsenic, a naturally occurring element that can cause skin damage, circulatory problems and cancer, was reduced from 0.05 mg/L to 0.010 mg/L. Seventy-one water systems exceeded the arsenic MCL during 2007.

IOC Contaminant Group Highlights

- ▶ 1,929 public water systems were required to sample for at least one IOC during the 2005 - 2007 compliance period
- ▶ 96 percent compliance with all IOCs MCLs
- ▶ 97 percent of the public water systems were in compliance for IOCs M/R
- ▶ 96 percent of the M/R violations were associated with public water systems serving fewer than 500 people

Nitrate/Nitrite

Nitrate contamination of drinking water usually results from runoff of agricultural fertilizers, or from human or animal wastes, such as feedlots or faulty septic systems. Nitrite is the reduced form of nitrate, and is usually found in nature at lower levels than nitrate. Nitrate is monitored by all CWS, NTNC, and TNC PWS. Nitrate is monitored monthly by surface water systems, ground water systems under the direct influence of surface water, and by systems using treatment to remove nitrate. Ground water systems monitor annually for nitrate. Some ground water systems may be monitoring quarterly for nitrate based upon the levels reported in previous sampling. After initial monitoring shows that nitrite levels are less than one half of the MCL, many water systems are required to monitor for nitrite only once every nine years. Occurrence of nitrate, nitrite or nitrate/nitrite may require the systems to do additional monitoring. Approximately 5,066 water systems were required to monitor for nitrate and nitrite during the three year compliance period from 2005 through 2007.

The compliance rate for nitrate M/R during 2007 is 95 percent and 100 percent for nitrite. Of the 246 water systems with a nitrate M/R violation during the 2007 calendar year, 93 percent were issued to transient water systems and approximately 96 percent of the violations were associated with systems serving fewer than 500 people.

During the 2007 calendar year, 7 nitrate MCL violations occurred at 5 different water systems. There were no MCL violations for nitrite during 2007. Infants below the age of six months who drink water containing nitrate or nitrite in excess of the MCL could become seriously ill and if untreated, may die. Symptoms include shortness of breath and a bluish tint to the skin from a condition known as blue-baby

syndrome.

Nitrate/Nitrite Contaminant Group Highlights

- ▶ 5,066 water systems were required to monitor for nitrate and nitrite during the three year compliance period from 2005 through 2007
- ▶ 99.9 percent compliance rate for nitrate MCLs
- ▶ 100 percent compliance rate for nitrite MCLs
- ▶ 7 nitrate MCL violations occurred at 5 water systems
- ▶ 86 percent of the MCL violations occurred at public water systems serving fewer than 500 people

- ▶ 95 percent of the public water systems were in compliance for nitrate M/R
- ▶ 100 percent of the public water systems required to monitor were in compliance for nitrite M/R
- ▶ 96 percent of the nitrate M/R violations were associated with public water systems serving fewer than 500 people

For specific information on each contaminant, such as the number of PWS required to sample a contaminant in 2007 and how many violations occurred for that contaminant, please refer to Appendix A-Compliance Table.

Figure 4.





Figure 5.



Radionuclide Contaminants

The radionuclide group, which includes the contaminants gross alpha, gross beta, radium-226 and radium-228, and uranium, occurs from the erosion or decay of natural and manmade deposits. Drinking water containing radionuclide contaminants in excess of the MCL may increase the risk of getting cancer. Radium-226 is only monitored individually when a PWS exceeds the gross alpha action level of 5 pCi/L or if the total alpha and radium-228 exceeds 5 pCi/L.


Radionuclides are monitored by approximately 1,026 community PWSs. Initially, systems monitor for radionuclides quarterly, unless they qualified for reduced monitoring at three, six, or nine year intervals. If the MCL is exceeded, systems must perform quarterly monitoring. The overall radionuclide MCL compliance rate is 100 percent. The overall compliance rate for radionuclide M/R is 99 percent. Of the 10 public water systems that had M/R violations during the 2007 calendar year, 90 percent were associated with systems serving fewer than 500 people.

Radionuclides Contaminant Group Highlights

- ▶ 1,026 community public water systems are required to sample for radionuclides
- ▶ 100 percent compliance rate for radionuclide MCLs
- ▶ 99 percent of the water systems were in compliance for radionuclides M/R
- ▶ 90 percent of the M/R violations were associated with public water systems serving fewer than 500 people

For specific information on each contaminant, such as the number of PWSs required to sample a contaminant in 2007 and how many violations occurred for that contaminant, please refer to Appendix A.

Figure 6.



Total Coliform Regulations

Total coliform monitoring is used to determine if microbiological contaminants are present in drinking water. Total coliform is a family of bacteria which contain pathogenic as well as harmless organisms. Fecal coliform and *E. coli* bacteria are specific types of coliform bacteria which are associated with animal waste and present an acute human health threat. Microbiological pathogens can cause gastrointestinal illness and pose a special risk to children, the elderly and those individuals with suppressed immune systems. In Ohio, a total coliform (TC) test is used initially as a screening to indicate whether or not microbiological contaminants may be present. If a sample is TC positive (total coliform bacteria is present), further analysis for either fecal coliform or *E. coli* and the collection of additional samples are required to determine if potentially harmful contamination is present. TC is monitored by all PWSs. The frequency of TC testing and the number of samples collected is dependent upon the type of PWS, the population served and source type. Sampling requirements range from as few as one TC sample per quarter for small TNC water systems to hundreds of TC samples per month for large community water systems. Ohio's minimum monitoring requirements of one sample per quarter can be up to four times as frequent as the federal requirements. Two types of MCL violations, acute and non-acute, are associated with the total coliform regulations. An acute violation occurs when more than one sample is total coliform positive and at least one sample contains *E. coli* or fecal coliform bacteria. Non-acute MCL violations occur when greater than 5 percent (or 2 or more samples if collecting less than 40 samples per month) of all the samples collected during a month are TC positive.

During the 2007 calendar year, the compliance rate for the TC acute MCL was 99 percent and 94 percent

for the TC non-acute MCL. Of the 283 water systems with TC MCL violations, 74 percent were associated with TNC water systems, and 91 percent were associated with water systems serving less than 500 people. Of the 5,340 PWSs sampling for total coliform, approximately 48 (less than 1 percent) detected *E. coli* or fecal coliform.

Major routine and follow-up M/R violations for the TC regulations are incurred by water systems when they fail to sample or report all of the required samples during a given monitoring period. Of the water systems with one or more major routine and follow-up M/R violations, 80 percent were associated with TNC water systems and 93 percent were associated with water systems serving less than 500 people.

Total Coliform Contaminant Group Highlights

- ▶ 5,340 public water systems were required to sample for TC
- ▶ 99 percent compliance with the acute MCL
- ▶ 94 percent compliance with the non-acute MCL
- ▶ 82 percent compliance with the TC M/R requirements
- ▶ 93 percent of the M/R violations and 91 percent of MCL violations were associated with public water systems serving fewer than 500 people, mostly TNC water systems

Figure 7.





Figure 8.



Surface Water Treatment Regulations

The Surface Water Treatment Rule (SWTR), Interim Enhanced Surface Water Treatment Rule (IESWTR), and Long Term 1 Enhanced Surface Water Treatment Rule (LT1) establish treatment and monitoring standards for water systems that have sources designated as surface water or ground water under the direct influence of surface water. Ground water under the direct influence (GUDI) of surface water are systems that use wells to obtain their water, but the water quality is subject to the influence of surface water. GUDI systems have 18 months, by rule, to eliminate the causes of the GUDI designation or install surface water treatment. The influence of surface water can be from unacceptably constructed wells to the type of aquifer from which the system is drawing. Public water systems subject to these regulations are required to provide filtration and disinfection of the water. The surface water treatment requirements are designed to inactivate, kill or remove pathogens found in surface water. Microbiological pathogens can cause gastrointestinal illness and pose a special risk to children, the elderly and those individuals with suppressed immune systems. Water quality tests are performed on the water to ensure treatment is being maintained at a level that should prevent contamination. Tests include evaluation and measurement of sufficient chlorination contact time, filtration type and effectiveness, turbidity levels, and residual chlorine levels in the distribution system. Failure to meet one or more of these standards results in a monthly treatment technique (TT) violation. During the 2007 calendar year, 142 water systems were subject to the surface water TT and M/R requirements. The overall TT compliance rate is 89 percent. The overall compliance rate for M/R is 98 percent. Of the 17 water systems with a TT violation during the 2007 calendar year, 47 percent were associated with systems serving fewer than 500 people.

SWTR/IESWTR/LT1 Contaminant Group Highlights

- ▶ 142 public water systems were subject to the surface water monitoring and treatment requirements
- ▶ 89 percent of the public water systems were in compliance with the TT requirements
- ▶ 98 percent of water systems which provide treatment were in compliance with the M/R requirements
- ▶ 47 percent of the water systems with a TT violations were associated with water systems serving fewer than 500 people

Figure 9.





Figure 10.



Lead and Copper Regulations

The lead and copper regulations in Ohio establish standards for levels of lead and copper in the distribution systems of community and nontransient noncommunity public water systems. Although lead and copper are found in natural deposits, they typically enter tap water through corrosion of plumbing materials. During the beginning phases of monitoring, these public water systems are required to perform initial monitoring during two consecutive six month periods. Following completion of these periods, routine annual or triennial monitoring periods are required. A total of 1,929 water systems were required to monitor for lead and copper during the three year compliance period from 2005 through 2007. Lead can affect the physical and mental development in children, as well as cause kidney problems and high blood pressure in adults. The overall compliance for lead and copper monitoring is 95 percent. Of the 98 water systems with lead and copper violations, 83 percent were associated with systems serving fewer than 500 people.

Lead and Copper Contaminant Group Highlights

- ▶ 1,929 public water systems required to perform initial, annual or triennial monitoring and public education requirements
- ▶ 95 percent of water systems were in compliance with the lead and copper M/R requirements
- ▶ 83 percent of the water systems with a lead and copper M/R violation were associated with public water systems serving fewer than 500 people

Figure 11.





Figure 12.




Consumer Confidence Reports

Every Community Water System is required to deliver to its customers a Consumer Confidence Report (CCR). This report is to include some educational material, provide information on the source water, levels of any detected contaminants, and compliance with drinking water regulations. A significant public notification violation occurred if a community water system completely failed to provide its customers the required annual water quality report. A total of 1,296 community water systems were required to provide their customers with a CCR. For the 2007 calendar year, 24 systems failed to provide this report in violation of these requirements, and 29 systems that provided a CCR did not include all the required content which resulted in a violation. The overall compliance for CCR requirements is 96 percent.

Consumer Confidence Report Highlights

- ▶ 1,296 public water systems were subject CCR requirements
- ▶ 96 percent of the water systems were in compliance with the requirements

Figure 13.



Compliance Summary

The large majority of Ohio’s public water systems continued to comply with federal health-based standards for drinking water in 2007. Highlights for 2007 include:

- Ninety-eight percent of all public water systems met the chemical standards throughout the year;
- Ninety-five percent of all public water systems met the bacteriological standards throughout the year;
- Ninety-one percent of all public water systems met all of their chemical monitoring/reporting requirements;
- Eighty-two percent of all public water systems met all of their bacteriological monitoring/reporting requirements;
- Eighty percent of the violations that occurred during 2007 were the result of public water systems failing to monitor or report in a timely fashion;
- Approximately eighty-eight percent of the violations occurred at water systems serving fewer than 500 individuals;
- Sixty-three percent of the systems with violations were transient noncommunity systems (e.g. campgrounds; gas stations);

Ohio EPA’s Public Water System Compliance Assistance

Ohio EPA employs various methods to assist public water systems in achieving compliance with the Safe

Drinking Water Act regulations. Some of the methods that may be used include: providing a monitoring schedule for each public water system; offering technical assistance during facility inspections (sanitary surveys) and follow-up visits; assisting in investigations of contamination; performing investigatory monitoring; providing off-site assistance through phone calls and meetings; providing outreach training sessions for new rules and treatment; assistance in finding funding for projects; providing operator and laboratory personnel training sessions; distributing reminder postcards and/or contacting the water systems towards the end of the monitoring period to ensure collection of the required samples; and sending notice of violation letters for failure to meet the requirements for each specific regulation. The use of these methods is based on the availability of Ohio EPA personnel and resources.

Listing of Maximum Contaminant Level and Treatment Technique Violations

Appendix B contains a listing of all violation types related to the MCL and TT regulation categories. The

listing is ordered by water system identification number and violation date. Violation type or contaminant codes associated with the violations are defined in the Appendix A Compliance Summary Table. Included in the violation listing are enforcement action type codes (e.g. A, E, G, etc) associated with each violation. These are the particular actions the State of Ohio took to address each violation with the water system. Table 7 describes the enforcement action type codes used in Appendix B. Not all violations are required to have a compliance achieved enforcement action type code associated with them when a public water system has returned to compliance. In particular, the total coliform (code 3100) MCL violations listed do not have the returned to compliance enforcement code associated violations while almost all systems have returned to compliance. A return to compliance for these violations is determined by lack of subsequent on-going violations.

Table 7. Enforcement Action Type Code Descriptions

Enforcement Action Type Code	Description
A	Notice of Violation Letter sent to Public Water System
C	Technical Assistance Visit, Meeting, or Investigation
E	Request for System to Public Notice
F	Public Notice received from Public Water System
G	Ohio EPA News Release (Public Notice)
H	Boil Water Order
J	Division, Notice of Violation Warning Letter
K	Bilateral Compliance Agreement Signed
L	Administrative Order without penalty
O	Administrative Order with penalty
Q	Civil Case Filed
R	State Consent Decree or Consent Judgement
X	Compliance Achieved
9	Civil Case Referred to Attorney Generals Office

A list of violations can also be viewed using the Internet at U.S. EPA’s site known as “Envirofacts”. This Internet site provides access to a subset of data available from U.S. EPA’s Safe Drinking Water Information System (SDWIS). Using the Envirofacts website allows the user to select by state, county, public system name, public water system identification number and population size to obtain general facility information and violation information for public water systems in Ohio. The Internet address for this Envirofacts site is http://www.epa.gov/enviro/html/sdwis/sdwis_query.html.

Summary and Report Availability & Contact Information

Ohio EPA will provide copies of the 2007 Annual Compliance Report to U.S.EPA, as well as post the report on the Division's web page at <http://www.epa.state.oh.us/ddagw/annualreports.html>. Copies of the 2007 annual report may also be obtained by writing to the State of Ohio at: PWS Annual Compliance Report, Ohio EPA - DDAGW, P.O. Box 1049, Columbus, OH 43216-1049.

In compliance with U.S. EPA's requirements, Ohio EPA will also notify the public of the availability of a summary of the 2007 annual report through the Drinking Water Advisory Committee, the Division of Drinking and Ground Waters rule list serve, and by making the summary available on the Division of Drinking Waters web site.

For further information concerning this report, you may contact Beth Messer, Mark Sheahan, or Todd Kelleher with the Ohio EPA Division of Drinking and Ground Waters at (614) 644-2752. If you have questions concerning the specific violations associated with individual water systems, contact your local Ohio EPA District Office in your region.

Scot Foltz
Ohio EPA
Central District Office
122 South Front Street
Columbus, Ohio 43215
(614) 728-3778

Janet Barth
Ohio EPA
Southeast District Office
2195 Front Street
Logan, Ohio 43138
(740) 385-8501

Jeff Davidson
Ohio EPA
Southwest District Office
401 East 5TH Street
Dayton, Ohio 45402
(937) 285-6357

Ellen Gerber
Ohio EPA
Northwest District Office
347 N. Dunbridge Road
Bowling Green, Ohio 43402
(419) 352-8461

Nancy Rice
Ohio EPA
Northeast District Office
2110 E. Aurora Road
Twinsburg, Ohio 44087
(330) 963-1200

APPENDIX A:

COMPLIANCE SUMMARY TABLE

APPENDIX B:

MCL and TT VIOLATION LISTING