

3745-95-08. Violations.

- (A) The supplier of water shall deny or discontinue, after reasonable notice to the occupant thereof, the water service to any premises wherein any backflow prevention device required by this chapter is not installed, tested and maintained in a manner acceptable to the supplier of water, or if it is found that the backflow prevention device has been removed or by-passed, or if an unprotected cross-connection exists on the premises or if a low pressure cut-off required by rule 3745-95-07 of the Administrative Code is not installed and maintained in working order, or if the supplier of water or the director, or the authorized representative of either, is denied entry to determine compliance with this chapter of the Administrative Code.

- (B) Water service to such premises shall not be restored until the consumer has corrected or eliminated such conditions or defects in conformance with this chapter of the Administrative Code, and to the satisfaction of the supplier of water.

Effective: November 26, 1980

Replaces: 3745-5-09

R.C. 119.032 review dates: 05/12/2008 and 05/12/2013

Promulgated under: R.C. Chapter 119

Rule amplifies: R.C. 6109.03; 6109.04; 6109.13

Prior effective dates: 7/1/72