

**REVISED 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**

PWS ID: 4700003 PWS Name: Amherst, City Of

Community Purchased Surface Water POPULATION: 10500

Effective Date: 3/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
------------------	-------------	---------------------------

Asbestos	1 sample between Oct 1 and Dec 31	
Haloacetic Acids (five) (HAA5)	2 Samples each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	2 Samples each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

---

---

**2004 CHEMICAL MONITORING SCHEDULE**

Autorama Twin Theater

PWS ID: 4737312 **Sample Monitoring Point: EP001**

STU NAME: Autorama Twin Theater STU ID: 4755839

Transient Noncommunity Ground Water

Effective Date: 1/1/04

---

---

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

**Chemicals**

**2004**

NITRATE	1 Sample between Jul 1 and Dec 31 Date Sample Taken: _____
NITRITE	Not Required

**NOTE: Check with your district office regarding your coliform monitoring requirements.**

**2004 CHEMICAL MONITORING ENTRY POINT SCHEDULE**

PWS NAME: Avon Lake, City Of PWS TYPE: Community Surface Water

PWS ID: 4700311 **Sample Monitoring Point: EP001**

STU NAME: Avon Lake Utilities Dept WTP STU ID: 4755816

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
INORGANICS	Antimony, total Arsenic, total Barium, total Beryllium, total Cadmium, total Chromium, total Cyanide, total Fluoride, total Mercury, total Nickel, total Selenium, total Thallium, total	1 Sample between Jul 1 and Dec 31
NITRATE		1 Sample Monthly
NITRITE		1 Sample between Jul 1 and Dec 31
ORGANIC CARBON		1 Paired Sample Set Monthly*
BROMATE		Not Required
CHLORINE DIOXIDE		Not Required
CHLORITE		Not Required
VOLATILE ORGANIC CHEMICALS (VOC's)		1 Sample between Jul 1 and Dec 31
SYNTHETIC ORGANIC CHEMICALS (SOC's)	Alachlor Atrazine Simazine	1 Sample between May 1 and Jul 31
RADIOLOGICALS	Alpha, total Radium-228	Not Required

\* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

## 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 4700311 PWS Name: Avon Lake, City Of  
Community Surface Water POPULATION: 21333  
Effective Date: 1/1/04

### THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
-----------	------	--------------------

Asbestos	1 sample between Apr 1 and Jun 30	
Total Chlorine	Sample in the distribution system *	
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Chlorite	Not Required	

### Disinfectants and Disinfection Byproducts Sampling Information

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

### Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**REVISED 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**

PWS ID: 4700203 PWS Name: City of Avon PWS

Community Purchased Surface Water POPULATION: 12000

Effective Date: 3/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
------------------	-------------	---------------------------

Asbestos	1 sample between Oct 1 and Dec 31	
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**2004 CHEMICAL MONITORING ENTRY POINT SCHEDULE**

PWS NAME: Crystal Springs RV Campground PWS PWS TYPE: Community Ground Water

PWS ID: 4731012 **Sample Monitoring Point: EP001**

STU NAME: Crystal Springs Club Store STU ID: 4755829

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
INORGANICS	Antimony, total Arsenic, total Barium, total Beryllium, total Cadmium, total Chromium, total Cyanide, total Fluoride, total Mercury, total Nickel, total Selenium, total Thallium, total	1 Sample between Jul 1 and Dec 31
NITRATE		1 Sample between Jul 1 and Dec 31
NITRITE		1 Sample between Jul 1 and Dec 31
RADIOLOGICALS	Alpha, total Radium-228	1 Sample quarterly Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec 1 Sample quarterly Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec
BROMATE		Not Required
CHLORINE DIOXIDE		Not Required
CHLORITE		Not Required
VOLATILE ORGANIC CHEMICALS (VOC's)		1 Sample quarterly Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec
SYNTHETIC ORGANIC CHEMICALS (SOC's)	Alachlor Atrazine Simazine	1 Sample between Jul 1 and Sep 30

\* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

**2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**  
PWS ID: 4731012 PWS Name: Crystal Springs RV Campground PWS  
Community Ground Water POPULATION: 215  
Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
Total Chlorine	Sample in the distribution system *	
Haloacetic Acids (five) (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Asbestos	Not Required	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**2004 CHEMICAL MONITORING ENTRY POINT SCHEDULE**

PWS NAME: Elyria Water Department PWS TYPE: Community Surface Water

PWS ID: 4700411 **Sample Monitoring Point: EP001**

STU NAME: Elyria Water Department STU ID: 4755817

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
INORGANICS	Antimony, total Arsenic, total Barium, total Beryllium, total Cadmium, total Chromium, total Cyanide, total Fluoride, total Mercury, total Nickel, total Selenium, total Thallium, total	1 Sample between Jul 1 and Dec 31
NITRATE		1 Sample Monthly
NITRITE		1 Sample between Jul 1 and Dec 31
ORGANIC CARBON		1 Paired Sample Set Monthly*
BROMATE		Not Required
CHLORINE DIOXIDE		Not Required
CHLORITE		Not Required
VOLATILE ORGANIC CHEMICALS (VOC's)		1 Sample between Jul 1 and Dec 31
SYNTHETIC ORGANIC CHEMICALS (SOC's)	Alachlor Atrazine Simazine	1 Sample between May 1 and Jul 31
RADIOLOGICALS	Alpha, total Radium-228	Not Required

\* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

## 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 4700411 PWS Name: Elyria Water Department

Community Surface Water POPULATION: 68000

Effective Date: 1/1/04

### THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
-----------	------	--------------------

Total Chlorine	Sample in the distribution system *	
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Asbestos	Not Required	
Chlorite	Not Required	

#### Disinfectants and Disinfection Byproducts Sampling Information

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

#### Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**  
PWS ID: 4700511 PWS Name: Grafton, Village Of  
Community Purchased Surface Water POPULATION: 2200  
Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
------------------	-------------	---------------------------

Haloacetic Acids (five) (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Asbestos	Not Required	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**  
PWS ID: 4700603 PWS Name: Lagrange, Village Of  
Community Purchased Surface Water POPULATION: 1900  
Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
-----------	------	--------------------

Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Asbestos	Not Required	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**2004 CHEMICAL MONITORING ENTRY POINT SCHEDULE**

PWS NAME: Lorain, City Of PWS TYPE: Community Surface Water

PWS ID: 4700711 **Sample Monitoring Point: EP001**

STU NAME: Lorain WTP STU ID: 4755820

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
INORGANICS	Antimony, total Arsenic, total Barium, total Beryllium, total Cadmium, total Chromium, total Cyanide, total Fluoride, total Mercury, total Nickel, total Selenium, total Thallium, total	1 Sample between Jul 1 and Dec 31
NITRATE		1 Sample Monthly
NITRITE		1 Sample between Jul 1 and Dec 31
ORGANIC CARBON		1 Paired Sample Set Monthly*
BROMATE		Not Required
CHLORINE DIOXIDE		Not Required
CHLORITE		Not Required
VOLATILE ORGANIC CHEMICALS (VOC's)		1 Sample between Jul 1 and Dec 31
SYNTHETIC ORGANIC CHEMICALS (SOC's)	Alachlor Atrazine Simazine	1 Sample between May 1 and Jul 31
RADIOLOGICALS	Alpha, total Radium-228	Not Required

\* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

## 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 4700711 PWS Name: Lorain, City Of  
Community Surface Water POPULATION: 72000  
Effective Date: 1/1/04

### THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
-----------	------	--------------------

Total Chlorine	Sample in the distribution system *	
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Asbestos	Not Required	
Chlorite	Not Required	

#### Disinfectants and Disinfection Byproducts Sampling Information

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

#### Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

---

---

**2004 CHEMICAL MONITORING SCHEDULE**

Melody Grove PWS

PWS ID: 4737512 **Sample Monitoring Point: EP001**

STU NAME: Melody Grove STU ID: 4761458

Transient Noncommunity Ground Water

Effective Date: 1/1/04

---

---

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

**Chemicals**

**2004**

NITRATE	1 Sample between Jul 1 and Dec 31 Date Sample Taken: _____
NITRITE	1 Sample between Jul 1 and Dec 31 Date Sample Taken: _____

**NOTE: Check with your district office regarding your coliform monitoring requirements.**

**REVISED 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**

PWS ID: 4700803 PWS Name: North Ridgeville, City O

Community Purchased Surface Water POPULATION: 24000

Effective Date: 3/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
------------------	-------------	---------------------------

Asbestos	1 sample between Jul 1 and Sept 30	
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**2004 CHEMICAL MONITORING ENTRY POINT SCHEDULE**

PWS NAME: Oberlin Water Department PWS TYPE: Community Surface Water

PWS ID: 4700911 **Sample Monitoring Point: EP001**

STU NAME: Oberlin Water Department STU ID: 4755822

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
INORGANICS	Antimony, total Arsenic, total Barium, total Beryllium, total Cadmium, total Chromium, total Cyanide, total Fluoride, total Mercury, total Nickel, total Selenium, total Thallium, total	1 Sample between Jul 1 and Dec 31
NITRATE		1 Sample Monthly
NITRITE		1 Sample between Jul 1 and Dec 31
ORGANIC CARBON		1 Paired Sample Set Monthly*
BROMATE		Not Required
CHLORINE DIOXIDE		Not Required
CHLORITE		Not Required
VOLATILE ORGANIC CHEMICALS (VOC's)		1 Sample between Jul 1 and Dec 31
SYNTHETIC ORGANIC CHEMICALS (SOC's)	Alachlor Atrazine Simazine	1 Sample between May 1 and Jul 31
RADIOLOGICALS	Alpha, total Radium-228	Not Required

\* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

## 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 4700911 PWS Name: Oberlin Water Department

Community Surface Water POPULATION: 8600

Effective Date: 1/1/04

### THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
-----------	------	--------------------

Asbestos	1 sample between Apr 1 and Jun 30	
Total Chlorine	Sample in the distribution system *	
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Chlorite	Not Required	

### Disinfectants and Disinfection Byproducts Sampling Information

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

### Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

---

---

**2004 CHEMICAL MONITORING SCHEDULE**

Panther Trails Campground

PWS ID: 4736912 **Sample Monitoring Point: EP001**

STU NAME: Panther Trails Campground STU ID: 4755837

Transient Noncommunity Ground Water

Effective Date: 1/1/04

---

---

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

**Chemicals**

**2004**

NITRATE	1 Sample between Jul 1 and Dec 31 Date Sample Taken: _____
NITRITE	Not Required

**NOTE: Check with your district office regarding your coliform monitoring requirements.**

**2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**  
PWS ID: 4701912 PWS Name: Pheasant Run Association PWS  
Community Purchased Surface Water POPULATION: 1952  
Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Asbestos	Not Required	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.



**REVISED 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**

PWS ID: 4701103 PWS Name: Sheffield Lake City PWS  
Community Purchased Surface Water POPULATION: 9800  
Effective Date: 3/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
------------------	-------------	---------------------------

Asbestos	1 sample between Jul 1 and Sept 30	
Haloacetic Acids (five) (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**REVISED 2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**

PWS ID: 4701203 PWS Name: Sheffield, Village Of  
Community Purchased Surface Water POPULATION: 2900  
Effective Date: 3/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
------------------	-------------	---------------------------

Asbestos	1 sample between Jul 1 and Sept 30	
Haloacetic Acids (five) (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

**2004 CHEMICAL MONITORING ENTRY POINT SCHEDULE**

PWS NAME: South Amherst, Village O PWS TYPE: Community Surface Water

PWS ID: 4701411 **Sample Monitoring Point: EP001**

STU NAME: South Amherst Village STU ID: 4755825

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
INORGANICS	Antimony, total Arsenic, total Barium, total Beryllium, total Cadmium, total Chromium, total Cyanide, total Fluoride, total Mercury, total Nickel, total Selenium, total Thallium, total	1 Sample between Jul 1 and Dec 31
NITRATE		1 Sample Monthly
NITRITE		1 Sample between Jul 1 and Dec 31
ORGANIC CARBON		1 Paired Sample Set Monthly*
BROMATE		Not Required
CHLORINE DIOXIDE		Not Required
CHLORITE		Not Required
VOLATILE ORGANIC CHEMICALS (VOC's)		1 Sample between Jul 1 and Dec 31
SYNTHETIC ORGANIC CHEMICALS (SOC's)	Alachlor Atrazine Simazine	1 Sample between May 1 and Jul 31
RADIOLOGICALS	Alpha, total Radium-228	Not Required

\* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

**2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**

PWS ID: 4701411 PWS Name: South Amherst, Village O

Community Surface Water POPULATION: 1850

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
Asbestos	1 sample between Apr 1 and Jun 30	
Total Chlorine	Sample in the distribution system *	
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

---

---

**2004 CHEMICAL MONITORING SCHEDULE**

Springs of Life Church

PWS ID: 4730912 **Sample Monitoring Point: EP001**

STU NAME: Springs of Life Church STU ID: 4755828

Transient Noncommunity Ground Water

Effective Date: 1/1/04

---

---

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

**Chemicals**

**2004**

NITRATE	1 Sample between Jul 1 and Dec 31 Date Sample Taken: _____
NITRITE	Not Required

**NOTE: Check with your district office regarding your coliform monitoring requirements.**

**2004 CHEMICAL MONITORING ENTRY POINT SCHEDULE**

PWS NAME: Wellington, Village Of PWS TYPE: Community Surface Water

PWS ID: 4701511 **Sample Monitoring Point: EP001**

STU NAME: Wellington WTP STU ID: 4755826

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact Northeast District Office at (330) 963-1200 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule.

Chemicals	2004	Date Samples Taken
INORGANICS	Antimony, total Arsenic, total Barium, total Beryllium, total Cadmium, total Chromium, total Cyanide, total Fluoride, total Mercury, total Nickel, total Selenium, total Thallium, total	1 Sample between Jul 1 and Dec 31
NITRATE		1 Sample Monthly
NITRITE		1 Sample between Jul 1 and Dec 31
ORGANIC CARBON		1 Paired Sample Set Monthly*
BROMATE		Not Required
CHLORINE DIOXIDE		Not Required
CHLORITE		Not Required
VOLATILE ORGANIC CHEMICALS (VOC's)		1 Sample between Jul 1 and Dec 31
SYNTHETIC ORGANIC CHEMICALS (SOC's)	Alachlor Atrazine Simazine	1 Sample between May 1 and Jul 31
RADIOLOGICALS	Alpha, total Radium-228	Not Required

\* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

**2004 CHEMICAL MONITORING DISTRIBUTION SCHEDULE**

PWS ID: 4701511 PWS Name: Wellington, Village Of

Community Surface Water POPULATION: 4600

Effective Date: 1/1/04

**THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.**

Contact your district representative at Northeast District Office at (330) 963-1200 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule.

<b>Chemicals</b>	<b>2004</b>	<b>Date Samples Taken</b>
Asbestos	1 sample between Apr 1 and Jun 30	
Total Chlorine	Sample in the distribution system *	
Haloacetic Acids (five) (HAA5)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Total Trihalomethanes (TTHM)	1 Sample each quarter (Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec)	
Chlorite	Not Required	

**Disinfectants and Disinfection Byproducts Sampling Information**

Guidance on monitoring for the Disinfectants and Disinfection Byproducts rule and how to identify sampling locations and use of the Sample Monitoring Point Identifiers (SMPIDs) can be found in the "Ohio EPA Sample Monitoring Plan Template for Disinfectants and Disinfection Byproducts". An electronic version of the template is located at <http://www.epa.state.oh.us/ddagw/Documents/new-ddbp-smp3.PDF>. A copy of this document is also available from your local Ohio EPA District Office. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Richard Ciotola of the Ohio EPA DDAGW Central Office at (614) 644-3387 or [richard.ciotola@epa.state.oh.us](mailto:richard.ciotola@epa.state.oh.us). Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

\* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

\*\* One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

**Asbestos Sampling Information**

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.