

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Airmate Inc PWS TYPE: Nontransient Noncommunity Ground Water

PWS ID: 8633312 **Sample Monitoring Point: EP001**

STU NAME: Airmate Inc STU ID: 8659848

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<p>ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.</p>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8633312 PWS Name: Airmate Inc

Nontransient Noncommunity Ground Water POPULATION: 36

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Monitoring Schedule

Triennial		
Sampling Period		Report is due to your district office no later than
Start	End	
06/01/2006	09/30/2006	10/10/06

System size (number of people served)	Number of sites (reduced monitoring)
------------------------------------------	-----------------------------------------

> 100,000	50
10,001 to 100,000	30
3,301 to 10,000	20
501 to 3,300	10
101 to 500	5
< 101	5

The dates and number of samples noted above supercede any previous schedule received from this agency. Copies of EPA Forms 5105, 5106, and 5107 are available on our web site at <http://www.epa.state.oh.us/ddagw/drinkforms.htm> or your district office to use for your next report. If your Lead and Copper monitoring does exceed an action level or if you have any other questions, please contact your district representative at Northwest District Office at (419) 352-8461

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Anderson Vreeland PWS TYPE: Nontransient Noncommunity Ground Water

PWS ID: 8633612 **Sample Monitoring Point: EP001**

STU NAME: Anderson and Vreeland Midwest Inc STU ID: 8659851

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	1 Sample between Oct 1 and Dec 31	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #cccccc; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

REVISED 2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8633612 PWS Name: Anderson Vreeland

Nontransient Noncommunity Ground Water POPULATION: 77

Effective Date: 8/31/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Bethlehem Christian Union Church

PWS ID: 8633812 **Sample Monitoring Point: EP001**

STU NAME: Bethlehem Christian Union Church STU ID: 8659853

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

Chemicals (Code)	Monitoring Requirements
NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Bridgewater Community Church PWS

PWS ID: 8634112 **Sample Monitoring Point: EP001**

STU NAME: Bridgewater Community Church STU ID: 8659855

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Bryan Fuel Stop PWS

PWS ID: 8639812 **Sample Monitoring Point: EP001**

STU NAME: Bryan Fuel Stop STU ID: 8659886

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Bryan Municipal Light & Water Utilities PWS TYPE: Community Ground Water

PWS ID: 8600012 **Sample Monitoring Point: EP001**

STU NAME: Bryan Municipal Light & Water Utilities STU ID: 8659808

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #cccccc; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8600012 PWS Name: Bryan Municipal Light & Water Utilities

Community Ground Water POPULATION: 8550

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Haloacetic Acids, five (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite (1009)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Burger King -Edon, OH PWS

PWS ID: 8640912 **Sample Monitoring Point: EP001**

STU NAME: Burger King Edon Oh STU ID: 8659897

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Camp Dicclair

PWS ID: 8634512 **Sample Monitoring Point: EP001**

STU NAME: Camp Dicclair STU ID: 8659856

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Cocca Building PWS

PWS ID: 8631412 **Sample Monitoring Point: EP001**

STU NAME: Dollar General STU ID: 8659835

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

D & L Town and Country PWS

PWS ID: 8633512 **Sample Monitoring Point: EP001**

STU NAME: D & L Town and Country STU ID: 8659850

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Edgerton Alliance Church

PWS ID: 8633412 **Sample Monitoring Point: EP001**

STU NAME: Edgerton Alliance Church STU ID: 8659849

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Edgerton Village PWS PWS TYPE: Community Ground Water

PWS ID: 8600312 **Sample Monitoring Point: EP001**

STU NAME: Edgerton WTP STU ID: 8659810

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
-------------------	----------------------	-------------------------	-------------

CONSUMER CONFIDENCE REPORT (CCR)	CCR due by July 1, 2006		
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #cccccc; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8600312 PWS Name: Edgerton Village PWS

Community Ground Water POPULATION: 2117

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Haloacetic Acids, five (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite (1009)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Edon Farmers Co-Op

PWS ID: 8633012 **Sample Monitoring Point: EP001**

STU NAME: Edon Farmers Co-Op STU ID: 8659845

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Edon Village PWS PWS TYPE: Community Ground Water

PWS ID: 8600512 **Sample Monitoring Point: EP001**

STU NAME: Edon Village WTP 1 STU ID: 8659812

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #cccccc; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8600512 PWS Name: Edon Village PWS

Community Ground Water POPULATION: 980

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Haloacetic Acids, five (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite (1009)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Hillcrest Country Club

PWS ID: 8640412 **Sample Monitoring Point: EP001**

STU NAME: Hillcrest Country Club STU ID: 8659892

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Kunkle Farms AMLC

PWS ID: 8630312 **Sample Monitoring Point: EP001**

STU NAME: Kunkle Farms ALMC STU ID: 8659828

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Kunkle United Baptist In Christ Church PWS

PWS ID: 8640812 **Sample Monitoring Point: EP001**

STU NAME: Kunkle UB In Christ Church STU ID: 8659896

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Lazy River Camp

PWS ID: 8636212 **Sample Monitoring Point: EP001**

STU NAME: Lazy River Camp STU ID: 8659862

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Living Word School PWS TYPE: Nontransient Noncommunity Ground Water

PWS ID: 8640712 **Sample Monitoring Point: EP001**

STU NAME: Living Word School STU ID: 8659895

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8640712 PWS Name: Living Word School

Nontransient Noncommunity Ground Water POPULATION: 104

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Lockport Mennonite Church

PWS ID: 8636312 **Sample Monitoring Point: EP001**

STU NAME: Lockport Mennonite Church STU ID: 8659863

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Loveberrys Funny Farm Campground

PWS ID: 8635512 **Sample Monitoring Point: EP001**

STU NAME: Funny Farm Campground STU 1 STU ID: 8659860

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Loveberrys Funny Farm Campground

PWS ID: 8635512 **Sample Monitoring Point: EP002**

STU NAME: Funny Farm Campground STU 2 STU ID: 8660634

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

M&D Suburban Inn

PWS ID: 8638012 **Sample Monitoring Point: EP001**

STU NAME: M & D Suburban Inn STU ID: 8659875

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Manufactured Housing Enterprises Inc PWS TYPE: Nontransient Noncommunity Ground Water

PWS ID: 8636412 **Sample Monitoring Point: EP001**

STU NAME: Manufactured Housing Enterprise STU 1 * STU ID: 8659864

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8636412 PWS Name: Manufactured Housing Enterprises Inc

Nontransient Noncommunity Ground Water POPULATION: 190

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Monitoring Schedule

Triennial		
Sampling Period		Report is due to your district office no later than
Start	End	
06/01/2006	09/30/2006	10/10/06

System size (number of people served)	Number of sites (reduced monitoring)
------------------------------------------	-----------------------------------------

> 100,000	50
10,001 to 100,000	30
3,301 to 10,000	20
501 to 3,300	10
101 to 500	5
< 101	5

The dates and number of samples noted above supercede any previous schedule received from this agency. Copies of EPA Forms 5105, 5106, and 5107 are available on our web site at <http://www.epa.state.oh.us/ddagw/drinkforms.htm> or your district office to use for your next report. If your Lead and Copper monitoring does exceed an action level or if you have any other questions, please contact your district representative at Northwest District Office at (419) 352-8461

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Montpelier Village PWS PWS TYPE: Community Ground Water

PWS ID: 8600912 **Sample Monitoring Point: EP001**

STU NAME: Montpelier WTP No 1 STU ID: 8659815

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	1 Sample between Jan 1 and Mar 31	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #e0e0e0; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8600912 PWS Name: Montpelier Village PWS

Community Ground Water POPULATION: 4320

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Haloacetic Acids, five (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite (1009)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Nettle Lake UB Church

PWS ID: 8638312 **Sample Monitoring Point: EP001**

STU NAME: Nettle Lake UB Church STU ID: 8659876

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

New Hope Community Church PWS

PWS ID: 8641512 **Sample Monitoring Point: EP001**

STU NAME: New Hope Community Church STU ID: 8660988

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

New Life Temple

PWS ID: 8636812 **Sample Monitoring Point: EP001**

STU NAME: New Life Temple STU ID: 8659866

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Norlick Place Utilities PWS TYPE: Community Ground Water

PWS ID: 8601012 **Sample Monitoring Point: EP001**

STU NAME: Norlick Place Utilities STU ID: 8659816

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #e0e0e0; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8601012 PWS Name: Norlick Place Utilities

Community Ground Water POPULATION: 345

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Monitoring Schedule

Triennial		
Sampling Period		Report is due to your district office no later than
Start	End	
06/01/2006	09/30/2006	10/10/06

System size (number of people served)	Number of sites (reduced monitoring)
------------------------------------------	-----------------------------------------

> 100,000	50
10,001 to 100,000	30
3,301 to 10,000	20
501 to 3,300	10
101 to 500	5
< 101	5

The dates and number of samples noted above supercede any previous schedule received from this agency. Copies of EPA Forms 5105, 5106, and 5107 are available on our web site at <http://www.epa.state.oh.us/ddagw/drinkforms.htm> or your district office to use for your next report. If your Lead and Copper monitoring does exceed an action level or if you have any other questions, please contact your district representative at Northwest District Office at (419) 352-8461

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: North Pine Estates PWS TYPE: Community Ground Water

PWS ID: 8600812 **Sample Monitoring Point: EP001**

STU NAME: North Pine Estates STU ID: 8659814

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #e0e0e0; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8600812 PWS Name: North Pine Estates

Community Ground Water POPULATION: 70

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Haloacetic Acids, five (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite (1009)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Northland Park MHP PWS PWS TYPE: Community Ground Water

PWS ID: 8601112 **Sample Monitoring Point: EP001**

STU NAME: Northland Park MHP STU ID: 8659817

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #e0e0e0; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8601112 PWS Name: Northland Park MHP PWS

Community Ground Water POPULATION: 50

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Haloacetic Acids, five (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite (1009)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Monitoring Schedule

Triennial		
Sampling Period		Report is due to your district office no later than
Start	End	
06/01/2006	09/30/2006	10/10/06

System size (number of people served)	Number of sites (reduced monitoring)
------------------------------------------	-----------------------------------------

> 100,000	50
10,001 to 100,000	30
3,301 to 10,000	20
501 to 3,300	10
101 to 500	5
< 101	5

The dates and number of samples noted above supercede any previous schedule received from this agency. Copies of EPA Forms 5105, 5106, and 5107 are available on our web site at <http://www.epa.state.oh.us/ddagw/drinkforms.htm> or your district office to use for your next report. If your Lead and Copper monitoring does exceed an action level or if you have any other questions, please contact your district representative at Northwest District Office at (419) 352-8461

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: OTC-Kunkle Maintenance Building PWS PWS TYPE: Nontransient Noncommunity Ground Water

PWS ID: 8640112 **Sample Monitoring Point: EP001**

STU NAME: Ohio Turnpike Commission - Kunkle Maintance Bldg. STU ID: 8659889

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8640112 PWS Name: OTC-Kunkle Maintenance Building PWS

Nontransient Noncommunity Ground Water POPULATION: 32

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Oakwood MHP PWS TYPE: Community Ground Water

PWS ID: 8601212 **Sample Monitoring Point: EP001**

STU NAME: Oakwood MHP STU 1 * STU ID: 8659818

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Oakwood MHP PWS TYPE: Community Ground Water

PWS ID: 8601212 **Sample Monitoring Point: EP002**

STU NAME: Oakwood MHP STU 2 * STU ID: 8660632

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	

ATTENTION:
Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8601212 PWS Name: Oakwood MHP
Community Ground Water POPULATION: 180
Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Orchard Hills Country Club

PWS ID: 8636712 **Sample Monitoring Point: EP001**

STU NAME: Orchard Hills Country Club STU ID: 8659865

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Pine Grove Mennonite Church

PWS ID: 8636912 **Sample Monitoring Point: EP001**

STU NAME: Pine Grove Mennonite Church STU ID: 8659867

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Pioneer Scout Reserve-Camp PWS

PWS ID: 8633912 **Sample Monitoring Point: EP001**

STU NAME: Pioneer Scout Res - Camp * STU ID: 8659854

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Pioneer Scout Reserve-Pool PWS

PWS ID: 8637012 **Sample Monitoring Point: EP001**

STU NAME: Pioneer Scout Res - Pool * STU ID: 8659868

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Pioneer Village PWS PWS TYPE: Community Ground Water

PWS ID: 8601312 **Sample Monitoring Point: EP001**

STU NAME: Pioneer Village of STU ID: 8659819

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #cccccc; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8601312 PWS Name: Pioneer Village PWS

Community Ground Water POPULATION: 1300

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Haloacetic Acids, five (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite (1009)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Pulaski Head Start PWS PWS TYPE: Nontransient Noncommunity Ground Water

PWS ID: 8631912 **Sample Monitoring Point: EP001**

STU NAME: Pulaski Head Start STU ID: 8659837

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8631912 PWS Name: Pulaski Head Start PWS

Nontransient Noncommunity Ground Water POPULATION: 143

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Monitoring Schedule

Triennial		
Sampling Period		Report is due to your district office no later than
Start	End	
06/01/2006	09/30/2006	10/10/06

System size (number of people served)	Number of sites (reduced monitoring)
------------------------------------------	-----------------------------------------

> 100,000	50
10,001 to 100,000	30
3,301 to 10,000	20
501 to 3,300	10
101 to 500	5
< 101	5

The dates and number of samples noted above supercede any previous schedule received from this agency. Copies of EPA Forms 5105, 5106, and 5107 are available on our web site at <http://www.epa.state.oh.us/ddagw/drinkforms.htm> or your district office to use for your next report. If your Lead and Copper monitoring does exceed an action level or if you have any other questions, please contact your district representative at Northwest District Office at (419) 352-8461

2006 CHEMICAL MONITORING SCHEDULE

Pulaski United Methodist Church PWS

PWS ID: 8637312 **Sample Monitoring Point: EP001**

STU NAME: Pulaski United Methodist Church STU ID: 8659870

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

River of Life Worship Center PWS

PWS ID: 8639512 **Sample Monitoring Point: EP001**

STU NAME: River of Life Worship Ctr STU ID: 8659883

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Riverside Greens

PWS ID: 8637512 **Sample Monitoring Point: EP001**

STU NAME: Riverside Greens STU ID: 8659871

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Sams Place

PWS ID: 8632312 **Sample Monitoring Point: EP001**

STU NAME: Sams Place STU ID: 8659841

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

REVISED 2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE
PWS NAME: Seneca Utilities, Inc. PWS TYPE: Community Ground Water
PWS ID: 8601512 **Sample Monitoring Point: EP001**
STU NAME: Seneca Utilities Inc STU ID: 8659820
Effective Date: 3/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	1 Sample quarterly Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8601512 PWS Name: Seneca Utilities, Inc.

Community Ground Water POPULATION: 750

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Monitoring Schedule

Triennial		
Sampling Period		Report is due to your district office no later than
Start	End	
06/01/2006	09/30/2006	10/10/06

System size (number of people served)	Number of sites (reduced monitoring)
------------------------------------------	-----------------------------------------

> 100,000	50
10,001 to 100,000	30
3,301 to 10,000	20
501 to 3,300	10
101 to 500	5
< 101	5

The dates and number of samples noted above supercede any previous schedule received from this agency. Copies of EPA Forms 5105, 5106, and 5107 are available on our web site at <http://www.epa.state.oh.us/ddagw/drinkforms.htm> or your district office to use for your next report. If your Lead and Copper monitoring does exceed an action level or if you have any other questions, please contact your district representative at Northwest District Office at (419) 352-8461

2006 CHEMICAL MONITORING SCHEDULE

Shady Shore Campground

PWS ID: 8637712 **Sample Monitoring Point: EP001**

STU NAME: Shady Shore Campground STU ID: 8659872

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Silver Creek Church

PWS ID: 8637812 **Sample Monitoring Point: EP001**

STU NAME: Silver Creek Church STU ID: 8659873

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: St Josephs School PWS PWS TYPE: Nontransient Noncommunity Ground Water

PWS ID: 8632412 **Sample Monitoring Point: EP001**

STU NAME: Saint Joseph School STU ID: 8659842

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8632412 PWS Name: St Josephs School PWS
Nontransient Noncommunity Ground Water POPULATION: 64
Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Stryker Village PWS PWS TYPE: Community Ground Water

PWS ID: 8601712 **Sample Monitoring Point: EP001**

STU NAME: Stryker Village STU 1 STU ID: 8659822

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #e0e0e0; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Stryker Village PWS PWS TYPE: Community Ground Water

PWS ID: 8601712 **Sample Monitoring Point: EP002**

STU NAME: Stryker Village STU 2 STU ID: 8660633

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #cccccc; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8601712 PWS Name: Stryker Village PWS

Community Ground Water POPULATION: 1418

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Stuckey AMLC

PWS ID: 8639612 **Sample Monitoring Point: EP001**

STU NAME: Stuckey ALMC STU ID: 8659884

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Suburban Golf, Inc.

PWS ID: 8637912 **Sample Monitoring Point: EP001**

STU NAME: Suburban Golf Inc STU ID: 8659874

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

Victory Barn Church

PWS ID: 8640612 **Sample Monitoring Point: EP001**

STU NAME: Victory Barn Church STU ID: 8659894

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING SCHEDULE

West Bethesda Presbyterian Church

PWS ID: 8638512 **Sample Monitoring Point: EP001**

STU NAME: West Bethesda Church STU ID: 8659877

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: West Unity Village PWS PWS TYPE: Community Ground Water

PWS ID: 8601812 **Sample Monitoring Point: EP001**

STU NAME: West Unity WTP STU ID: 8659823

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #cccccc; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8601812 PWS Name: West Unity Village PWS

Community Ground Water POPULATION: 1725

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Haloacetic Acids, five (HAA5)	1 Sample between Jul 1 and Sept 30	
Total Trihalomethanes (TTHM)	1 Sample between Jul 1 and Sept 30	
Chlorite (1009)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Williams County Garage PWS TYPE: Nontransient Noncommunity Ground Water

PWS ID: 8634812 **Sample Monitoring Point: EP001**

STU NAME: Williams County Garage STU ID: 8659858

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	1 Sample between Oct 1 and Dec 31	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully.			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8634812 PWS Name: Williams County Garage
Nontransient Noncommunity Ground Water POPULATION: 38
Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.

2006 CHEMICAL MONITORING SCHEDULE

Windwood Hollow Golf Course

PWS ID: 8633112 **Sample Monitoring Point: EP001**

STU NAME: Windwood Hollow Golf Course STU ID: 8659846

Transient Noncommunity Ground Water

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample between Jun 1 and Oct 31 Sample Date: _____
NITRITE (1041)	Not Required

**Attention: Some monitoring periods have been reduced from 6 months to 5 months.
Please review the monitoring requirements carefully.**

2006 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS NAME: Wms Co/Hillside Country PWS TYPE: Community Ground Water

PWS ID: 8601912 **Sample Monitoring Point: EP001**

STU NAME: Williams County - Hillside Country Living * STU ID: 8659824

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office at (419) 352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals/Reports	Chemical Name (Code)	Monitoring Requirements	Sample Date
CONSUMER CONFIDENCE REPORT (CCR)		CCR due by July 1, 2006	
INORGANICS	Inorganics	Not Required	
ARSENIC	Arsenic, total (1005)	Not Required	
NITRATE	Nitrate (1040)	1 Sample between Jun 1 and Oct 31	
NITRITE	Nitrite (1041)	Not Required	
RADIOLOGICALS	Alpha, total (4000) Radium-228 (4030)	Not Required	
BROMATE	Bromate (1011)	Not Required	
CHLORINE DIOXIDE	Chlorine dioxide (1008)	Not Required	
CHLORITE	Chlorite (1009)	Not Required	
VOLATILE ORGANIC CHEMICALS (VOCs)	VOCs	Not Required	
SYNTHETIC ORGANIC CHEMICALS (SOCs)	SOCs	Not Required	
<div style="border: 1px solid black; background-color: #cccccc; padding: 5px; display: inline-block;"> ATTENTION: Some monitoring periods have been reduced from 6 months to 5 months. Please review the monitoring requirements carefully. </div>			

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2006 CHEMICAL MONITORING DISTRIBUTION SCHEDULE

PWS ID: 8601912 PWS Name: Wms Co/Hillside Country

Community Ground Water POPULATION: 91

Effective Date: 1/1/06

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district representative at Northwest District Office at (419) 352-8461 to review additional monitoring for total coliform, minimum requirements for chemical analysis for your monthly operating reports, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)	Monitoring Requirements	Sample Date
Total Chlorine (1000)	Sample in the distribution system *	
Chlorite (1009)	Not Required	
Haloacetic Acids, five (HAA5)	Not Required	
Total Trihalomethanes (TTHM)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use the MR00# as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use the appropriate RD00# as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Todd Kelleher of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Lead and Copper Tap Schedule

Routine Lead and Copper Tap Monitoring Not Required

If a lead or copper action level has been exceeded, additional sampling may be required.