

Application No. OH0007072

Issue Date: January 31, 2008

Effective Date: March 1, 2008

Expiration Date: February 28, 2013

Ohio Environmental Protection Agency
Authorization to Discharge Under the
National Pollutant Discharge Elimination System

In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et. seq., hereinafter referred to as the "Act"), and the Ohio Water Pollution Control Act (Ohio Revised Code Section 6111),

Sypris Technologies Inc

is authorized by the Ohio Environmental Protection Agency, hereinafter referred to as "Ohio EPA," to discharge from Sypris Technologies Kenton Inc. wastewater treatment works located at 13267 State Route 68 S, Kenton, Ohio, Hardin County and discharging to Taylor Creek in accordance with the conditions specified in Parts I, II, III, IV, V and VI of this permit.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code.

This permit and the authorization to discharge shall expire at midnight on the expiration date shown above. In order to receive authorization to discharge beyond the above date of expiration, the permittee shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.

Laura H. Powell
Assistant Director

Total Pages: 28

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from outfall 2IS00000001. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 001 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00400 - pH - S.U.	9.0	6.5	-	-	-	-	-	1/Month	Grab	All
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Composite	All
00552 - Oil and Grease, Hexane Extr Method - mg/l	10.0	-	-	-	-	-	-	1/Month	Grab	All
00980 - Iron, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	Composite	All
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	Composite	All
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	24hr Total Estimate	All

Notes for Station Number 2IS00000001:

Sampling shall be performed when discharging. If NO DISCHARGE OCCURS DURING THE ENTIRE MONTH, report "AL" in the first column of the first day of the month on the 4500 Form (Monthly Operating Report). A signature is still required.

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of the permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from outfall 2IS00000002. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 002 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00400 - pH - S.U.	9.0	6.5	-	-	-	-	-	1/Month	Grab	All
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Month	Composite	All
00552 - Oil and Grease, Hexane Extr Method - mg/l	10.0	-	-	-	-	-	-	1/Month	Grab	All
00980 - Iron, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	Composite	All
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	Composite	All
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	24hr Total Estimate	All

Notes for Station Number 2IS00000002:

Sampling shall be performed when discharging. If NO DISCHARGE OCCURS DURING THE ENTIRE MONTH, report "AL" in the first column of the first day of the month on the 4500 Form (Monthly Operating Report). A signature is still required.

Part II, OTHER REQUIREMENTS

A. Description of the location of the required sampling stations are as follows:

Sampling Station	Description of Location
2IS00000001	Storm water discharge from 18" tile to Taylor Creek (Lat: 40 N 37 ' 52 " ; Long: 83 W 37 ' 2 ")
2IS00000002	Storm water discharge from 48" tile to Taylor Creek (Lat: 40 N 37 ' 54 " ; Long: 83 W 37 ' 5 ")

B. This permit shall be modified, or alternatively, revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act, if the effluent standard or limitation so issued or approved.

1. Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
2. Controls any pollutant not limited in the permit.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Act then applicable.

C. All parameters, except flow, need not be monitored on days when the plant is not normally staffed (Saturdays, Sundays, and Holidays). On those days, report "AN" on the monthly report form.

D. Composite samples shall be comprised of at least three grab samples proportionate in volume to the sewage flow rate at the time of sampling and collected at intervals of at least 30 minutes, but not more than 2 hours, during the period that the plant is staffed on each day for sampling. Such samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance.

E. Grab samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's performance.

F. Outfall Signage

Not later than 4 months from the effective date of this permit, the permittee shall post a permanent marker on the Taylor Creek stream bank at each outfall that is regulated under this NPDES permit where a marker does not currently exist. This includes final outfalls, bypasses, and combined sewer overflows. The marker shall consist at a minimum of the name of the establishment to which the permit was issued, the Ohio EPA permit number, and the outfall number and a contact telephone number. The information shall be printed in letters not less than two inches in height. The marker shall be a minimum of 2 feet by 2 feet and shall be a minimum of 3 feet above ground level. The sign shall not be obstructed such that persons in boats or persons swimming in the river or someone fishing or walking along the shore cannot read the sign. Vegetation shall be periodically removed to keep the sign visible. If the outfall is normally submerged the sign shall indicate that. If the outfall is a combined sewer outfall, the sign shall indicate that untreated human sewage may be discharged from the outfall during wet weather and that harmful bacteria may be present in the water. When an existing marker is replaced or reset, the new marker shall comply with the requirements of this section.

G. Monitoring Report Name Change

The name of the monitoring reports required for each effluent table contained in this permit has been changed from "Monthly Operating Report" (MOR) to "Discharge Monitoring Report" (DMR). The circumstances requiring the submittal of a DMR remain the same as those which were required for an MOR. Form 4500 must be used for DMR submittal.