

National Pollutant Discharge Elimination System (NPDES) Permit Program
FACT SHEET
Regarding NPDES Permit to Discharge to State Waters

Ohio Environmental Protection Agency
P.O. Box 1049
50 West Town St, Suite 700
Lazarus Government Center
Columbus, Ohio 43216-1049
(614) 644-2001

Public Notice No.: 10-10-006
Public Notice Date: October 4, 2010

Name and Address of Applicant:

Mayor and Council
Village of Milan
PO Box 1450
Milan, OH 44846

Name and Address of Facility
Where Discharge Occurs:

Village of Milan WWTP
Riley Road
Milan, OH 44846
Erie County

Receiving Water: Huron River

I. Location of Discharge

The above named applicant has applied for an NPDES permit, which will be issued by the Ohio Environmental Protection Agency, to discharge into the designated receiving water. A description and/or sketch of the location of the discharge is appended as Attachment I.

II. Description of Existing Discharge

A quantitative description of the existing discharge in terms of significant effluent parameters is appended as Attachment II.

III. Determinations

The Ohio Environmental Protection Agency has examined the application and has made the determination to issue the permit subject to certain effluent limitations and other mandatory conditions.

Derivation and calculation of specific effluent limitations are accomplished in accordance with standard engineering practices and applicable guidelines, standards and documents. Justification of specific characteristics is appended as Attachment III.

The other special conditions in the permit may include, but are not necessarily limited to: monitoring, recording, and reporting discharges, limiting discharges of oil, hazardous substances, collected solids, visible floating solids, foams, prevention and containment; and prohibiting bypass of treatment facilities. Persons wishing further information about the special conditions may contact the Ohio Environmental Protection Agency.

Permit requirements are based upon Section 6111.03(J) of the Ohio Revised Code and upon Chapter 3745-33 of the Ohio Administrative Code in order to achieve and maintain full compliance with national effluent limitations, standards of performance, toxic and pretreatment standards.

IV. Procedures for the Formulation of Final Determinations

The determination shall be issued as a final action unless the Director revises the draft after consideration of the record of a public meeting or written comments, or upon disapproval by the Administrator of the U.S. Environmental Protection Agency.

Within thirty days of the date of the public notice, any person may request or petition for a public meeting for presentation of evidence, statements or opinions. The purpose of the public meeting or hearing is to obtain additional evidence. Statements concerning the issues raised by the party requesting the hearing are invited. Evidence may be presented by the applicant, the state, and other parties, and following presentation of such evidence other interested persons may present testimony of facts or statements of opinion.

Requests for public meeting should be addressed to:

Legal Records Section
Ohio Environmental Protection Agency
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, Ohio 43216-1049

Interested persons are invited to submit written comments upon the discharge permit. Comments should be submitted in person or by mail no later than 30 days after the date of this public notice. Deliver or mail all comments to:

Ohio Environmental Protection Agency
Division of Surface Water
Permits Processing Unit
50 West Town Street, Suite 700
P. O. Box 1049
Columbus, Ohio 43216-1049

The Ohio EPA permit number and public notice numbers should appear next to the above address on the envelope and on each page of any submitted comments. All comments received no later than 30 days after the date of this public notice will be considered.

The application, fact sheets, permit including effluent limitations, special conditions, comments received, and other documents are available for inspection and may be copied at a cost of 5 cents per page at the Ohio Environmental Protection Agency at the address shown on page one of this public notice any time between the hours of 8 a.m. and 4:30 p.m., Monday through Friday. Copies of the public notice are available at no charge at the same address.

Pursuant to Revised Code 3745.07, Ohio EPA maintains a mailing list of persons or groups who annually subscribe for notifications of all proposed actions, issuances, denials, modifications, revocations, and renewals of permits, licenses, variances, verified complaints, and all hearings and public meetings to be conducted. Subscriptions to the WEEKLY REVIEW are available for an annual fee of \$70.00, by writing to the Legal Records Section at the address above.

Persons or groups may request to be included on a mailing list pertaining to specific applications, to receive notices, fact sheets, permits and related documents by writing the Surface Water Permits Processing Unit at the address above. Such requests must provide the following information: County of interest, entity of interest (please provide permit number, if known) and documents requested.

V. The receiving water is classified for Warm Water Habitat.

The following water quality standards and effluent standards and limitations were applied to the discharge: Ohio EPA Agency Policy (OEPA AP), Existing Permit (EP), Total Maximum Daily Load (TMDL), Ohio Water Quality Standards (WQS), Plant Design (PD)

The terms and conditions of the permit will comply with the requirements of Ohio Administrative Code Chapter 3745-33, and Ohio Revised Code Section 6111.03(J).

VI. Average Flows and Temperature, if significant

The discharge from this facility into waters of the state is as follows:

<u>Discharge Point</u>	<u>Average Monthly Flows (GPD)</u>
001 (Lat: 41W 18' 20"; Long: 82W 36' 08')	370,000

ATTACHMENT I

This facility is located in Erie County. The facility is located at Riley Road, Milan, OH 44846. The discharge from the facility enters the Huron River.

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 2PB00037001. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 001 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Day	Grab	All
00300 - Dissolved Oxygen - mg/l	-	5.0	-	-	-	-	-	1/Week	Grab	All
00400 - pH - S.U.	9.0	6.5	-	-	-	-	-	1/Week	Grab	All
00530 - Total Suspended Solids - mg/l	-	-	45.0	30.0	-	63.0	42.0	1/Week	Composite	All
00550 - Oil and Grease, Total - mg/l	10.0	-	-	-	-	-	-	1/6 Months	Grab	Semi-annual
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	-	-	-	-	-	1 / 2 Weeks	Composite	All
00665 - Phosphorus, Total (P) - mg/l	-	-	1.5	1.0	-	2.1	1.4	1/Month	Composite	All
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Year	Composite	Yearly
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Year	Composite	Yearly
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Year	Composite	Yearly
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Year	Composite	Yearly
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Year	Composite	Yearly
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	1/Month	Grab	Summer
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50060 - Chlorine, Total Residual - mg/l	0.038	-	-	-	-	-	-	1/Day	Grab	Summer
50092 - Mercury, Total (Low Level) - ng/l	1700	-	-	9.3	0.00239	-	0.000014	1/Quarter	Grab	Quarterly
80082 - CBOD 5 day - mg/l	-	-	40.0	25.0	-	56.0	35.0	1/Week	Composite	All

Notes for station 2PB00037001:

* Effluent loadings based on average design flow of 0.370 MGD.

** Mercury - See Part II, Items O, P, Q and R.

*** Composite Samples - See Schedule of Compliance - Part I, C and Part II, Item G.

ATTACHMENT III

JUSTIFICATION OF SPECIFIC CHARACTERISTICS

Final Table Outfall: 2PB00037001

<u>Characteristic</u>	<u>Justification</u>
Temperature	OEPA AP
Total Suspended Solids	EP, PD
Oil & Grease, Total	WQS
Ammonia Nitrogen	EP
Fecal Coliform	
Total Mercury (Low Level)	EP
CBOD ₅	EP, PD
pH	WQS
Chlorine Residual, Total	EP, WQS
Dissolved Oxygen	WQS, EP
Turbidity	
Total Cyanide	
Dissolved Hexavalent Chromium	
Total Recoverable Nickel	EP
Total Recoverable Zinc	EP
Total Recoverable Cadmium	EP
Total Recoverable Lead	EP
Total Recoverable Chromium	
Total Recoverable Copper	EP
Total Phosphorus	TMDL

Abbreviations: **ABS** (Antibacksliding); **AD** (Antidegradation); **AP** (Administrative Policy); **AT Report** (Advanced Treatment Report); **AWS** (Agricultural Water Supply); **BADCT** (Best Available Demonstrated Control Tech.); **BAT** (Best Available Technology); **BCC** (Bio-accumulative Chemical of Concern); **BCT** (Best Conventional Pollutant Control Technology); **BEJ** (Best Engineering Judgement, P.L. 95-217, Section 402(a)(1)); **BPJ** (Best Professional Judgment); **BPT** (Best Practicable Control Technology); **CWH** (Cold Water Habitat); **CWQR** (Comprehensive Water Quality Report); **EEC** (Existing Effluent Characteristics); **EEQ** (Existing Effluent Quality, OAC 3745-33-04(B)(3)); **EWH** (Exceptional Warmwater Habitat); **EP** (Existing Permit); **FEG** (Federal Effluent Guidelines); **IJC** (International Joint Commission, 1978 Great Lakes Water Quality Agreement); **IMZM** (Inside Mixing Zone); **IWS** (Industrial Water Supply); **LP** (Lagoon Policy); **LRW** (Limited Resource Water); **MO** (Monitor Only); **MWH** (Modified Warmwater Habitat); **NSPS** (New Source Performance Standards); **OEPA AP** (Ohio EPA Agency Policy); **ORC** (ORSANCO); **PCR** (Primary Contact Recreation); **PD** (Plant Design); **PDL** (Prohibited Discharge Limitation); **PLER** (Permit Limitation Evaluation Report); **RPA** (Reasonable Potential Analysis); **SCR** (Secondary Contact Recreation); **SDP** (Small Discharges Policy); **SEC** (Secondary Treatment); **SEC FEG** (Secondary Federal Effluent Guidelines); **SLP** (State Lakes Policy); **SWR** (State Resource Water); **SS** (Secondary Standards); **TMDL** (Total Maximum Daily Load); **WET** (Whole Effluent Toxicity); **WLA** (Waste Load Allocation); **WQBEL** (Water Quality Based Effluent Limits Report); **WQS** (Ohio Water Quality Standards); **WWH** (Warmwater Habitat).

ATTACHMENT IV

GENERAL MERCURY VARIANCE COVERAGE

The permittee has applied for coverage under the general mercury variance, Rule 3745-33-07(D)(10) of the Ohio Administrative Code (OAC). Based on the results of low-level mercury monitoring, the permittee has determined that its wastewater treatment plant cannot meet the monthly average water quality based effluent limit (WQBEL) of 1.3 nanograms per liter (ng/l). However, the permittee believes that the plant will be able to achieve an annual average mercury effluent concentration of 12 ng/l. The variance application also demonstrated to the satisfaction of Ohio EPA that there is no readily apparent means of complying with the WQBEL without constructing prohibitively expensive end-of-pipe controls for mercury. Based on these factors, the permittee is eligible for coverage under the general mercury variance.

Ohio EPA has reviewed the mercury variance application and determined that it meets the requirements of the Ohio Administrative Code. As a result, Ohio EPA proposes to issue the variance as a special condition in Part II of the NPDES permit. The following variance provisions have been included in the draft permit:

- A variance-based monthly average effluent limit of 9.3 ng/l, which was developed from sampling data submitted by the permittee;
- A requirement that the permittee make reasonable progress to meet the water-quality-based effluent limit for mercury by implementing the plan of study, which has been developed as part of the Pollutant Minimization Program (PMP);
- Low-level mercury monitoring of the plant's influent and effluent;
- A requirement that the annual average mercury effluent concentration is less than or equal to 12 ng/l as specified in the plan of study;
- A summary of the elements of the plan of study;
- A requirement to submit an annual report on implementation of the PMP; and
- A requirement for submittal of a certification stating that all permit conditions related to implementing the plan of study and the PMP have been satisfied and whether compliance with the monthly average water quality based effluent limit for mercury has been achieved.